Routine Lab -

Mr. Barker -

Shipping today 20 - 400# drums of "Diphenyl Chloride Compound #11476", our Lot # 74. Two copies of laboratory report go to C. H. Crome, Canadian General Electric Co. Peterborough, Ontario, Canada.

Sp Gr	1.499
Color	< 1/4
Resist	2000 x 10^9
Pour Pt	12°
Vis	46.0 "
Cl	.01 ppm
Heat Loss	.1
Acid No.	.004

4/3/41

DSW 331059

STLCOPCB4077703