

PLAINTIFF'S
EXHIBIT
TN 5007

Dr. J. H. Collier
T.B.A. Co. Ltd.
Rochdale
Mr. W. J. Howard
Turner & Newall Ltd.
Manchester

1945/04/15/1945

20th June 1945

Manchester Central Library

A long time ago I promised to let you have the results of dust tests taken in Manchester Library five months after spraying had taken place. These are now shown on the attached sheet and are taken as an average of two tests by membrane filter method.

I doubt whether the use of these figures would help us in any way as they would only show that there is some asbestos still present albeit in very small quantities, i.e. near the negligible level and it is possibly less now.



20/880-3

	5/6 hours after spraying	5 months after spraying
		26.1.69
Great Hall	1.3	.02
Stack 1	.19	.02
Stack II	.12	.02
1st Floor Desk	.17	.02
General Readers Library	.14	.015
Commercial Library	.12	.02