

DOW CHEMICAL LAD
SOLVENTS / EDC 1

1990 ASBESTOS SURVEY UPDATE

THE ATTACHED SURVEY WILL SERVE AS AN AID TO AVOIDING ASBESTOS CONTACT FROM KNOWN SOURCES LOCATED WITHIN OUR PLANT. THE SURVEY INCLUDES BOTH PLANT PROCESS AREAS AND BUILDINGS. IF YOU ARE WORKING IN AN AREA THAT HAS ANY KNOWN ASBESTOS MATERIALS SUCH AS INSULATION, (AS DENOTED BY THE LABEL SHOWN AT BOTTOM OF PAGE), YOU NEED TO TAKE EXTRA PRECAUTION SO YOU DO NOT DISTURB IT.

IF YOU ARE ASSIGNED A JOB ON A PIECE OF EQUIPMENT OR IN AN AREA THAT YOU HAVE REASON TO BELIEVE MAY CONTAIN ASBESTOS MATERIALS, CONSULT YOUR SUPERVISOR IMMEDIATELY. DO NOT ATTEMPT TO REMOVE THE MATERIALS, NO MATTER HOW SMALL THE JOB OR HOW LITTLE ASBESTOS IS INVOLVED. THERE IS AN ASBESTOS REMOVAL TEAM AT OUR DISPOSAL (PETRIN INSULATORS FOREMAN DANIEL CORTEZ IS THE CONTACT).

IN AN EMERGENCY, SOME ASBESTOS MATERIALS MAY BE REMOVED BY FOLLOWING THE LOUISIANA DIVISION POLICY IF THE ASBESTOS WILL NOT BE DISTURBED (SEE ATTACHED PROCEDURE). YOUR COOPERATION IN THIS MATTER IS MANDATORY.

THERE IS ONE PLACE LEFT IN THE SOLVENTS / EDC 1 PLANT PROCESS AREAS THAT STILL CONTAINS KNOWN ASBESTOS INSULATION, THE STRUCTURAL I-BEAMS IN THE EDC A-1E REACTOR AREA. AN ADDITIONAL 3 FOOT SECTION OF ASBESTOS INSULATION WAS ALSO LOCATED IN THIS AREA WITH REMOVAL SCHEDULED DURING THE FIRST QUARTER OF 1991.

THERE ARE SEVERAL BUILDING AREAS WITH ASBESTOS MATERIALS THAT ARE INTACT AND IN USE. PLEASE CONSULT THE ATTACHED SURVEY BEFORE STARTING WORK IN ANY BUILDING IN THE PLANT AS A PRECAUTION TO AVOID CONTACT WITH ASBESTOS MATERIALS IN THESE AREAS.

THANK YOU,
MIKE BROWN

DOW CHEMICAL LAD
SOLVENTS / EDC 1
1990 ASBESTOS SURVEY

AN ASBESTOS MATERIALS SURVEY UPDATE WAS COMPLETED IN 12-90 FOR THE SOLVENTS / EDC 1 PLANT. THE FOLLOWING DETAILS THE ASBESTOS MATERIALS LOCATED IN THE PLANT AND ABATEMENT ACTION TAKEN OR PLANNED AS NEEDED.

BLOCK 16 PROCESS AREAS - NONE FOUND.

D-2C ASBESTOS INSULATION WAS REMOVED AND REPLACED WITH OTHER MATERIALS.
ASBESTOS INSULATION ON 1" STEAM LINE (SOUTH END FIN FAN DECK IN PER/TET AREA) WAS REMOVED AND REPLACED WITH OTHER MATERIALS.
OLD CL2 ANALYZER BUILDING WAS REMOVED.

1601 BUILDING - ASBESTOS INSULATED STEAM LINE BEHIND SOUTH CONTROL BOARD. GOOD CONDITION - NO ACTION TAKEN AT THIS TIME.

ASBESTOS INSULATED A/C CONDENSATE RETURN LINE LOCATED IN WOMENS RESTROOM. INSULATION WAS ENCAPSULATED IN 1988. GOOD CONDITION - NO ACTION PLANNED AT THIS TIME.

1602 BUILDING - DAMAGED TRANSITE ELECTRICAL INSULATION BETWEEN BUSES ENCAPSULATED 1989.
GOOD CONDITION - NO ACTION PLANNED AT THIS TIME.

NONE FOUND IN REMAINDER OF AREAS IN BUILDING.

1604 BUILDING - ONE ASBESTOS INSULATED STEAM LINE FOUND ABOVE LAB CEILING. GOOD CONDITION - NO ACTION TAKEN AT THIS TIME.

AHCL MCC I - TRANSITE EXTERIOR. DAMAGED PLACE ENCAPSULATED IN 1989. GOOD CONDITION - NO ACTION PLANNED AT THIS TIME.
TRANSITE ELECTRICAL INSULATION BETWEEN BUSES, DAMAGE ON BOTH ENDS WAS ENCAPSULATED IN 1988.
GOOD CONDITION - NO ACTION PLANNED AT THIS TIME.

AHCL MCC II - NONE FOUND.

AHCL HOUSE - TRANSITE EXTERIOR. GOOD CONDITION - NO ACTION PLANNED AT THIS TIME.

BLOCK 17 PROCESS AREAS - R-1E REACTOR AREA STRUCTURAL I-BEAMS HAVE ASBESTOS CONTAINING FIRE-PROOF COATING. SEVERAL PLACES NEED TO BE ENCAPSULATED. REMOVAL IS NOT PLANNED.

1" PROCESS LINE LOCATED WEST OF R-1E WITH APPROXIMATELY 3 LINEAR FEET OF ASBESTOS INSULATION. REMOVAL SCHEDULED FOR 1st QUARTER OF 1991.

ASBESTOS INSULATION ON CL2 LINE TO R-1D ENCAPSULATED 1990. ASBESTOS INSULATION ON OLD CL2 LINE IN EAST-WEST PIPERACK SOUTH OF R-1E REMOVED 1990.

- 1701 BUILDING - BUILDING COMPLETELY REMODELED. NO ASBESTOS CONTAINING MATERIALS WERE FOUND.
- 1701 MCC - DAMAGED TRANSITE ELECTRICAL INSULATION BETWEEN BUSES ENCAPSULATED 1989. GOOD CONDITION - NO ACTION PLANNED.
- 1702 BUILDING - GASKET ROOM VACUUMED AND CLEANED 10-90. RESCHEDULED 4-91. NONE FOUND IN REST OF AREA.
- 1702 DRUM HOUSE - TRANSITE EXTERIOR. GOOD CONDITION - NO ACTION PLANNED.
- 1703 LAB - NONE FOUND.
- 1704 BUILDING - GASKET AREA VACUUMED 10-90. RESCHEDULED 4-91. NONE FOUND IN REST OF AREA.
- ANALYZER HOUSE - NONE FOUND.
- RW PUMP MCC - NONE FOUND.
- BATTERY ROOM - NONE FOUND.