



Interoffice Communication

To DISTRIBUTION
From C. R. Miller
Date January 21, 1980
Subject D-400 REACTOR RELIEF VALVE DISCHARGE

The following are the list of steps that were discussed in this mornings meeting:

1. The operating procedures were revised immediately after the D-400 release to help determine when a reactor was empty. This procedure needs to be formalized and instructions given to lead operators. - MPB & JEB
2. An investigation into a possible level device to prevent reactor overfilling is to be done by MPB.
3. Expedite delivery of amp meter for D-400. - JAD
4. Investigate relocation of remote camera or revision to swirl piping to allow monitoring by lead operator. - JAD
5. Estimate cost to install amperage recorders on each reactor to serve as backup. - JAD
6. Determine quantity of VCM emission from available data. - RAF
7. Obtain all data necessary for EPA report. - RAF
8. A detailed investigation and write-up is to be done by CRM, JEB and MPB.
9. Make recommendations of possible solution to prevent reoccurrence. ALL

C. R. Miller

C. R. Miller

jf

DISTRIBUTION: MPB, JEB, RAF, JAD, AHS

DTH 000084427