

Mr. L. J. Wright

February 24, 1966

L. E. Clark, Jr.

L. C. McLean

Fairfield Works Standards for
Roofing and Siding

The attached "Fairfield Works Standards for Roofing and Siding" has been prepared in order to submit it to American Bridge Division in response to their request. Please review it and indicate your approval or recommended changes.

2-25-66
Chief Engineer

LCMcLean/bf

Encl.

FAIRFIELD WORKS STANDARDS FOR ROOFING AND SIDING

1. TYPE

- 1.1 - Pre-painted, galvanized, corrugated sheets will be used for all new buildings, and for replacement of roofing and siding on existing buildings when complete roofing and/or siding is replaced. Sheets will be furnished by Fairfield Works in 27-1/2" widths for roofing and 26" widths for siding. Only touch-up field painting will be required.
- 1.2 - Standard 1.25 ounce coated 27-1/2" wide roofing and 26" wide siding shall be used for repairs that include partial replacement of roofing and siding. These sheets shall be field painted.
- 1.3 - In special cases, 2.5 ounce coated 38" wide roofing and 37" wide siding; stainless steel; or coated sheets may be required. Fairfield Works will provide American Bridge with the necessary specifications in these particular situations.

2. MAXIMUM AVAILABLE LENGTHS

- 2.1 - 27-1/2" wide, 24, 22 and 20 gauge - 14' length
- 2.2 - 27-1/2" wide, 18 gauge - 12' length
- 2.3 - 26" wide, 26, 24, 22 and 20 gauge - 14' length
- 2.4 - On special orders 16' lengths may be obtained in 26 through 20 gauge.

3. ERECTION OF CORRUGATED ROOFING AND SIDING

- 3.1 - Attached general specification "Removing and Erecting Corrugated Roofing and Siding" dated June 18, 1964 provides Fairfield Works erection standards.

LCMcLean/bf
2-24-66

USHO 002862