

Refrigeration, Air Condition, and Heat Pump (RACHP) Field Inspection Worksheet for products subject to 40 CFR Part 84, Subpart B

version 12.03.2024

Use this form for:

All RACHP Products (not all fields will be applicable for every product)

General Inspection Information

Inspection Number:	CT-2-13-25-01	Inspector(s):	Christine Tokarz
Insp. Date:	2/13/2025	Photographer(s):	Christine Tokarz
Insp. Time Start/End:	8:30 am / 10:30 am	Photograph # Range:	IMG_0203 to IMG_0238

Location of Inspection

Facility Name:	ATS Logistics	Facility Type:	CES Warehouse
Address:	4033 W Montague Ave, North Charleston, South Carolina 29418	CBP POC Information:	Officer Bonnie Tupper, bonnie.s.tupper@cbp.dhs.gov

Import Documents Collected

Check all that Apply					
Entry Summary:	☒	Packing List:	☒	Describe "Other" Documents:	Original Shipping/Targeting documents
Bill of Lading:	☒	Invoice:	☒		
Other (Please Describe):	☒				

Shipment Information (from Entry Docs)

Entry/Shipment No:	CDY-03572451
Arrival/Import Date:	28-Jan-25
Entry File Date:	

☐ Check box if entry was not filed at time of inspectionImporter Information (from Entry Docs)

Name:	Florim USA
Address:	300 International Boulevard
City/State/Zip:	Clarksville, Tennessee 37040
POC Name & Title:	Greg Haupt, Purchasing Manager
Email & Phone:	GHaupt@FlorimUSA.com

Consignee Information (from Entry Docs)

Check box if the same as Importer:	☒
Name:	
Address:	
City/State/Zip:	
POC Name & Title:	
Email & Phone:	

Other Contacts (optional):

Other CBP Officers that assisted: TOMMASINI, JOSEPH J <JOSEPH.J.TOMMASINI@cbp.dhs.gov> , Shipper was General Noli USA Inc., 154-89 146th Avenue, 3rd Floor, Jamaica New York, New York 11434

Contents of Shipment from Import Documents

(Add additional lines in separate sheet as needed)

Item #	Product Description/Subsector	Indicated HFC(s)	Listed Quantity
1	Air Conditioner ANL 100H6 (product)	R410A	12Kg per product
2	Compressor Tecumseh TAG4534Y 230 V	R134A	none

Physical Inspection and Label Information required by 84.58(a)

Item #	Product Manufacturer	Product Name on Package	SKU	HFC or GWP Indication on label	DOM	Listed Charge	Units	Quantity
1	Aermec	Single Wall Heat Exchanger ANL100HA		R-410A	2024 (no day or month)	12.7	kg	4
2	Tecumseh	TAG4537Y		R-134A	none listed	none listed		3
3	Aermec	Rectangular Filters		none	none listed	none listed	g oz.	4
4		Ducts		none	none listed	none listed	g oz.	various
							g lb	

Comments (include areas of concern (e.g., no label observed))

Shipping Documents prior to entry had the following cargo description, "Dangerous Goods==1 pkg GW 3114,00 KG NW 2200,00 KG UN 2857, REF Refrigerating Machines, Class 22, EMS: F-C, S-V 1 X Wooden Box Containing 4 Refrigerating Machines X 550 KG Each (Gas R410A12.7 KG Each) Air Conditioner/Compressor HS Code 841510". The Heat Exchangers were each charged with 12.7 kg of R410A (>700GWP). Compressors were empty and label included "R-134a".

Inspector Signature & Date:

CHRISTINE TOKARZ Digitally signed by CHRISTINE TOKARZ
Date: 2025.03.03 13:22:36 -07'00'

Supervisor Signature & Date:

AMELIE ISIN Digitally signed by AMELIE ISIN
Date: 2025.03.03 15:28:07 -05'00'