

ORDER RECORD

S.O. 40164-B

TURBINE

DEPT. (BY REL) 12-12-47

E- 131062

(DATE ISSUED)

DESIRED SHIPPING DATE

SCHEDULED SHIPPING DATE

AUGUST 1948

TYPE OF PLANT POWER

NO. UNITS

THREE

SOLD WITH

(GIVE M.O. OR S.O. NOS. OTHER EQUIP.)

FORM 1081-B TURBINES


SERVICE RECORD	USER		SER. NO.
	OKLAHOMA A & M COLLEGE		13589
SHIPPED	STATE	CITY	S.O.
	OKLA.	STILLWATER	40164-B
	PURCHASER		GEAR SER. NO.
	AMERICAN BLOWER CORP.		-----
	ADDRESS		
	DETROIT, MICHIGAN		
TURB. ROTATION (FACING GOV.)	ENGINEER	DATED	E- 151062
	COSTON & FRANKFORT	11-26-47	DATE 12-12-47
CLOCKWISE	H.P. <u>13</u>	TYPE TURB. <u>2AYR</u>	GEAR <u>V-27</u>
CLOCKWISE	R.P.M. TURB. <u>4200</u>	R.P.M. GEAR <u>1500 (2.8 = 1)</u>	
GENERATOR	TYPE GOV. <u>STANDARD & EMERGENCY</u>		BEARINGS - (S.O.) - <u>---</u>
M.O.	STEAM CONDITIONS <u>250° - 600° F.T.T. - 10# B.P.</u>		
SERIAL	HAND VALVES <u>ONE</u>		EN. (FACING GOV.) - (R.H.) - <u>(S)</u>
EXCITED	CASING MATERIAL <u>HALF & HALF</u>		
M.O.	DRIVEN MACHINE <u>F. D. FAN</u>		
SERIAL			

SUPERHEAT PARTS ☒ YES ☐ NO ☒ 600° ☐ 750° ☐ SPECIALHAND SPEED CHANGER ☒ YES ☐ NO ☐ SPEED RANGE PLCS OR MINGS 5%PRESS. REG. ☐ YES ☒ NO ☐ CONST. ☐ EXCESS ☐ BUILT-IN ☐ SEPARATE ☐ SPECIALPRESS. REG. CONDITIONS --- 90 PUMP DISCH. PR. --- 9 EXCESS PR.MOUNT PURCHASER'S HALF COUPLING ☒ YES ☐ NOTURB. (OR GEAR) SHAFT END ☒ STD. ☐ SPECIALGEAR OFFSET (FACING GOV.) ☐ RIGHT ☐ LEFT ☒ VERT.RANGE OF VAR. SPEED OIL GOV. --- TO --- RPM.BASEPLATE ☐ YES ☒ NO SOLEPLATE ☒ YES ☐ NO DRIP RIM ☐ YES ☒ NO ☐ SPEC.INSULATION & LAGGING ☒ YES ☐ NO ☒ PAINTED ☐ STHL. STEEL ☐ SPEC.DRIVEN MACHINE COUPLING ☐ YES ☒ NO ☐ SPEC.DRIVEN MACHINE FURNISHED BY ☐ ELLIOTT ☒ PURCHASER MOUNT DRIVEN MACHINE ☐ YES ☒ NOSTEAM STRAINER ☒ STD. ☐ SPEC.COUPLING BETWEEN TURB. & GEAR ☐ STD. ☒ SPEC. BUILT-IN GEAROIL COOLER ☒ STD. ☐ SPEC. --- WATER TEMP. --- °F ☐ FRESH ☐ SALTH.V. SETTING FOR 6.5 H.P., ALL OTHER CONDITIONS THE SAME.

SPECIAL

FIRM PRICE
CUM OIL FILTER

3-47 70032 © Dittoforma

PROVIDE 13 PRINTS FOR (APPROVAL) (200548)PROVIDE 1 INSTRUCTION BOOKS PAINTING REQUIREMENTS PS-402PAINTING REQUIREMENTS: ☒ STD. ☐ SPEC.TEST OR INSPECTION NONESHIPPING PREPARATION: ☒ STD. ☐ SPEC.CONTRACT PRICE --- UNIT CONTRACT PRICE --- UNIT WEIGHT 18500TERMS: ☒ NET 30 DAYS ☐ STD. CONTRACT ☐ PENALTY ☐ BOND REQUIRED
☐ SPECIAL

ET-000021

FIELD WORK

☒ NONE☐ SUP'T. ONLY☐ COMPLETE ERECTION

APPROVAL

APPROVED BY DATE

ENGINEER

200	5/21/48
-----	---------