denser, six or more times as much heat may be obtained theoretically (and three to five times practically) as the heat equivalent of the work necessary to operate the system. There are a number of limitations, however, the most serious of which is the lack of ready availability of a practical source of heat.

One of the major problems in the development of the heat pump involves research on, and the compilation of reliable design data for, the various heat sources and sinks available. The four principal potential sources of heat are air, water, earth, and solar energy. Of these, the first three are primary sources of heat which may be used alone. The fourth, solar energy, while of tremendous potentiality, will probably be developed in most localities as auxiliary to the other three. In addition, there are other minor sources such as process waste heat, sewage, etc., which may be used under special circumstance.

There are also a number of industrial applications of heat pumps, for purposes other than space heating, which are practical largely through economic considerations of the particular process involved. Table 5 presents a summary of the advantages and disadvantages of each of these major heat sources.

By reference to Table 5, it will be seen that, to date, the most satisfactory heat sources are air, water, and earth, and that air and water are the most satisfactory heat sinks. There are, therefore, six possible combinations of source and sink in application: air to air, air to water, water to air, water to water, earth to air, and earth to water. In addition, it should be recognized that heat storage devices may be used with any of these systems involving either a single or a dual heat source. One promising possibility involves the utilization of a storage pit or cistern operating upon a heat of fusion cycle and supplied by supplementary heat from air or solar sources. Heat of fusion may, for example, also be utilized with city water and sewage disposal to increase the practicability of these sources.

When heat is to be obtained from a ground coil it should be emphasized that, in general, the heat extracted must be replaced by heat from the sun, received by radiation to the ground or by heat carried into the ground by rain.

Combinations of heat sources, such as air and water, air and ground, air and solar energy, or ground and solar energy, may also be used and will frequently improve the coefficient of performance over an entire heating season; but they will probably result in considerably greater initial cost. A typical arrangement of a heat pump system with air as the heat source is shown in Fig. 10.

Both water and air are practical media to which the condenser heat may be rejected; but the generation of steam requires too high a condenser temperature. Practical operation, therefore, dictates that the heat pump be used in conjunction with either an air or water heating system with actual distribution of the heat to the rooms through either air ducts, convection radiators, or panels.

In general, it is believed that the future of this device is very promising, and it is recognized that there are a number of practical and economical systems in operation at the present time. However, design data for the majority of types of systems are inadequate, and it is therefore recommended that the enthusiasm and the interest which have greeted the emergence of the heat pump from the category of a scientific toy to one of practical application, should be tempered with caution, since it

TABLE 5. HEAT PUMP HEAT SOURCES AND SINKS

Heat Source	Air	City Water	Well Water	Surface Water	Waste Water	Earth	Solar
Source Classification	Primary	Primary or auxiliary	Primary	Primary	Primary or auxiliary	Primary or auxiliary	Auxiliary
Suitability as Heat Sink	Good	Good	Good	Good	Variable with source	Usually poor	None
Availability (Location)	Universal	Cities	Uncertain	Rare	Limited	Extensive	Universal
Availability (Time)	Continuous	Continuous—except local shortages	Continuous—unless well runs dry	Continuous	Variable	Continuous, temperature level drops from a maximum to a minimum as heat is removed, slowly rises when pump is inoperative	Intermittent. Unpredictable, except over extended time
Expense (Original)	Low, less than earth and water sources except city	Usually lowest	High, result of drilling well	Low	Variable	High, usually less than the cost of drilling a well	Unexplored
Expense (Operating)	Relatively low	High, usually prohibitive	Low to moderate	Relatively low	Relatively low	Relatively moderate	Unexplored. Promising as auxiliary for reducing operating cost
Temperature (Level)	Favorable 75-98% of time in most of U. S.	Usually satisfactory	Satisfactory	Satisfactory	Usually good	Initially good—drops with time and rate of heat withdrawal	Excellent
Temperature (Variation)	Extreme	Variable with location (10 to 25 F Deg)	Small	Moderate	Usually moderate	Large—less than for air, however	Extreme
Design Information	Inadequate	Usually adequate	Usually adequate	Usually adequate	Adequate if source is constant in supply and temperature	Inadequate	Practically available
Size of Equipment	Particularly bulky	Moderate	Moderate (except well)	Moderate	Variable (usually moderate)	Moderate (except ground coils)	Probably bulky
Adaptability to Mass Production	Excellent, can be factory assembled and tested	Excellent	Excellent, (except well)	Excellent	Poor	Fair	Fair
Sources it may Augment		Air, earth				Air, water	Air, earth, water
Special Problems	Least heat available when demand greatest. Coils may become frosted requiring extra capacity, alternate source, or standby heat. May require duct work. Variable air temperature makes control difficult.	Scale on coils. Local use restrictions during shortages. Disposal. Water temperature may become too low to permit further heat removal.	Corrosion, scale may form on heat transfer surfaces. Disposal. Water location, temperature, composition usually unknown until well drilled. Well may run dry.	Water may cause scale, corrosion, and algae fouling.	Usually scale forming or corrosive. Often in sufficient supply. Very limited application, hence require individual design.	Limited by local geology and climate. Installation costs difficult to estimate. Requires considerable ground area, may damage lawns, gardens.	Probably will require heat storage equipment at either evaporator or condenser side.