

- 14—Physiological Response of Subjects Exposed to High Effective Temperatures and Elevated Mean Radiant Temperatures, by C. M. Humphreys, Oscar Inalis and Carl Gutberlet (A.S.H.V.E. JOURNAL SECTION, *Heating, Piping & Air Conditioning*, March, 1946, p. 101).
- 15—Life, Heat and Altitude, by David B. Dill (Harvard University Press, Cambridge, 1938).
- 16—The Upper Limits of Environmental Heat and Humidity Tolerated by Acclimatized Men Working in Hot Environments, by Ludwig W. Eichna, William F. Ashe, William B. Bean and Walter B. Shelley (*The Journal of Industrial Hygiene and Toxicology*, Vol. 27, March, 1945, p. 59).
- 17—A.S.H.V.E. RESEARCH REPORT No. 1188—Local Cooling of Workers in Hot Industry, by F. C. Houghten, M. B. Federber and Carl Gutberlet (A.S.H.V.E. TRANSACTIONS, Vol. 47, 1941, p. 403).
- 18—A.S.H.V.E. RESEARCH REPORT No. 673—Determination of the Comfort Zone, by F. C. Houghten and C. P. Yaglou (A.S.H.V.E. TRANSACTIONS, Vol. 29, 1923, p. 361). A.S.H.V.E. RESEARCH REPORT No. 691—Cooling Effect on Human Beings Produced by Various Air Velocities, by F. C. Houghten and C. P. Yaglou (A.S.H.V.E. TRANSACTIONS, Vol. 30, 1924, p. 193). A.S.H.V.E. RESEARCH REPORT No. 717—Effective Temperature with Clothing, by C. P. Yaglou and W. E. Miller (A.S.H.V.E. TRANSACTIONS, Vol. 31, 1925, p. 89). A.S.H.V.E. RESEARCH REPORT No. 755—Effective Temperature for Persons Lightly Clothed and Working in Still Air, by F. C. Houghten, W. W. Teague and W. E. Miller (A.S.H.V.E. TRANSACTIONS, Vol. 32, 1926, p. 315). How to Use the Effective Temperature Index and Comfort Charts, by C. P. Yaglou, W. H. Carrier, Dr. E. V. Hill, F. C. Houghten and J. H. Walker (A.S.H.V.E. TRANSACTIONS, Vol. 38, 1932, p. 410).
- 19—A.S.H.V.E. RESEARCH REPORT No. 1196—Comfort with Summer Air Conditioning, by Thomas Chester, N. D. Adams, C. R. Bellamy, G. D. Fife, E. P. Heckel, Dr. W. J. McConnell, F. C. McIntosh, A. B. Newton, B. F. Raber and C. Tasker. (A.S.H.V.E. TRANSACTIONS, Vol. 48, 1942, p. 107).
- 20—Conditions for Comfort, by C. S. Leopold (A.S.H.V.E. JOURNAL SECTION, *Heating, Piping and Air Conditioning*, June, 1947, p. 117).
- 21—A.S.H.V.E. RESEARCH REPORT No. 1102—Shock Experiences of 275 Workers After Entering and Leaving Cooled and Air Conditioned Offices, by A. B. Newton, F. C. Houghten, Carl Gutberlet, R. W. Qualley and M. C. W. Tomlinson (A.S.H.V.E. TRANSACTIONS, Vol. 44, 1938, p. 571).
- 22—A.S.H.V.E. RESEARCH REPORT No. 1055—Cooling Requirements for Summer Comfort Air Conditioning, by F. C. Houghten, F. E. Giesecke, C. Tasker and Carl Gutberlet (A.S.H.V.E. TRANSACTIONS, Vol. 43, 1937, p. 145).
- 23—A.S.H.V.E. RESEARCH REPORT No. 1012—Study of Summer Cooling in the Research Residence for the Summer of 1934, by A. P. Kratz, S. Konzo, M. K. Fahnestock and E. L. Broderick (A.S.H.V.E. TRANSACTIONS, Vol. 41, 1935, p. 207).
- 24—A.S.H.V.E. RESEARCH REPORT No. 755—Effective Temperature for Persons Lightly Clothed and Working in Still Air, by F. C. Houghten, W. W. Teague and W. E. Miller (A.S.H.V.E. TRANSACTIONS, Vol. 32, 1926, p. 315).
- 25—Application of Air Conditioning to Premature Nurseries in Hospitals, by C. P. Yaglou, Philip Drinker and K. D. Blackfan (A.S.H.V.E. TRANSACTIONS, Vol. 36, 1930, p. 383).

AIR CONDITIONING IN THE PREVENTION AND TREATMENT OF DISEASE

Control of Airborne Infection, Value of Air Cooling Under Tropical Conditions, Treatment of Disease, Operating Rooms, Nurseries for Premature Infants, Fever Therapy, Cold Therapy, Allergic Disorders, Oxygen Therapy, General Hospital Air Conditioning

THE late war has caused an increase of interest in the preventive aspects of air conditioning. It has re-emphasized the importance of the control of airborne infection and has demonstrated the value of air cooling under tropical conditions for the prevention of heat rash, for promoting proper rest and sleep, and in the convalescence of patients.

CONTROL OF AIRBORNE INFECTION

Any program of air sanitation is influenced by a number of factors. In the winter months, the closing of doors, windows and other means of access to the outside air to conserve warmth as well as the crowding of persons indoors provides conditions conducive to a high incidence of contagion. This seasonal phenomenon, illustrated in Fig. 1 which represents a study made by the U. S. Public Health Service, will concern the ventilating engineer in so far as air quality, determined by temperature, humidity, air replenishment and type of air movement and by freedom from contamination, is a major intrinsic factor. Apart from the seasonal picture of airborne contagion are such extrinsic factors as rate of turnover of personnel and the marked susceptibility of the recruit in comparison with permanent personnel¹ as shown in Fig. 2 by studies of military personnel housed in barracks. These extraneous variables and the factor of contact infection (direct spray) tend to complicate any evaluation of the effectiveness of air sanitation for elimination of microorganisms in droplet-nuclei and droplet-dust. Thus, control measures may eliminate consistently 90 per cent of airborne organisms in laboratory tests, but cannot effect a decrease in actual incidence of infection exceeding 30 per cent. Thirty per cent may be the maximal reduction in infection possible by air treatment methods. The distinction should be clearly drawn, therefore, between the effectiveness of a procedure in laboratory tests and its effectiveness and applicability in actually reducing the incidence of airborne disease.

The following sequence of events has been postulated as occurring in a large proportion of intra-ward infections: (a) ejection of relatively large protected infective particles from patients, (b) rapid venting or settling of these particles so that those remaining airborne are in low concentration, (c) survival of infective particles to permit the accumulation of high concentrations on surfaces, (d) repeated reintroduction of infective particles into the air under the stimulus of ward activities or by air currents of the order of 50 fpm over the floor, and (e) extension of infective areas by air turbulence throughout the ward or hospital. The most important link in this probable infection chain has been demonstrated to be the reintroduction of particles into the air².

Intensive studies on air disinfection have indicated two distinct control