





Region 6 Compliance Assurance and Enforcement Division
INSPECTION REPORT

Inspection Date(s):	10/10/2017		
Media:	Water		
Regulatory Program(s)	Clean Water Act		
Company Name:	City of New Iberia		
Facility Name:	City of New Iberia-HWY 14 WWTP #4		
Facility Physical Location:	800 Sucrose Drive		
(city, state, zip code)	New Iberia, LA 70560		
Mailing address:	800 Sucrose Drive		
(city, state, zip code)	New Iberia, LA 70560		
County/Parish:	Iberia Parish		
Facility Contact:	Vince Palumbo	Director	
	337-369-2362		
FRS Number:	1100010698183		
Identification/Permit Number:	LA0120201		
Media Number:	A#106791		
NAICS:	221320		
SIC:	4952		
Personnel participating in inspection:			
Michael Williams	EPA / 6EN-WMH	Inspector	281-983-2150
Shane Miller	LDEQ	Inspector	505-366-8402
Vince Palumbo	City of New Iberia	Director	337-369-2362
Johnny Romero	City of New Iberia	Plant Supervisor	337-369-2362
EPA Lead Inspector Signature/Date	 Michael D. Williams		12/15/17 Date
Supervisor Signature/Date	 Carol Peters		12/18/17 Date

Section I - Introduction

PURPOSE OF THE INSPECTION

EPA Region 6 inspector, Michael Williams, arrived at City of New Iberia-HWY 14 Wastewater Treatment Plant (WWTP) at 12:26 pm on October 10, 2017 for an unannounced inspection. LDEQ inspector, Shane Miller were present and assisted with the inspection. We met with Vince Palumbo, New Iberia Director. I presented my credentials to Vince and informed him that this was an EPA lead inspection to determine compliance with the Clean Water Act and the 2005 Consent Decree. The scope of the inspection was with permit LA0120201, the facility operation and maintenance under the Clean Water Act.

The information presented in this report is based on the materials and information supplied by the City of New Iberia, representatives (the permittee), observation during the inspection and records and reports maintained by the permittee.

FACILITY DESCRIPTION

City of New Iberia-HWY 14 WWTP is located in New Iberia, LA. The plant was built in 2007 as apart Consent Decree that the City of New Iberia is under. The plant is a Sequencing Batch Reactor (SBR) system. The plant consists of grit removal chamber, bar screen, 8 SBR aeration basins, 2 chlorine chambers, digester, dewatering facility with belt press. Sludge is transferred to the Tete Bayou Plant for lime treatment. The design flow for the plant is 6 MGD.

Section II- Observations

This inspection revealed the following observations:

- During the inspection all areas were well maintained and all essential units were operating adequately. The records and reports form the months of August and September 2017 were reviewed.
- The site has algae blooms that occur during the summer months due to the East to West orientation of the plant with direct sunlight exposure.

Section III- Areas of Concerns

This inspection revealed the following areas of concerns:

- No other major area of concerns during the inspection.

Section IV – LIST OF APPENDICES

- No Appendices