PLAINTIFF'S EXHIBIT USM-236

001417 0033

RESEARCH

J. F. O'Rourke

F. M. Stumpf

August 30, 1966

Complaint

Patching Fiber Complaint - Boiler Room, Student Union Hospital Building, University of Maryland, Baltimore, Md. - Stebbing Company.

The above job consists of 600 square feet of concrete ceiling area in a boiler room which is very cluttered with pipe, and therefore impossible to spray. Limited tests by Research indicated Patching Fiber could be hand applied.

The first shipment was 40 bags, of which about 10 worked satisfactorily and the rest gave difficulty, and therefore Stebbing requested new materials which make the Patching Fiber usable.

The plant apparently shipped another 20 bags using more of the binder and of this a few bags were good and the rest no good.

Last week, under the supervision of the Research Department, some 25 bags of Patching Fiber were made, of which 14 were taken by the writer to Baltimore and on Saturday, August 27, they were used to finish the job with no difficulty.

Harry Schneider will be discussing this with Stebbing Company, since they are going to look for some help from the several Saturdays lost in labor because of difficulty with the Patching Fiber.

FMS/ec

cc:
J. P. Verhalen
R. R. Schlenker
E. W. Fairweather

File

Stumpf #