

FILE NAME: Allied Signal Bendix (ASB)


DATE: 1968 Jan 18

DOC#: ASB035

DOCUMENT DESCRIPTION: NY Dept of Labor Memo - Notice of Plan Approval



State of New York
Department of Labor
DIVISION OF INDUSTRIAL HYGIENE
80 CENTRE STREET
NEW YORK, N.Y. 10013



Bendix Corporation
Friction Materials Division
P.O. Box 238
Troy, New York

ADDRESS REPLY TO:

DATE

January 18, 1968

Att: Mr. David E. Stone
Plant Engineer

NOTICE OF PLAN APPROVAL

Plan No. EP-2089-67 Brake Drilling
Location of System

Tibbits Avenue, Green Island, New York

Building: 4B
Department: Drilling

We are pleased to advise you that the plans you submitted to the Department of Labor for an exhaust system to be installed or altered have been approved. One set of these plans is returned herewith.

The above plan is approved subject to the following:

1. Since asbestos dust is being created, the final test shall be based on dust counts.
2. These plans have been held in abeyance pending receipt of additional information.

When the system has been installed or altered, and is ready for test, kindly notify the office of the Division of Industrial Safety Service at the following address: New York State Department of Labor, Division of Industrial Safety Service,

State Campus, Bldg. 12, Room 423, Washington Ave., Albany, N.Y. Att: E. F. Romer, Supv. Insp.

This approval is based upon conformance to standards and requirements of the Labor Law and to the applicable Industrial Codes of the State of New York. You are responsible for determining whether emissions from the system meet the requirements of any local air pollution ordinances. If any alterations or additions to the above system are required which change its operating characteristics, it will be necessary for you to submit revised plans to the Division of Industrial Hygiene for approval prior to making such alterations or additions.

MSh:pc

MORRIS KLEINFELD, M.D.
Director
For The Commissioner