

Environmental Protection Act, or 40 CFR 51, Appendix P (this incorporation includes no later amendments or editions.) to convert sulfur dioxide or nitrogen oxide continuous emissions data to units of the applicable emission standard applicable to that source.

2) Sulfuric acid plants of greater than 300 tons per day production capacity, the production being expressed as 100 percent acid, shall monitor for sulfur dioxide at each point of sulfur dioxide emission.

3) Nitric acid plants of greater than 300 tons per day production capacity, the production capacity being expressed as 100 percent acid, located in an Air Quality Control Region where the Administrator, U.S. Environmental Protection Agency, has specifically determined pursuant to Section 107 of the Clean Air Act that a control strategy for nitrogen dioxide is necessary to attain the national standard, shall monitor for nitrogen oxides at each point of nitrogen oxide emission.

4) Petroleum refineries shall monitor for opacity at each catalyst regenerator for fluid bed catalytic cracking units of greater than 20,000 barrels per day fresh feed capacity.

b) Except for sources permitted to use alternative monitoring pursuant to Section 201.402, compliance with the Illinois emissions limitations by the owners and operators of emission sources required to monitor continuously shall be determined by the use of equipment which meets the performance specifications set forth in paragraphs 3.1 through 3.8 of 40 CFR 51, Appendix P (1987) (this incorporation includes no later amendments or editions), and relevant portions of 35 Ill. Adm. Code 230, Appendix A and B.

(Source: Added at 13 Ill. Reg. 2066, effective February 3, 1989)

Section 201.402. Alternative Monitoring

Alternative monitoring requirements for sources subject to Section 201.401(a) shall be prescribed by permit upon a demonstration by the owner or operator that continuous monitoring is technically unreasonable or infeasible due to physical plant limitations or would impose an extreme economic burden. It shall be demonstrated that the installation, location or operation of a continuous monitoring system or device:

a) Would not provide accurate determinations of nitrogen dioxide, sulfur dioxide, carbon dioxide, percent oxygen, or opacity; or

b) Cannot be installed due to the facility's physical constraints such as size, space or strength of materials, or due to safety considerations; or

c) Would impose an extreme economic burden in proportion to the significance of the monitoring information which would be provided, in that the cost of monitoring would exceed the norm for similar sources and those costs would have a significant adverse effect on the profitability of the operations.

(Source: Added at 13 Ill. Reg. 2066, effective February 3, 1989)

Section 201.403. Exempt Sources

The following emission sources are exempt from the requirements of this Subpart:

a) Any source subject to monitoring requirements which are part of a new source performance standard adopted by USEPA pursuant to Section 111 of the Clean Air Act and made applicable in Illinois pursuant to Section 9.1 of the Act; or

b) Any source not subject to either the generally applicable emission limitation established pursuant to the Act or Board regulation or an alternative, adjusted or site specific standard approved by the Board.

(Source: Added at 13 Ill. Reg. 2066, effective February 3, 1989)

Section 201.404. Monitoring System Malfunction

The monitoring and recording requirements of this Subpart shall not be applicable during any period of a monitoring system or device malfunction if demonstrated by the owner or operator of the source that the malfunction was unavoidable and is being repaired as expeditiously as practicable. This demonstration may include, but is not limited to, evidence that the device has been properly calibrated and maintained, adequate spare parts are on hand, and trained technicians are available to make repairs.

(Source: Added at 13 Ill. Reg. 2066, effective February 3, 1989)

Section 201.405. Excess Emission Reporting

Owners and operators of sources subject to the continuous monitoring requirements of this Subpart shall report the following information:

a) For periods of emissions in excess of any emission limitation adopted by the Board:

1) The starting date and time of the excess emissions;