

PHONE/CONFERENCE CONVERSATIONS

DATE: 6/12/97 Thursday PHONE NO. 512 834 6600 EX 2779
 WHO: Debra MARLOW FAX 834-6644
 COMPANY: TDH
 SUBJECT: Demolition Notification

CONTENTS:

Question on gaskets

ANSWER: Can remain in place. However need to mark CAT. I not removed (non friable) need to fill out waste transporter #13 section.

Next day reply was removed if going to meet. Would not know how to handle

Question on phases

Demolition phases would be the same as asb. phases. Cannot cease project for 30 days without allowing out notification. Must give regional director copy of demolition schedule. If not working, need to notify local TDH.

Question on 4x8 panels need to be removed

ANSWER: Ifs Become RACH upon demolition.

Debra said I could send her a copy of the notice to see if filled out correctly. I sent 6/16

ACTION: Called L. Acuna Sun City. Discussed using us as the abatement contractor in case we do not receive a letter from Steel mill accepting gaskets in place.

DM

PHONE/CONFERENCE CONVERSATIONS

DATE: 6/5/97
WHO: Jim Duran PHONE NO. 774-6260
COMPANY: TEXAS Dept of Health
SUBJECT: Demolition

CONTENTS:

Questions asked How do we fill out Phased Project.
First phase will run from: About 6-7 mo.
Penalty involved w/ lrg scale project → did not ask question
→ Sending a copy of phased project policy
Question on Gaskets: → need Demolition schedule
Wall panels 4' x 8' x 3/4" 96 sq feet.
→ need to be indicated on survey
gaskets exist.
Less that 160/260 can go out
as Demolition Debris.
→ wall panels need to be removed
intact

ACTION: ☒ Notification form needs to be dated w/ 4/2 date
4/2/97 must mark Demolition / Phase project
Schedule of the phase project

f:\users\peggy\phone.wp1