

MILACRON

MILACRON

To B. Block
W. Eckerson
M. Fox
M. Paliobagis

From E. J. McClary
Location Environmental
Date July 30, 1980
Subject Asbestos Identification

SAMPLE #	DATE	LOCATION	RESULT
580	Jan. 80	Insulation around steam line 3-5608, Don Silver 03E	Chrysotile Asbestos Present
880	June 80	A.D. Lab Insulation on heating microscope	Chrysotile Asbestos Present
980	June 80	A.D. Lab on bench	Chrysotile Asbestos Present
1080	June 80	Grinding Wheels Plant Bay N-5 Steam Pipe #1	Chrysotile Asbestos Present
1180	June 80	Grinding Wheels Plant Bay N-6 Steam Pipe #2	Chrysotile and Amosite Asbestos Found

These samples of insulation were collected at the sites indicated above.
The samples were submitted to determine the presence of asbestos.

E. J. McClary
E. J. McClary
bab

PLAINTIFF'S EXHIBIT

CGI-12

MIL 000016