

DOW-727

R & D REPORT

DOW CHEMICAL U.S.A.

RESTRICTED: for use within The Dow Chemical Company only.

CRI NUMBER 73 3468

LABORATORY REPORT CODE

NCT-5517

DATE ISSUED

6-28-73

LAB. NO.

5 8 1

PROBLEM NO.

0 6 0 2 0 4 0

DEPARTMENT

COMPUTATION RESEARCH - THERMAL RESEARCH

TITLE

Specific Heat of Asbestos - 15% Latex Sheet

PAGES
IN FULL
REPORT

AUTHOR(S)

R. A. McDonald

AUTHOR(S) SIGNATURE(S)

REVIEWER'S SIGNATURE

This
report
is:☐ INTERIM☒ FINAL

and mainly:

☒ NEW☐ REVIEWDESCRIPTIVE SUMMARY
WITH CONCLUSIONS:

(Include in this space references to data books, and to earlier related reports, patents and publications.)

D. M. Blake, Designed Products TS&D, requested the specific heat measurement at 150 and 180°F on a sample of an asbestos-latex sheet material supplied by Nicolet Industries, Inc. The 15% latex content was said to be Dow SD655 latex or a blend of that and XD8131 latex.

The specific heat was determined by comparison with standard reference α -Al₂O₃ in a differential scanning calorimeter. The values at 150 and 180°F are read from a curve through the plot of the experimental points. See the attached Figure 1.

°F	BTU/(lb. °F)
150	.295
180	.304

A slight weight loss and a slight exothermal drift were noticed during the measurement.

JUN 29 1973

MIDLAND

DISTRIBUTION:

DEPARTMENT FILES
R & D ADMINISTRATION
CENTRAL REPORT INDEX - 5 COPIES
(566 Bldg. - Midland)

D. M. Blake
R. R. Klimpel
C. M. Bowman

(2)

Distribution list
is continued on
attached page.

73 3468

CRI NUMBER

ST0284315

FIGURE 1
SPECIFIC HEAT OF AN
ASBESTOS - 15% LATEX SHEET

BTU/(lb. °F)

130

140

150

160

°F

170

180

190

200

.28

.29

.30

.31

ST0284316

733104

16c. B-16,339
Title SIMULATED PLANT FIRE TESTING OF PIPE INSULATION SYSTEMS
Authors W.J. McMillan

16a. B-16,339
PG-1

RELEASE OF TECHNICAL INFORMATION
(Numbers 1 - 15, 22 - 24 for originators of request; 16 - 21 for reviewers)

1a. Title of Proposed Talk, Publication or Release SIMULATED PLANT FIRE TESTING OF PIPE INSULATION SYSTEMS

1b. Request for release of ☐ Title only ☐ Abstract only ☒ Full text

2. Author(s) WILLIAM J. McMILLAN

3. Return request to: Name W.J. McMillan Phone No. 6-3512
Address _____

4. Date submitted to sponsor MAY 23, 1973

5. Final release decision required no later than JUNE 1, 1973

6-13. See page 2.

14. Please classify as one of following: ☐ Agricultural and/or Biochemical, ☐ Analytical, ☐ Chemical Engineering and/or Industrial Chemistry, ☐ Instrument and/or Control, ☐ Medical and/or Pharmaceutical, ☐ Metallurgy and/or Mineralogy, ☐ Organic, ☐ Physical Chemistry, Inorganic, Physics, ☐ Physical Properties, ☐ Polymers, ☒ Other PRODUCT & MARKET DEVELOPMENT

15. I have reviewed and approved this paper and recommend its release as being in the interest of Dow. It is appropriate to the intended audience and reflects the professional standards desired by this organization and Dow.

Sponsor SSL Signature C. L. Grahm Date 6/4/73 Organization _____

16a. Received by D. L. Graham (Responsible line manager) on 6/3/73 Date for approval.

Indicate appropriate reviewers in (16b on page 2) and forward to Corporate R&D 2020 Bldg., Midland, Mich.

16c. Corporate R&D will assign B-number, and send to reviewers designated CENTRAL REPORT ROOM

17-18. See page 2.

19. Final review by D. L. Graham (responsible line manager).

☒ Approved for release, note comments if made
☐ Approved for limited release and/or only after revisions are made

describe _____
☐ Not approved for release _____
reasons _____

Signature D. L. Graham Date 6/3/73

20. Classification: ☐ A, primarily research; ☐ B, non-research; ☐ C, Associated research, Rocky Flats; ☐ D, Analytical; ☐ E, Sales; ☐ F, General, review; ☐ G, other _____

21. Return to name/address in (3). If not approved, send copy of page 1 to Corporate R&D.

22. Final approved draft. I have complied with the conditions stated above; the originally submitted manuscript has been changed to this final form and will be submitted, published and/or presented in this form.

Signature _____ Date _____

23. Three copies of completed cover sheet and final manuscript to CRI for distribution to CRI Midland, Texas and Western _____

24. Cover sheet copies: Responsible line manager (16a), Corporate R&D, Public Relations, College Relations.

ST0284317

SIMULATED PLANT FIRE TESTING

OF

PIPE INSULATION SYSTEMS

by

William J. McMillan

In industrial plants, particularly in the petrochemical industries, accidental plant fires involve burning liquid hydrocarbons, many of them lighter than water. Thus, the consideration of a large flame area with rapid temperature rise and flame impingement directly on pipes is of paramount importance in pipe insulation systems design.

Small scale comparison tests of insulation materials may provide a rating for combustibility or fire resistance, but they will not establish the performance of pipe insulation in a fire. Recognizing the inadequacy of point impingement flame tests and radiant heat exposure to forecast pipe insulation behavior; the Union Carbide Corporation in the early sixties initiated an outdoor fire resistance test to simulate plant fire conditions. This test exposed pipes and insulation systems to approximately thirty square feet of

ST0284318

flame area having temperatures tailored to the ASTM E-119 Standard Time-Temperature Curve. The results of these tests were reported⁽¹⁾ by Durbin H. Way and Carlos J. Hilado in 1968. During the past two years research at The Dow Chemical Company duplicated and modified the Union Carbide test procedure.

The fire resistance of pipe insulation systems is determined by suspending 20 feet of insulated 3" diameter steel pipe over a 4 x 12 foot steel fire pan containing water with burning gasoline on its surface. A schematic of the test apparatus is shown in Figure 1. Five insulated pipes may be tested simultaneously. The gasoline feed rate to the underwater sparger in the bottom of the fire pan is continuously monitored to produce a flame temperature rise which coincides with the ASTM E-119 Standard Fire Temperature Curve. After burning for one hour, the fire is allowed to burn out and the insulation inspected. The impact of water on the insulation is simulated by re-igniting the fire and after five minutes spraying the insulation with water from a fire hose until the fire is extinguished.

ST0284319

The pipe temperature rise is measured by a thermocouple in the pipe surface midway between the pipe ends.

Although these tests were conducted within a specially designed building, the flame temperature and profile were sensitive to weather conditions and required constant monitoring and control by adjustment of the fuel flow and draft profile. The variation in flame profile and intensity also made it necessary to measure the flame temperature immediately adjacent to each pipe. The flame temperature thermocouples are mounted within a 4" length of stainless steel pipe to modulate the thermocouple sensitivity.

Fire resistance is expressed as the time required for the insulated pipe to reach a forecast failure temperature or as the pipe temperature after a given fire exposure time. The desired minimum fire resistance for pipe insulation for the petro-chemical industry has been arbitrarily selected as one hour for the pipe temperature to reach 1000°F. However, a specific fire resistance should be selected for each installation.

ST0284320

The variation in flame temperature from the ASTM E-119 Standard Time-Temperature Curve, from pipe to pipe and test to test, is corrected by application of a deviation factor to the temperature and or time. The deviation factor is expressed as the ratio of the area under the flame temperature curve to the area under the ASTM E-119 Standard Time-Temperature Curve. When computing the deviation correction only that portion of the Time-Temperature Curve for the time period under consideration is used. The test is considered invalid if the flame temperature curve for the duration of the test deviates from the ASTM E-119 curve by more than ten percent.

When five pipes were insulated with one inch of a calcium silicate insulation and a ten mil stainless steel jacket; the insulation system was found to provide essentially one hour of fire resistance. Figure 2 shows the test in progress and the fire resistance curve is shown in Figure 3. The average variation in flame temperature was 360°F. The pipe temperatures varied by 92°F.

ST0284321

Because "white goods" normally shrink when exposed to high temperatures a double layer pipe insulation system is usually specified to provide satisfactory fire protection against direct flame impingement or direct radiation from the jacket. However, since ceramic and glass foam insulations expand rather than shrink when heated; a single layer of these materials will provide the required protection provided they are secured on the pipe with steel jacketing or bands.

With an external temperature rise of 2000°F and a pipe temperature rise from ambient to 1000°F; calculations show that the expansion of the glass foam insulation exceeds that of the pipe and cracks for direct flame impingement are not formed. Also, in a three foot length of pipe the expansion of the pipe will not exceed that of ceramic foam insulation by more than 0.1". Past experience has shown the ceramic foam to fracture an average of each 6" under rapid external temperature rise; thus the potential crack due to a fire would be distributed over five fractures and would be approximately 0.02" which is insignificant for direct flame impingement consideration.

ST0284322

The difference in fire resistance between glass foam and ceramic foam becomes more obvious with increased flame exposure time. The glass foam, because of its lower softening temperature tends to sinter and shrink at temperatures where the ceramic foam remains essentially unchanged. The fire resistance of ceramic foam pipe insulation is shown in Figure 4. Ceramic foam pipe insulation 2" thick with proper covering will provide the desired one hour of fire resistance.

From the tabulated fire resistance shown in Table I of various high and low temperature jacketing systems for two inches of ceramic foam, the fire resistance is not very sensitive to the jacketing material. The ceramic foam pipe insulation without a jacket spalled due to the rapid temperature rise and flame impingement during the first 14 minutes of the test. The loss of material reduced the fire resistance. The vinyl acrylic mastic did not readily burn and left a cement-asbestos like residue which protected the ceramic foam from spalling and left it intact under the jacket residue. The asphaltic mastic burned and dripped

ST0284323

from the pipe but left a light-weight expanded residue. Some spalling occurred. The aluminum jacket had melted from the insulation within 12 minutes into the test. Banding with steel bands 12" on center instead of 6" on center allowed fragments of the foam to become dislodged from the pipe. The foam under the steel and asbestos felt jackets, although fractured, was intact after the test.

The "after fire" integrity and functionality of an insulation system is very significant when selecting an insulation system to minimize processing or production "down time" after a fire. Three inches of ceramic foam pipe insulation with an asphalt impregnated asbestos felt jacket banded with steel bands 6 inches on center did not change its fire resistance when exposed to three consecutive fire tests. The insulation was rejacketed between tests.

In a single test, a 6" diameter pipe insulation system composed of 24 ceramic foam segments approximately 1.7" wide bonded to an asbestos felt jacket, when banded 6"

ST0284324

on center; was found to remain functional after the fire resistance test in that despite the small size of the segments, they remained firmly secured on the pipe even when the jacket^{res. linc} was scraped off.

Plastic foam insulation is not usually considered as providing fire protection. However, some fire retardant rigid polyurethane foams by virtue of their char forming characteristics, do provide fire resistance, especially when installed with steel jacketing. Most of these rigid foams, once converted to carbon char by a high temperature, contract and rupture leaving a part of the pipe exposed to direct heat radiation or flame impingement.

One rigid polyurethane foam is unique in that when exposed to high temperature it concurrently melts, carbonizes, and intumesces thereby providing an essentially continuous carbon char insulation. Variance in the fire resistance of four commercial rigid polyurethane foam pipe insulations is shown in Figure No. 5. Each foam was 3" thick and was jacketed

ST0284325

with 10 mils of vinyl coated steel. The better resistance is provided by the non shrinking type foam previously described.

The characteristic to melt, carbonize, and intumesce applies to vertical as well as horizontal surfaces. A vertical pipe insulated with 3" of rigid polyurethane foam and a steel jacket was included in one of the fire resistance tests and is shown during the test in Figure 6. The char formation did not melt and run out and provided fire resistance for longer than one hour.

Some rigid polyurethane foams continued to "punk" 20 minutes after the fire was extinguished, even when the fire was extinguished with water. The punking was usually adjacent to the pipe where a high temperature could be maintained. A punking characteristic is undesirable where there is a potential for fire re-ignition.

Five jacket materials for three inches of fire retardant rigid polyurethane foam pipe insulation

ST0284326

were tested simultaneously. The results shown in Table 2 indicate that the fire resistance of a rigid polyurethane foam pipe insulation system correlates directly with the fire resistance of the jacketing. The fire resistance as a function of the foam thickness for a steel jacket system is shown in Figure 7.

Since these fire resistance tests were run with empty pipes the fire resistance will be increased when the pipes are filled and should be extended considerably ^{THIS TEST} when the pipe contents are flowing. They should not be confused with established ASTM test procedures such as ASTM E-119 and ASTM E-84, nor should these test results be considered as guaranteeing pipe insulation performance in a fire. However, these test results can provide the basis for the selection of insulation materials and systems.

In summary, simulated plant fire testing of pipe insulation systems has shown that: (1) Rigid polyurethane foam insulation can provide fire resistance. (2) The fire resistance of polyurethane foam

ST0284327


pipe insulation is a function of the jacketing material. (3) Single layer ceramic foam pipe insulation can provide fire resistance without flame impingement. (4) Ceramic foam pipe insulation can remain functional after a fire. The ability to forecast the insulation thickness required for fire protection becomes significant when the potential fire severity and heat insulation requirements are combined to determine the most economical thickness of insulation.

BIBLIOGRAPHY

- ¹ - Durbin H. Way, and Carlos J. Hilado, Fire Technology 4:271-283 November 1968 and Journal of Cellular Plastics, 221-228 June 1968.

ST0284328

Figure 1



Equipment for Measuring Pipe Covering
Fire Resistance
(Not to Scale)

ST0284329

ST0284330





Figure 4
Fire Resistance of Ceramic Foam Pipe Pipe Insulation



ST0284331

Table 1


FIRE RESISTANCE

TWO INCHES OF CERAMIC FOAM

<u>System</u>	<u>Minutes To 1000°F Pipe Temperature</u>
No Jacket	54
Vinyl-Acrylic-Mastic	65
Asphaltic Mastic	67
10 Mils Corrugated Aluminum	63
10 Mils Stainless Steel	66
Asbestos Felt	59

ST0284332

Figure 5
Fire Resistance of Three Inch Thick Rigid
Polyurethane Foam Pipe Insulation




ST0284333

Table 2

<u>Jacket</u>	<u>Minutes To 1000°F Pipe Temperature</u>
10 Mil Polyvinyl Chloride	18
Paper/Aluminum Foil/ Skrim Laminare	22
26 Gage Aluminum	28
1/8" Reinforced Asphaltic Mastic	40
10 Mil Vinyl Coated Steel	58

48848201S

Figure 7
Fire Resistance as a Function of
Polyurethane Foam Thickness



ST0284335

BACKGROUND FOR REVIEWERS

Please supply following information. Reviewers may return form for data if it is not supplied, causing unnecessary delay.

1-5. See page 1.

6. Check one: ☒ Dow work covered by internal reports, nos. FP-435 4340504-2, 3, 4, 5, 6, 7, 8, 9, 11 & 13
☐ Dow work not covered by internal reports; ☐ Review, including only previously published work (no new theories or insights presented).

7. Check one or more: ☐ Subject of patent disclosures, nos. _____; ☐ Covered by issued patents, nos. _____; ☐ Subject of license and/or agreement (identify) _____; ☒ Not patentable or licensable; ☐ Publication is a part of business planning.

8. Check one or more: Subject matter related to (identify)
☐ Dow process or system _____; ☐ Dow service _____; ☒ Dow product _____; ☒ Dow technology _____; ☐ Other _____; ☐ No present Dow interests.

9. Material ☐ related to: ☐ revision of previously released paper(s) no(s). _____; Date(s) _____; ☐ Abstract or Title No. _____; previously released; ☐ Not applicable.

10. If released, material will be
☐ Published by Dow for distribution to _____;
☐ Orally presented at 1973 AICHE LOSS PREVENTION SYMPOSIUM 11/1-15 (conference, meeting, etc.); ☐ Submitted to TECHNICAL LOSS PREVENTION IN (journal) for publication. CHEMICAL PROCESS INDUSTRY VOL #8 AND CONSIDERATION FOR CHEMICAL ENG. PROGRESS.

11. Copyright and/or publishing contract/agreements with non-Dow agencies ☐ have, ☐ have not been made by authors or others. AUTOMATIC PUBLISHING RIGHTS TO AICHE

12. Trademarks of Dow or any other company ☐ are, ☒ are not used anywhere in paper (title, text, tables, figures, references, footnotes, etc.)

13. Liability clause ☐ is, ☐ is not required and ☐ is, ☐ is not included.

14-16a. See page 1.

16b. To be reviewed by 17. Reviewed by

(Reviewers to be designated at Step 16a)	Name	Recommendation			Signature	Date
		Yes	Provisional*	No*		
☐ a. Prod. Dept.	<u>RB Ingraham</u>	☐	☐	☐	<u>[Signature]</u>	<u>5 May 73</u>
☒ b. Patent Dept.	<u>Wenderson</u>	☒	☐	☐	<u>[Signature]</u>	<u>5/8/73</u>
☐ c. Trademark	<u>J.S. LAINE</u>	☐	☐	☐	<u>[Signature]</u>	<u>5/8/73</u>
☐ d. Tech. Center		☐	☐	☐		
☐ e.		☐	☐	☐		
☐ f.		☐	☐	☐		
☐ g.		☐	☐	☐		
☐ h.		☐	☐	☐		

*Comments or limitations with modification of p5 discussed with WJM 5 May 73
RAJ

18. Reviewers in (17) return to: (_____) 20 Bldg., Midland, Michigan.

19-24. See page 1.

CENTRAL RESEARCH DEPT
 20 BLDG. MIDLAND

ST0284336

ST0284337

16c.
B- 16,339
pg.

BACKGROUND FOR REVIEWERS

Please supply following information. Reviewers may return form for data if it is not supplied, causing unnecessary delay.

1-5. See page 1.

6. Check one: ☒ Dow work covered by internal reports, nos. FP-435 439 0504-2, 3, 4, 5, 6, 7, 8, 9, 11, 13
☐ Dow work not covered by internal reports; ☐ Review, including only previously published work (no new theories or insights presented).

7. Check one or more: ☐ Subject of patent disclosures, nos. _____; ☐ Covered by issued patents, nos. _____; ☐ Subject of license and/or agreement (identify) _____; ☒ Not patentable or licensable; ☐ Publication is a part of business planning.

8. Check one or more: Subject matter related to (identify)
☐ Dow process or system _____; ☐ Dow service _____; ☒ Dow product _____; ☐ Other _____; ☒ Dow technology _____; ☐ No present Dow interests.

9. Material ☐ related to: ☐ revision of previously released paper(s) no(s). _____; Date(s) _____; ☐ Abstract or Title No. _____; previously released: ☐ Not applicable.

10. If released, material will be
☐ Published by Dow for distribution to _____;
☐ Orally presented at 1973 AICHE LOSS PREVENTION SYMPOSIUM 11/11-15 (conference, meeting, etc.); ☐ Submitted to TECHNICAL - LOSS PREVENTION IN (journal) for publication. CHEMICAL PROCESS INDUSTRY VOL #8 AND CONSIDERATION FOR CHEMICAL ENG. PROGRESS

11. Copyright and/or publishing contract/agreements with non-Dow agencies ☐ have, ☐ have not been made by authors or others. AUTOMATIC PUBLISHING RIGHTS TO AICHE

12. Trademarks of Dow or any other company ☐ are, ☒ are not used anywhere in paper (title, text, tables, figures, references, footnotes, etc.)

13. Liability clause ☐ is, ☐ is not required and ☐ is, ☐ is not included.

14-16a. See page 1.

16b. To be reviewed by 17. Reviewed by

(Reviewers to be designated at Step 16a)	Name	Recommendation			Signature	Date
		Yes	Provisional*	No*		
☐ a. Prod. Dept.	<u>Waterman</u>	☐	☐	☐		
☐ b. Patent Dept.		☐	☐	☐		
☐ c. Trademark		☐	☐	☐		
☐ d. Tech. Center		☐	☐	☐		
☐ e. _____	<u>J.S. LAING</u>	☒	☐	☐	<u>John Laing</u>	<u>5/25</u>
☐ f. _____		☐	☐	☐		
☐ g. _____		☐	☐	☐		
☐ h. _____		☐	☐	☐		

*Comments or limitations _____

18. Reviewers in (17) return to: CORPORATE HEADQUARTERS, 200 Bldg., Midland, Michigan.

19-24. See page 1.

CENTRAL REPORT DOW
BLDG. 200 MIDLAND