FILE NAME: Superior Combustion Industries (SCI)

DATE: 1971 Mar 16

DOC#: SCI009

DOCUMENT DESCRIPTION: Field Activity Report

File

Region II - W.R.
Prod. Mfg. or Service boilers
Date of Activity 3/16/71

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF HEALTH
OCCUPATIONAL HEALTH

FIELD ACTIVITY REPORT

Plant	SUPERIOR COMBUSTION INDUSTRIES		
Address	201 Broad St., Emmaus	Zip 18049	Phone (215) 965-9051
Person Interviewed	Maurice Ott	Title	Industrial Engineer
Employees Male / Female / Total 107		Ind. Code 34	County 39

Purpose: Invest.; Survey; Inspect.; Prelim.; F.U.; Conf.; visit;

Reason: Self-Init.; O.D. Rep.; Compl.; Request; Source

Specific Hazard or Condition	Workers Exposed	Recommendations R — Written - Verbal	Accomplished Yes	No	In Prog.
OV	4	1.	X		
		2.	X		
		3.	X		
		(see below)			

Samples Collected — Total
No. & Kind
Determ. Made — Total
(No. & Kind)
Medical - O.D. Reported, No. & Kind

PUNCH CARD Yes [X] No [ ] MSH - no FOLDER Yes [X] No [ ]

REMARKS:

1. Continue with your plans to install an exhaust ventilated booth at the airless spray painting operation. Accomplished

2. Continue to provide spray painters with respirators approved by the USBM for protection against OV and dispersoids. Accomplished

3. Establish a respirator maintenance program in accordance with Section 4C, Article 432. Accomplished.

Paper Section of the Original Records
Preservation Branch
PA STATE ARCHIVES

REMARKS:

Followed up above recommendations made as a result of an investigation. Concerning No. 1, a DeVilbiss plenum and fan have been installed. Plenum measures 8' x 12' and is designed to hold filters which are in place. Company has installed one of these on own boiler stacks to a height above the edge of the roof. It appears to work quite well.

Concerning No. 2, Pulmosan respirators approved by the USBM for organic vapors and dispersoids are being provided.

(OVER)

BY K. Knauss RIH
WINS 4.5