

HEATING VENTILATING AIR CONDITIONING GUIDE 1939

TABLE 2. DESIRABLE INSIDE CONDITIONS IN SUMMER CORRESPONDING TO OUTSIDE TEMPERATURES^a
Occupancy Over 40 Min

OUTSIDE DRY-BULB DEG F	INSIDE AIR CONDITIONS				
	Effective Temperature	Dry-Bulb DEG F	Wet-Bulb DEG F	Dew-Point DEG F	Relative Humid- ity Per Cent
100	75	83	66	56	40
	75	82	67	59	45
	75	81	68	61	51
	75	80	70	65	60
95	74	82	64	53	36
	74	81	66	57	44
	74	80	67	60	51
	74	79	68	62	57
90	74	78	70	66	68
	73	81	63	52	36
	73	80	64	54	41
	73	79	66	59	50
85	73	78	67	61	56
	72	80	61	48	32
	72	79	63	53	41
	72	78	64	56	46
80	72	77	66	60	56
	71	78	61	49	36
	71	77	63	54	45
	71	76	64	57	52
	71	75	66	61	61

^aApplicable to individuals engaged in sedentary or light muscular activity.

but a few minutes in the cooled space, observations³⁶ indicate a schedule about 1 deg dry-bulb or effective temperature higher than that shown in Table 2. Laboratory experiments with exposures of 2 to 10 min indicate temperatures 2 to 10 F higher than those in Table 2 but with much lower relative humidities.

It should be kept in mind that southern people, with their more sluggish heat production and lack of adaptability, will demand a comfort zone several degrees higher than that for the more active people of northern climates. Instead of the summer comfort line standing at 71 deg as here given, it was found to be much higher for foreigners in Shanghai where climatic conditions are similar to those of our gulf states. This difference in adaptability of people forms a very real problem for air conditioning engineers. Cooling of theaters, restaurants, and other public buildings in southern climates cannot be based on northern standards without considerable modification.

Optimum Humidity

Just what the optimum range of humidity is, is a matter of conjecture. There seems to exist a general opinion, supported by some experimental and statistical data, that warm, dry air is less pleasant than air of a

³⁶How Cool? Inside Temperature Should Depend Upon Type of Occupancy, by J. H. Walker (*Heating and Ventilating*, October, 1932).

CHAPTER 3. PHYSICAL & PHYSIOLOGICAL PRINCIPLES OF AIR CONDITIONING

moderate humidity, and that it dries up the mucous membranes in such a way as to increase susceptibility to colds and other respiratory disorders^{37, 38, 39}. Owing to the cooling effect of evaporation, higher temperatures are necessary, and this condition may lead to discomfort and lassitude. Moist air, on the other hand, interferes with the normal evaporation of moisture from the skin, and again may cause a feeling of oppression and lassitude, especially when the temperature is also high. For the premature infant, a high relative humidity of about 65 per cent is demonstrably beneficial to health and growth⁴⁰ until the infants reach a weight of about 5 lb. No such clear-cut evidence exists in the case of adult persons. In the comfort zone experiments of the A.S.H.V.E. Research Laboratory, the relative humidity was varied between the limits of 30 and 70 per cent approximately, but the most comfortable range has not been determined. In similar experiments at the Harvard School of Public Health, the majority of the subjects were unable to detect sensations of humidity (*i.e.*, too high, too low, or medium) when the relative humidity was between 30 per cent and 60 per cent with ordinary room temperatures. This is in accord with studies by Howell⁴¹, Miura⁴² and others.

The limitation of the comfort zones in Fig. 6 with respect to humidity must not be taken too seriously. Relative humidities below 30 per cent may prove satisfactory from the standpoint of comfort, so long as extremely low humidities are avoided. In mild weather comparatively high relative humidities are entirely feasible, but in cold or sub-freezing weather they are objectionable on account of condensation and frosting on the windows. They may even cause serious damage to certain building materials of the exposed walls by condensation and freezing of the moisture accumulating inside these materials. Unless special precautions are taken to properly insulate the affected surfaces, it will be necessary to reduce the degree of artificial humidification in sub-freezing weather to less than 40 per cent, according to the outdoor temperature. Information on the prevention of condensation on building surfaces is given in Chapter 7. The principles underlying humidity requirements and limitations are discussed more fully elsewhere⁴³.

The purpose of artificial humidification may be easily defeated by failure to change the spray water of the humidifier at least daily. Where this condition occurs, the air is characterized by a *lack of freshness*, and under extreme conditions by a musty, sour odor in the conditioned space.

³⁷Reactions of the Nasal Cavity and Post-Nasal Space to Chilling of the Body Surface, by Mudd, Stuart, et al (*Journal Experimental Medicine*, 1921, Vol. 34, p. 11).

³⁸Reactions of the Nasal Cavity and Post-Nasal Space to Chilling of the Body Surfaces, by A. Goldman, et al, and Concurrent Study of Bacteriology of Nose and Throat (*Journal Infectious Diseases*, 1921, Vol. 29, p. 151).

³⁹The Etiology of Acute Inflammations of the Nose, Pharynx and Tonsils, by Mudd, Stuart, et al (*Am. Otol., Rhinol., and Laryngol.*, 1921).

⁴⁰Loc. Cit. Note 24.

⁴¹Humidity and Comfort, by W. H. Howell (*The Science Press*, April, 1931).

⁴²Effect of Variation in Relative Humidity upon Skin Temperature and Sense of Comfort, by U. Miura (*American Journal of Hygiene*, Vol. 13, 1931, p. 432).

⁴³Humidification for Residences, by A. P. Kratz, University of Illinois (*Engineering Experiment Station Bulletin No. 230*, July 28, 1931).