

based on the change in volume from 0 F to 91 F. From Table 7, determine $w = 62.5$ lb per cu ft at 0 F, and $w = 60.5$ lb per cu ft at 91 F. From Table 1, Chapter 26, 10,000 ft of 1-in. IPS contains 44.9 gal. Allowing another 15 gal for heat exchanger, headers, etc., assume the system contains 60 gal. Then the expansion would be $60(62.5 - 60.5) = 2.48$ gal.

60.5

A quick approximation of required head can be obtained from Fig. 20. At 91 F, the oil has a viscosity of 4.92×10^{-6} ft sq per sec or 35 SSU. Enter Fig. 20 at 35 SSU and rise to the 12 gpm curve, read $h = 12.5$ ft per 100 ft, then $h_t = 12.5 \times \frac{300}{100} = 37.5$ ft, which agrees fairly well with the 37.9 ft obtained by the Equation 23.

REFERENCES

- ¹ Standard Specifications for Gypsum Plastering, including Requirements for Lathing and Plastering (*American Standards Association*, A 42.1, 1946).
- ² Code and Manual for the Design and Installation of Warm Air Ceiling Panel Systems (Manual 7-A of the *National Warm Air Heating and Air Conditioning Association*).
- ³ Chapters 4 & 7 (pages 68, 69, 72-76, 180) of Heat Transmission by W. H. McAdams (McGraw-Hill Book Company, Inc., New York, Third Edition, 1954).
- ⁴ Natural Convection and Radiation in a Panel Heated Room, by T. C. Min, L. F. Schutrum, G. V. Parmelee, and J. D. Vouris (ASHAE JOURNAL SECTION, *Heating, Piping & Air Conditioning*, May 1956, p. 153).
- ⁵ ASHVE RESEARCH REPORT No. 1444—The ASHVE Environment Laboratory, by Cyril Tasker, C. M. Humphreys, G. V. Parmelee, and L. F. Schutrum (ASHVE TRANSACTIONS, Vol. 58, 1952, p. 139).
- ⁶ ASHVE RESEARCH REPORT No. 1473—Heat Exchanges in a Ceiling Panel Heated Room, by L. F. Schutrum, G. V. Parmelee and C. M. Humphreys (ASHVE TRANSACTIONS, Vol. 59, 1953, p. 197).
- ⁷ ASHVE RESEARCH REPORT No. 1490—Heat Exchanges in a Floor Panel Heated Room, by L. F. Schutrum, G. V. Parmelee, and C. M. Humphreys (ASHVE TRANSACTIONS, Vol. 59, 1953, p. 495).
- ⁸ ASHVE RESEARCH REPORT No. 1499—Effects of Non-Uniformity and Furnishings on Panel Heating Performance, by L. F. Schutrum and C. M. Humphreys (ASHVE TRANSACTIONS, Vol. 60, 1954, p. 121).
- ⁹ ASHVE RESEARCH REPORT No. 1516—Effects of Room Size and Non-Uniformity of Panel Temperature on Panel Performance, by L. F. Schutrum and J. D. Vouris (ASHVE TRANSACTIONS, Vol. 60, 1954, p. 455).
- ¹⁰ Heat Loss Through a Solid Floor, by H. H. Macey (*Journal Institute of Fuel*, 1949, 22-128, p. 369).
- ¹¹ Performance of Covered Hot Water Floor Panels, Part I—Thermal Characteristics, by E. L. Sartain and W. S. Harris (ASHAE JOURNAL SECTION, *Heating, Piping and Air Conditioning*, October, 1955, p. 117).
- ¹² Thermal Design of Warm Water Concrete Floor Panels, by a Subcommittee of the TAC on Panel Heating and Cooling, R. L. Maher, Chairman; W. P. Chapman; H. T. Gilkey; P. B. Gordon; E. F. Snyder; and J. M. Van Nieuwerkerken; and by ASHAE Laboratory Staff Members, L. F. Schutrum, and C. M. Humphreys (ASHAE JOURNAL SECTION, *Heating, Piping and Air Conditioning*, October 1956, p. 125).
- ¹³ Thermal Design of Warm Water Ceiling Panels, by a Subcommittee of the TAC on Panel Heating and Cooling, R. L. Maher, Chairman; W. P. Chapman; H. T. Gilkey; P. B. Gordon; E. F. Snyder; and J. M. Van Nieuwerkerken; and by ASHAE Laboratory Staff Members; L. F. Schutrum, G. V. Parmelee, and C. M. Humphreys (ASHAE JOURNAL SECTION, *Heating, Piping and Air Conditioning*, December 1955, p. 123).
- ¹⁴ Design Conditions for Snow Melting, by W. P. Chapman (*Heating and Ventilating*, November, 1952, p. 88).
- ¹⁵ Design of Snow Melting Systems, by W. P. Chapman (*Heating and Ventilating*, April, 1952, p. 95).
- ¹⁶ Snow Melting System Hydraulics, by W. P. Chapman (*Air Conditioning, Heating and Ventilating*, November, 1955).
- ¹⁷ Anti-Freeze Protection for Snow Melting Systems, by P. B. Gordon (*Official*

Bulletin, Heating, Piping and Air Conditioning Contractors National Association, February, 1950, p. 21).

¹⁸ Properties of Ethylene Glycol and Its Aqueous Solution, by C. S. Cragoe (*National Bureau of Standards CRC Report No. 9, Society of Automotive Engineers*).

¹⁹ Are Thermal Stresses a Problem in Snow Melting Systems? by W. P. Chapman (*Heating, Piping and Air Conditioning*, June and August, 1955).

BIBLIOGRAPHY

- Trend Curves for Estimating Performance of Panel Heating Systems, by B. F. Raber and F. W. Hutchinson (ASHVE TRANSACTIONS, Vol. 48, 1942, p. 425).
- ASHVE RESEARCH REPORT No. 1192—Panel Heating and Cooling Performance Studies, by B. F. Raber and F. W. Hutchinson (ASHVE TRANSACTIONS, Vol. 48, 1942, p. 35).
- ASHVE RESEARCH REPORT No. 1193—Radiation as a Factor in the Feeling of Warmth in Convection Radiator and Panel Heated Rooms, by F. C. Houghten, Carl Gutberlet and E. C. Hach (ASHVE TRANSACTIONS, Vol. 48, 1942, p. 55).
- Panel Heating and Cooling, Analysis, by B. F. Raber and F. W. Hutchinson (ASHVE TRANSACTIONS, Vol. 47, 1941, p. 285).
- Operating Results of a Residence Radiant Wall Heating System, by E. J. Rodee (ASHVE TRANSACTIONS, Vol. 47, 1941, p. 123).
- Performance of a Residential Panel Heating System, by H. F. Randolph and J. B. Wallace (ASHVE TRANSACTIONS, Vol. 49, 1943, p. 235).
- Radiant Heating (*Heating and Ventilating*, March, 1941, p. 35).
- Radiant Heating and Cooling, by F. E. Giesecke (*Heating, Piping and Air Conditioning*, June, July, August, September and October, 1940).
- Calculations for Radiant Heating, by T. Napier Adlam (*Heating and Ventilating*, October, 1931).
- Radiant Heating and Cooling, Part I, by C. O. Mackay, L. T. Wright, Jr., R. E. Clark, and N. R. Gay (*Cornell University Engineering Experiment Station*, Bulletin No. 32, 1943).
- Design Method for Panel Heating Systems Using Copper Tubing, by R. G. Vanderweil (ASHVE JOURNAL SECTION, *Heating, Piping and Air Conditioning*, Nov. 1947, p. 123).
- Air Temperature Gradients in a Panel Heated Room, by J. M. Ayres and B. W. Levy (ASHVE TRANSACTIONS, Vol. 54, 1948, p. 131).
- Graphical Solution of Radiant Panel Areas, by W. P. Chapman and R. E. Fischer (*Heating and Ventilating*, Jan. 1948, p. 88).
- Embedding Coils in Radiant Heating Panels, by D. L. Mills and L. J. LaTart (*Heating and Ventilating*, Dec. 1947, p. 75).
- Radiant Heat with Copper Tubing, by D. L. Mills and L. J. LaTart (*Heating and Ventilating*, Nov. 1947, p. 95).
- Panel Heat with Copper Tubing—Experiment in Practice, by D. L. Mills and L. J. LaTart (*Heating and Ventilating*, Oct. 1947, p. 65).
- Experimental Studies on Panel Heating Tube Spacing, by B. F. Raber and F. W. Hutchinson (ASHVE TRANSACTIONS, Vol. 53, 1947, p. 369).
- Panel Heating—A Basic Discussion, by S. Konzo (*American Artisan*, Oct. 1946, p. 68).
- Solar House Heated by a Warm Air Floor Panel, by John E. Peterson (*American Artisan*, Dec. 1946, p. 83).
- Design Data for a Warm Air Floor Panel, by Axel B. Algren (*American Artisan*, Jan. 1947, p. 141).
- The Mechanism of Heat Transfer, Panel Cooling, Heat Storage, by Charles S. Leopold (*Refrigerating Engineering*, July 1947, p. 33).
- Radiant Heating—Simplified Design and Installation (*Copper and Brass Research Association*, 1949).
- RESEARCH REPORT No. 1387—Laboratory Studies on Heat Flow Within a Concrete Panel, by C. M. Humphreys, H. B. Nottage, C. V. Franks, R. G. Huebscher, L. F. Schutrum and D. W. Locklin (ASHVE TRANSACTIONS, Vol. 56, p. 175).
- RESEARCH REPORT No. 1388—Heat Flow Analysis in Panel Heating or Cooling Sections, by L. E. Hulbert, H. B. Nottage and C. V. Franks (ASHVE TRANSACTIONS, Vol. 56, 1950, p. 189).