CLASSIFIED DOCUMENT

001413 007.

K. Schneider

F. K. Stumpf

December 27, 1965

Maryland Cup Job - Your memo of 12/21/65.

The material you sent back which is claimed to be dusty appears to be satisfactory in all respects. Once in a while some dirt gets in the dedusting equipment and the product may not be completely dedusted. However, this would have no deleterious effect on Type B as a fireproofing material. Its only disadvantage is that it is dusty during application.

Steps have been taken from time to time to correct this problem.

FKS/ce

cc:
J. F. O'Rourke
K. S. Cowpp

File

FKS