

Mon-1350

Monsanto

FROM (NAME & LOCATION)

G. C. Chesnut - Texas City


DATE June 9, 1983

cc. A. H. Conrad
M. J. Leidy
R. T. Hammann

SUBJECT MAY SAFETY MEETING
Dept. 33

REFERENCE

TO : K. E. Bretz



The subject of the May safety meeting was "Unsafe Acts". Slides of unsafe acts were shown and discussed.

Procedure bulletin No. P-0115 was also reviewed at this time.

George Chesnut /jp
George Chesnut

/jp

ATTENDED:

Scott
Boggess
White
Tovrea
Prendergass
Lemons
Rains
Lessa
Lingenfelter
Holcomb
Heer
Nelson
Thomas

LAM001235

SC

000038

PROCEDURE BULLETIN—TEXAS CITY PLANT P-0115

FLAMMABLE AND COMBUSTIBLE LIQUIDS STORAGE AND DISPENSING AREAS

I. PURPOSE

The purpose of this bulletin is to establish a procedure for dispensing and storage of flammable and combustible liquids.

II. SCOPE

This bulletin covers the responsibility and an acceptable method for storage and dispensing of flammable and combustible liquids. Flammable liquids have flash points below 100°F, combustible liquids have flash points above 100°F. See paragraph IV, B. for details.

III. POLICY AND RESPONSIBILITY

All Manufacturing units, Stores Department, Process Technology Department and any other department storing and dispensing flammable and combustible liquids have the individual responsibility to see that these liquids are stored and dispensed in a safe and proper manner.

IV. PROCEDURE

A. Drum Storage

1. Drums used for dispensing flammable or combustible liquids which are mounted in a horizontal position must be equipped with self-closing valves, relief vent devices, ground connections and individual drip pans equipped with safety screens or filled with absorbent material. Some means of protecting drip pans from overflowing because of rain must be provided. Drip pans should be emptied on a routine basis.
2. Drums mounted vertically and equipped with hand operated pumps do not require a drip pan, but must have relief vent devices, grounds and tops should be protected from weather.
3. All drums used for dispensing flammable liquid must be located away from operating equipment by a minimum distance of 20 feet. They must be located on a non-absorbent floor.
4. Flammable liquids in excess of one quart dispensed from drums should be carried in safety cans equipped with suitable screens. The can being filled should be bonded to the grounded drum while filling.

SC

000039

ORIGINAL ISSUE: 10/1/76

REVISED:

PAGE 1 OF 3

LAM001236

PROCEDURE BULLETIN — TEXAS CITY PLANT P-0115

FLAMMABLE AND COMBUSTIBLE LIQUIDS STORAGE AND DISPENSING AREAS

5. Locations for storage and dispensing of flammable liquid should be situated to provide adequate natural ventilation. If this is not possible, mechanical ventilation should be provided.
6. Suitable fire control devices must be available where flammable liquids are dispensed.
7. All drums must be labeled as to chemical content.

B. Storage Other Than Drums

Laboratories at this location may store up to 2 gal/100 ft.² of floor space of Class I flammable liquids. An additional 2 gal/100 ft.² may be stored in safety cans or approved storage cabinets. Quantities of Class II and III combustible liquids may also be stored such that the total for Classes I, II and III does not exceed 4 gal/100 ft.² in bottles or 8 gal/100 ft.² if half of it is in approved safety cans or cabinets. In addition, 1 gallon of acetone in an approved plastic bottle is permitted and is excluded from the above totals. Any deviation from this provision will require written authorization from the Department Head or Manufacturing Superintendent and the Loss Prevention & Safety Department.

The most flammable liquids, Class IA, should be limited to no larger than 1 pint in glass or approved plastic bottles. Class IB is limited to a maximum of 1 quart.

EXAMPLES

Class IA, Flash point <73°F, Boiling point <100°F

Ethyl ether
Pentane

Class IB, Flash point <73°F, Boiling point >100°F

Acetone
Benzene
Carbon disulfide
Hexane
Ethyl Alcohol

Class IC, Flash point 73°F-100°F

Turpentine
Xylene

SC

000040

ORIGINAL ISSUE: 10/1/76

REVISED:

PAGE 2 OF 3

LAM001237

PROCEDURE BULLETIN—TEXAS CITY PLANT P-0115

FLAMMABLE AND COMBUSTIBLE LIQUIDS STORAGE AND DISPENSING AREAS

Class II, Flash point 100°-140°F

Cellosolve
Mineral spirits

Class IIIA, Flash point 140°-200°F

Class IIIB, Flash point >200°F

V. INSPECTION & CONTROL


It is recommended that each individual department set aside designated areas for the storage of both drum and less than drum quantities of flammable liquids. Periodic inspections of these areas should be scheduled to insure that they are being properly used and that quantities stored in labs and buildings are limited as specified above. In addition, the inspection should verify that all containers are properly labeled as to content and that only authorized materials are stored. The inspections should be made at least every six months.

Reviewed by:

Plant Managers Safety Board

Prepared by:


R. D. Querry


J. V. Cavender

Approved by:


P. E. Brubaker

SC

000041

LAM001238