

APR 28 1983

CAMBRIDGE

TO: ~~H. A. Eschenbach~~

DATE: 27 April 1983

FROM: P. M. Connor

PLAINTIFF'S
EXHIBIT
WRG-760a

SUBJECT: Travelers Rest Machine Shop -- Asbestos Air Sampling

There were "no visible fibers" detected in any of the three air samples taken in the machine shop at Travelers Rest.

The bulk sample analysis revealed chrysotile asbestos fibers to be well distributed throughout the spray-coated wall materials.

Since the wall coating material is flaking in most locations, I still believe there should be cause for concern.

Paul M. Connor
Paul M. Connor

PMC/cs

attachment

R0011299

PLAINTIFF'S
EXHIBIT

Eschenbach 77
6a 8-7-82

PLAINTIFF'S
EXHIBIT
-127

15159960