

cc: Dr. R. A. Kehoe

SAFETY DEPARTMENT

May 21, 1946

Mr. T. R. A. Bevan
Associated Ethyl Ltd.
Artillery House, Artillery Row
London SW 1, England

Dear Ray:

I have a copy of your letter of May 13, together with a copy of your "Regulations Governing the Cleaning, Scaling and Repairing of Tanks Which Have Contained Leaded Gasoline." For what my comments may be worth (as they are very few), I am herewith making them in Section and Paragraph reference:

INTRODUCTION - GENERAL: We do not put a sign on tanks, such as you have indicated in this section.

INTRODUCTION - SOURCE AND NATURE OF THE HAZARD: Under source of hazard I suggest the addition of: (3) ATMOSPHERE of tank. (or some proper wording to call attention to the fact that breathing without protective equipment seems to be an immediate source of poisoning.)

Last word on page 2 should be "mask" instead of "When such a tank".

SECTION I - A - Item 7: After sentence beginning "Men engaged in the handling . . .", you might wish to add the following sentence: Working on windward side will reduce exposure.

SECTION I - B - Item 1: The removal of rust scale, etc. is different than our instructions.

Yours very truly,


O. B. LEWIS
Manager

O. B. L.B

KE 0007331

N 7860