

11/22/72

Act:

PCB Data are somewhat confusing during past week

Note this month's data

<u>Date</u>	<u>Dgt 246</u>	<u>Influent</u>	<u>Effluent</u>
11/1	1.45 #/day	3 #/day	0.8
11/5	—	5	(11)
11/8	1.21	10	(10)
11/12	0.38	6	4
11/15	(26.9)	9	(12.6)
11/19	2.3	2	8

Dgt 246: Sample on 11/15 reflects the equipment failure of the off-gas Condensate tank and resultant loss

Influent: High department loss did not show-up at Waste Treatment Influent. Could still be in low probab in the sewer system

Effluent: Confusion. Abnormally high numbers were not be explained. — Will clean sampling equipment.

MONS 058216

Ed Stewart