

Bulk Sample Analysis - Asbestos
Case 48106-3



PLAINTIFF'S EXHIBIT

SWB-114

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

February 29, 1980

Mr. Lucius Williams
Supervisor - Safety
AT&T Long Lines - Bedminster

The two bulk samples you mailed to me have been analyzed for asbestos by optical microscopy and x-ray diffraction. Sample number one taken from the back of stairway "C" between basement "A" and the first floor of 33 Thomas Street, New York, contained no asbestos. The principal crystalline materials noted were calcium sulfate anhydrate, calcium sulfate, and quartz. Sample number two taken from the fourth floor men's room at 33 Thomas Street, also contained no asbestos. The principal crystalline material noted in this sample was calcite.

Should you have any questions about this analysis, please feel free to give me a call at (201) 582-7512.

MH-8685-DR-km

David Rainer
Field Industrial Hygienist

Ref:1136

Copy to
G. W. Barnard - AT&T LL
D. Johnson, M.D.

R. L. Beach - AT&T
N. J. DeCapua
J. M. Degen
R. W. Stone, M.D.

THIS COPY IS FOR

W. J. Schreibeis
G. M. Wilkening

CONFIDENTIAL

003596