

cc: Chuck Guenther
Bob Whittle

WRG 006371



November 4, 1970

Mr. Ed Wilhelm
Kenneth Wischmeyer & Partners,
317 North 11th Street
St. Louis, Missouri 63101

SUBJECT: Multi Purpose Building
University of Missouri
Normandy, Missouri

Dear Ed:

At the request of Mr. Robert Whittle of Niehaus Interiors, I inspected their application of our fireproofing material Mono Kote on the above job. As you are aware in several areas this material has been left exposed and has eroded to some degree. There are also several areas where material has been removed by other trades to make attachment to a structural member.

In general the application appears to be fine, however, the areas that have been eroded need to be repaired to bring it up to the required thickness.

Mono Kote like any Gypsum based plaster material should not be left exposed to weather as it can be washed away. This however should not hurt the ultimate performance of our material.

Niehaus Interiors has had a great deal of experience in applying our material and are very qualified in this field.

If you desire any further information from us please let me know.

EXHIBIT

Egan S
ra 9/22/56

Very truly yours,
ZONOLITE DIVISION
W.R. GRACE & CO.,

Robert O. de Bastian,
District Manager

ROD:tm