34 Engle Street, Englewood
Asbestos Analysis -
Case 48106-3

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

October 12, 1978

PLAINTIFF'S EXHIBIT

SWB-167

A. B. Goetze
New Jersey Bell Telephone Company
540 Broad Street
Room 500
Newark, New Jersey

Dear Al:

The insulation sample from the Basement Power Room at 34 Engle Street Englewood, New Jersey has been analyzed by x-ray diffraction and optical microscopy for asbestos. Many fine fibers were noted by microscopic examination. The major crystalline material noted by x-ray diffraction was crysotile. The presence of chrysotile and the fibrous nature of the particles indicates that this sample is composed of asbestos.

Any disturbance of this material which would cause the release of fibers into the air must be controlled to avoid exposure as specified by federal regulation 29 CFR 1910.1001.

Sincerely,

C. P. Lichtenwalner

MH-7885-CPL-cls

Copy to
R. L. Beach - AT&T
N. J. DeCapua - AT&T
R. W. Stone, M.D. - AT&T
W. J. Schreibeis
G. M. Wilkening

CONFIDENTIAL

003770