MP
2/28/70

Aroclor Data = All results are for only 1242

A Losses From Department 246

1. Blow Tank Scrubber - Grab Samples

Sample No	ppm	ppd (based on 35 gpm)	Remarks
42	99.25	101	
43	29.17	30	Dept. Down
44	114.5	115	
45	88.75	90	
46	88.75	90	

2. 246 Main Sewer - Composite (24hr)

Sample No.	ppm
20	.0112
26	10.33
30	1.51

3. 246 Trench - 24hr. Composites

Sample No	PPm
21	.041
27	1.50
31	.021

B. Dept. 218 Carbon

two samples showed 6 & 8 ppb. Could be low due to difficulty in absorbing from carbon.

C. Sayget Waste Treatment Plant MCNS 072871

Sample Numbers	Int - ppm	Eff - ppm	% Rem.	ppd To TP	ppd To D...
32, 33	71.25	1.85			370
34, 35	.97	.588	40	124	118
40, 41	1.18	1.41	—	234	280
42, 43	.91	.887	—	152	177

AVG = 218 ppd