CELANESE CHEMICAL COMPANY
Chemcel Plant
Bishop, Texas

To: Mr. C. W. Harrison

From: James M. Jackson JMJ-42-78 August 16, 1978

Analysis of Ceiling Tile for Asbestos Fiber

Three samples of ceiling tile were submitted to the Laboratory by Mr. N. J. Sternadel, Safety Department, for asbestos fiber determination. This tile was being removed from the main office area during regular work hours. These samples were sent to the Celanese Chemical Company Technical Center for asbestos fiber determination. Results show that the ceiling tile does not contain asbestos fiber. See attached Laboratory report sheet[1].

No further work is planned unless requested.

J. M. Jackson

JMJ/as
Attachment
c: G. D. Boyd
G. Ille
W. H. Meyer
M. P. Neff
N. J. Sternadel
R. Updike

W. T. McNair - CCCTC
Central Files (2)

Uniterm

Ceiling Tile
Asbestos Fiber
OSHA

000471

[1] Laboratory work performed by Mr. P. A. Drake, Celanese Chemical Company Technical Center.

File: 259.2

PLAINTIFF'S EXHIBIT
CEL-300

LABORATORY NOTEBOOK

GEN-12M1 (10-56)

BOOK NO. 25122 PAGE NO. 16

SUBJECT Ceiling Tile

DATE 7-13-78

PROJECT OR SANCTION NO 492

#1
#2
#3

Samples do not contain asbestos fiber. Material appears to be a mineral wool of some type.

000472

READ AND UNDERSTOOD BY US

SIGNATURE OF WITNESS	DATE	SIGNATURE OF INVESTIGATOR	DATE
SIGNATURE OF WITNESS	DATE	SIGNATURE OF INVESTIGATOR	DATE