CYANAMID

To: H. C. Gaffney

Date: 1/23/84

Location: Chicago Plant

Copy to: J. Daly

From: R. Johnson

Location: Chicago Plant

Extension:

Subject: MONTH REPORT FOR JANUARY

Reference:

EFFLUENT New control valve on order. Six weeks delivery. Sample from inside due to snow taken Jan. 18th

MAINTENANCE PROBLEMS

Frozen shut Sulfuric Acid line. Line now open, but Sulfuric acid tank still needs a new valve and plug. This to be done when the tank is empty.

Changed ~~Vertical~~ RENTAL air compressor, waiting for ours to be rebuilt.

Install new parts 712 mill.

Rebagged outside dust collector - 144 bags 10 foot long. Spares should be ordered.

Jan. 12 feed pig lead 130 pigs/ shift.

Broke three screws in building 19.

Sprinkler line broke - frozen.

JOB ORDERS

Litharge Weighting System - will be able to check the big bin this month and correct if necessary.

Waxed Stabilizer Extruder - Talked to salesman on new pump and head, Laboratory to send samples for testing.

CYWI 1-000206

JOB ORDERS (Continued)

Oil & Gas Burner For Kiln - Rechecking new updated cost of gas vs oil to see if this burner should be installed.

TRF Lab Equipment - Other Brabender hooked - up. Motor Motor on the new blower was defective. Contractor is providing a replacement.

Purchase and Install Vertical Elevator - Elevator on order.

Purchase and Install Magnetic Grate - Grate on order due 2/1/84.

Purchase Semi - Bulk Containers - Containers on order. Some A/P have been delivered.

Purchase IBM Micro Computer - J. Daly will order extra parts.

Rider 26 Project - Job order written and submitted. Working on additional bids for this job.

R. Johnson