PLAINTIFF'S EXHIBIT WRG-1742

SPEED MESSAGE

TO Mr. R. Alshton
Supervisory Field Engr.
Follow-up Services
Chicago

FROM Fred L. Guillemot
Dist. Inspector
Clearwater I. C. 162

SUBJECT Zonolite R-4339, Tampa, Florida

Dear Dick:

DATE April 5, 1972

During my last inspection to Zonolite plant I noticed that the bags they were using for Monokote fireproofing type MK-3 were marked MK, see enclosed sample. There is a product MK which is produced by Zonolite, which is described in file #R5483, Vol. 1, Sec.1, which is not made at this plant. As you can see from enclosed sample the bag is marked with a fire resistant classification. This is the right label for type MK-3. It is not the right label for product MK which carries a fire hazard classification. These bags were printed by Union Camp Corp., in Savannah, GA., under Laboratories order #L19492, see copy attached. The copy of the wrapper report shows the description of these bags as being MK-3.

I believe the bags should be marked with the product they contain. Should I have the manufacturer mark a 3 beside the MK or shall I let them continue using these bags until their supply is exhausted(10,000)? The manufacturer stated that their bags are always marked in this way. Being a new account for me I cannot verify this.

Best regards,

Fred L. Guillemot

SIGNED

"SNAP-A-WAY" FORM 44-680 2-PARTS
WILLIAM JONES COMPANY • © 1961 • PRINTED IN U.S.A.

36

PLAINTIFF'S EXHIBIT G-107.102