

**Stationary Source Sampling Report
Mercury Emissions from the
End Box and Hydrogen Systems
PPG, Lake Charles, LA
December, 1984**

**PPG Industries, Inc.
Environmental Testing Group
Barberton Technical Center
P. O. Box 31
Barberton, OH 44203**

SL 025692

TABLE OF CONTENTS

	<u>Page No.</u>
I. Introduction	1
II. Abstract	1
III. Sampling Procedures	1
V. Results	2
V. Discussion	4
VI. Approvals	4

APPENDICES

A. Sample Location - End Box	5
B. Sample Location - Hydrogen System	8
C. Sampling and Analytical Methods	10
D. Sampling Parameters, Field Data and Results	24
E. Analytical QA and Results, Emission Calculations and Chain of Custody	48
F. Sampling QA	55

I. Introduction

Effective June 20, 1983, the State of Louisiana was delegated the authority to implement and enforce the National Emission Standards for Hazardous Air Pollutants (NESHAP) for stationary sources. Sections 76.18 of the Louisiana Emission Standards for Hazardous Air Pollutants (LESHAP) requires all LESHAP sources to demonstrate compliance with applicable regulations within ninety days of the effective date and yearly thereafter.

This report covers mercury emissions from the end box stack and hydrogen production at the chlor-alkali facility, Lake Charles complex during the period December 12 and 13, 1984. Sampling procedures, quality assurance, analytical methodology, and process related data are presented.

II. Abstract

Stationary source sampling was performed at the chlor-alkali facility, Lake Charles complex for mercury emissions December 12 and 13, 1984. The test results showed mercury emissions ranging 26 to 72 g/day at the end box stack and ≤ 11 to 140 g/day at the hydrogen system.

Testing was conducted in accordance with USEPA Test Methods 101 and 102 (40CFR61 Appendix B) with the following exceptions waived by the LESHAP Administrator: 1) One lane of the end box stack was sampled with the number of traverse points doubled due to structural interferences, 2) Non-isokinetic sampling was performed at the hydrogen system due to production constraints. Testing was witnessed in part by Mr. W. Coltrin, Louisiana Department of Natural Resources, Dept. of Environmental Quality.

III. Sampling Procedures

A. Sample Locations

1. End Box Stack (Appendix A)

Sample ports were installed on the south and east sides of the 12" ID end box stack 10'-9" downstream and 7'-8" upstream from any point of streamline disturbances such as bends, turns, constrictions, or expansions. Revised (48FR45035) Method 1 dictates an eight point traverse (four per lane). Building interferences negated sampling the west lane. The Administrator approved sampling the south lane only using eight traverse points instead of four. Traverse point locations and a stack diagram are shown in Appendix A.

2. Hydrogen System (Appendix B)

Routinely, the hydrogen produced at the mercury cell operation is sold as a raw material to a local chemical plant. If sales are interrupted for any reason, the hydrogen is used as boiler fuel. If an upset condition occurs in the cell operation, the hydrogen could be vented through the tertiary stack. Due to the size and pressure of the H₂ vent header and the potential disruption of product sales, the Administrator waived isokinetic sampling at this source. Integrated sampling was performed at the centroid of the PuraSiv bed vent lines (8"). Hydrogen flows were calculated based upon production. A flow diagram is shown in Appendix B.

B. Sampling Methods

1. End Box

Isokinetic sampling was performed at each of eight traverse points located along the north-south lane of the end box stack in accordance with Method 101 (40CFR61 Appendix B) included in this report as Appendix C. The recommended minimum sample duration of 2 hours was adhered to.

2. Hydrogen System

Integrated, non-isokinetic sampling was conducted for the minimum recommended 2 hours duration at the hydrogen system utilizing a Method 102 train (Appendix C) without the pitobe assembly. Hydrogen under pressure was valved into a mixing bottle from the discharge of the active PuraSiv® unit using 1/2" TFE tubing. Sampling was performed by attaching a short piece of 1/4" TFE tubing (valved) from the mixing bottle to the first impinger. To assure positive pressure in the mixing bottle at all times, the bottle was vented through a seal pot before being discharged to the atmosphere at a safe distance from the sampling equipment. The sample train orifice discharge was also vented away from the equipment for safety purposes. Appendix B shows a sampling flow diagram.

C. Analytical Methodology (Appendix C)

The analytical method employed for the determination of mercury followed the procedure detailed in Method 101 (40CFR61 Appendix B) included in this report as Appendix C.

IV. Results (Appendices D, E, and F)

The pertinent test results are presented in the following tables. Appendix D details sampling parameters, field sampling data sheets, and calculations. Appendix E contains the analytical quality assurance and results plus chain of custody. Appendix F presents sampling quality assurance.

A. End Box

	<u>84EB-1</u>	<u>Test No. 84EB-2</u>	<u>84EB-3</u>
	<u>12/12/84</u>	<u>12/12/84</u>	<u>12/13/84</u>
	<u>09:03-11:03</u>	<u>13:30-15:30</u>	<u>08:10-10:10</u>
Stack Gas Flow Rate, Dry scfm*	2260	2653	2600
Sample Volume, Dry SCF	77.399	77.180	74.562
Mercury Found, μg	525	1450	525
Emission Rate, g/d	25.98	71.80	26.38
Isokinetic Sampling Rate, %	97.8	97.8	96.4

B. Hydrogen System

	<u>84PV-1</u>	<u>Test No. 84PV-2</u>	<u>84PV-3</u>
	<u>12/13/84</u>	<u>12/13/84</u>	<u>12/13/84</u>
	<u>05:54-07:54</u>	<u>12:53-14:53</u>	<u>19:53-21:53</u>
	<u>East Bed</u>	<u>East Bed</u>	<u>East Bed</u>
Hydrogen Flow Rate, Dry scf*/day	6.056 ^{E06}	6.889 ^{E06}	7.092 ^{E06}
Sample Volume, scf	65.897	65.046	73.359
Mercury Found, μg	<125	<125	1450
Emission Rate, g/d	<11.49	<13.24	140.18

*Std. cubic foot at 68°F, 29.92" Hg

V. Discussion

PPG Industries, Lake Charles has demonstrated compliance with the Louisiana Emission Standard for Hazardous Air Pollutants.

This report has been reviewed and approved by Mr. R. J. Samelson, Manager of Environmental Programs, Chemicals Group.

VI. Approvals

Signed: L. A. Kuryla 1/4/85
L. A. Kuryla Date

M. P. Hogan 1/4/84
M. P. Hogan Date

T. F. Gole 1/4/84
T. F. Gole Date

W. Hebert 1/4/85
W. Hebert Date

M. Carver 1/4/85
M. Carver Date

Approved: W. G. Krochta 1/7/85
W. G. Krochta Date


M. Wood 1/7/85
M. Wood Date

H. J. Hoenes 1/7/85
H. J. Hoenes Date

APPENDIX A

Sample Location - End Box

SL 025698



MERCURY CELL
FUME SYSTEM

Preliminary Field Data

PLANT NAME PPG Lake Charles
 LOCATION Marine Cell
 SAMPLING LOCATION End Box Stack

DUCT DEPTH
 FROM INSIDE FAR WALL TO OUTSIDE OF PORT 17.75'
 NIPPLE LENGTH 5.75'
 DEPTH OF DUCT 12.0"
 WIDTH (RECTANGULAR DUCT) _____


EQUIVALENT DIAMETER:

$$D_E = \frac{2 \times \text{DEPTH} \times \text{WIDTH}}{\text{DEPTH} + \text{WIDTH}} = \frac{2 \times \text{K}}{\text{K} + \text{K}} = \text{_____}$$

DISTANCE FROM PORTS UPSTREAM DOWNSTREAM
 TO NEAREST FLOW DISTURBANCE: FEET 10'-9" 7'-8"

STACK DIAMETERS _____

STACK AREA = $(R)^2 \pi = 0.7854 \text{ m}^2$



One diam, 8 transverse pts

Point	% OF DIAMETER	DISTANCE FROM INSIDE WALL	DISTANCE FROM OUTSIDE OF PORT
1	3.2	3.84	6.75
2	10.5	1.26	7.01
3	19.4	2.33	8.08
4	32.3	3.88	9.63
5	47.7	8.12	13.87
6	80.6	9.67	15.42
7	89.5	10.74	16.49
8	96.8	11.62	16.75
9			
10	* Adj. to 1.		
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			

LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	6.7	6.4	1.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
2	75.0	14.0	10.5	8.2	6.7	5.7	4.9	4.4	4.0	3.5	3.3	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
3	75.0	29.6	19.4	14.6	11.9	9.9	8.5	7.5	6.7	6.0	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5
4	91.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9	7.9
5		81.4	47.7	34.2	25.7	20.1	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
6		91.4	60.6	41.8	29.6	20.9	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
7			77.4	44.4	30.6	20.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
8			94.0	51.4	31.6	20.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
9				91.0	42.3	21.1	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
10				97.4	40.2	20.9	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
11					93.3	40.4	20.4	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
12					97.9	40.1	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
13						94.3	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
14						98.2	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
15							95.1	40.1	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
16							98.4	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
17								95.6	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
18								98.6	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
19									94.1	40.3	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
20									98.7	40.6	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
21										98.5	40.1	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
22										98.0	40.5	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
23											98.0	40.5	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3	10.3
24												98.0	40.5	16.9	14.6	12.9	11.4	10.3	10.3	10.3	10.3	10.3	10.3	10.3

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	1	2	3	4	5	6	7	8	9	10	11	12
1	25.0	10.5	12.5	10.5	6.3	7.5	6.3	5.6	5.6	5.6	5.6	5.6
2	75.0	10.0	17.5	10.0	25.0	21.6	18.0	16.7	15.0	13.6	12.5	12.5
3		81.3	82.3	10.0	41.7	35.7	31.3	27.0	23.0	22.7	20.0	20.0
4			87.5	10.0	54.3	40.0	33.0	28.0	23.0	21.6	20.0	20.0
5				90.9	70.0	46.3	36.3	30.0	25.0	24.0	20.0	20.0
6					91.7	70.6	46.0	31.1	25.0	20.0	20.0	20.0
7						91.9	41.3	32.2	25.0	20.1	20.2	20.2
8							92.8	42.3	25.0	20.2	20.2	20.2
9								94.4	45.0	27.3	20.0	20.0
10									95.0	46.4	20.0	20.0
11										95.5	47.5	20.0


APPENDIX B

Sample Location - Hydrogen System

SL 025701

TO A SPHERE
TERTIARY STACK

SL 025702



8:9

MERCURY CELL HYDROGEN
SYSTEM

APPENDIX C
Sampling and Analytical Methods

SL 025703

Part 61, App. B

Title 40—Protection of Environment

APPENDIX B—TEST METHODS

METHOD 101—DETERMINATION OF PARTICULATE AND GASEOUS MERCURY EMISSIONS FROM CHLOR-ALKALI PLANTS—AIR STREAMS

1. Applicability and Principle—1.1 Applicability. This method applies to the determination of particulate and gaseous mercury (Hg) emissions from chlor-alkali plants and other sources (as specified in the regulations), where the carrier-gas stream in the duct or stack is principally air.

1.2 Principle. Particulate and gaseous Hg emissions are withdrawn isokinetically from the source and collected in acidic iodine monochloride (ICl) solution. The Hg collected (in the mercuric form) is reduced to elemental Hg, which is then aerated from the solution into an optical cell and measured by atomic absorption spectrophotometry.

2. Range and Sensitivity—2.1 Range. After initial dilution, the range of this method is 0.5 to 120 μg Hg/ml. The upper limit can be extended by further dilution of the sample.

2.2 Sensitivity. The sensitivity of this method depends on the recorder/spectrophotometer combination selected.

3. Interfering Agents—3.1 Sampling. SO₂ reduces ICl and causes premature depletion of the ICl solution.

3.2 Analysis. ICl concentrations greater than 10^{-4} molar inhibit the reduction of the Hg (II) ion in the aeration cell. Condensation of water vapor on the optical cell windows causes a positive interference.

4. Precision and Accuracy. The following estimates are based on collaborative tests, wherein 13 laboratories performed duplicate analyses on two Hg-containing samples from a chlor-alkali plant and on one laboratory-prepared sample of known Hg concentration. The concentration ranged from 2 to 66 μg Hg/ml.

4.1 Precision. The estimated within-laboratory and between-laboratory standard deviations are 1.6 and 1.8 μg Hg/ml, respectively.

4.2 Accuracy. The participating laboratories that analyzed a 64.3- μg Hg/ml (in 0.1 M ICl) standard obtained a mean of 63.7 μg Hg/ml.

5. Apparatus—5.1 Sampling Train. A schematic of the sampling train is shown in Figure 101-1; it is similar to the Method 5 train (mention of Method 5 refers to Parts 60 of 40 CFR). The sampling train consists of the following components:

5.1.1 Probe Nozzle, Pilot Tube, Differential Pressure Gauge, Metering System, Barometer, and Gas Density Determination Equipment. Same as Method 5, Sections

2.1.1, 2.1.3, 2.1.4, 2.1.8, 2.1.9, and 2.1.10, respectively.

5.1.2 Probe Liner. Borosilicate or quartz glass tubing. The tester may use a heating system capable of maintaining a gas temperature of $120 \pm 14^\circ \text{C}$ ($248 \pm 25^\circ \text{F}$) at the probe exit during sampling to prevent water condensation.

NOTE: Do not use metal probe liners.

5.1.3 Impingers. Four Greenburg-Smith impingers connected in series with leak-free ground glass fittings or any similar leak-free noncontaminating fittings. For the first, third, and fourth impingers, the tester may use impingers that are modified by replacing the tip with a 13-mm-ID (0.5-in.) glass tube extending to 13 mm (0.5 in.) from the bottom of the flask.

5.1.4 Acid Trap. Mine Safety Appliances air line filter, Catalog number 81857, with acid absorbing cartridge and suitable connections, or equivalent.

5.2 Sample Recovery. The following items are needed:

5.2.1 Glass Sample Bottles. Leakless, with Teflon-lined caps, 1000- and 100-ml.

5.2.2 Graduated Cylinder. 250-ml.

5.2.3 Funnel and Rubber Pellicman. To aid in transfer of silica gel to container; not necessary if silica gel is weighed in the field.

5.2.4 Funnel. Glass, to aid in sample recovery.

5.3 Sample Preparation and Analysis. The following equipment is needed:

5.3.1 Atomic Absorption Spectrophotometer. Perkin-Elmer 303, or equivalent, containing a hollow-cathode mercury lamp and the optical cell described in Section 5.3.2.

5.3.2 Optical Cell. Cylindrical shape with quartz end windows and having the dimensions shown in Figure 101-2. Wind the cell with approximately 2 meters of 34-gauge nichrome heating wire, and wrap with fiberglass insulation tape or equivalent; do not let the wires touch each other.

5.3.3 Aeration Cell. Constructed according to the specifications in Figure 101-3. Do not use a glass frit as a substitute for the blown glass bubbler tip shown in Figure 101-3.

5.3.4 Recorder. Matched to output of the spectrophotometer described in Section 5.3.1.

5.3.5 Variable Transformer. To vary the voltage on the optical cell from 0 to 40 volts.

5.3.6 Hood. For venting optical cell exhaust.

5.3.7 Flowmetering Valve.

5.3.8 Flowmeter. Rotameter or equivalent, capable of measuring a gas flow of 1.5 liters/min.

Part 61, App. B

Title 40—Protection of Environment

Pipet 5.0 ml from the "Intermediate Mercury Standard Solution" (6.2.4) into a 250-ml volumetric glass flask. Add 10 ml of the 5 percent H_2SO_4 and 2 ml of the 0.1 M ICI absorbing solution taken as a blank (7.2.3) and dilute to 250 ml with deionized distilled water. Mix thoroughly.

7. Procedure—7.1 Sampling. Because of the complexity of this method, testers should be trained and experienced with the test procedures to assure reliable results. Since the amount of Hg that is collected generally is small, the method must be carefully applied to prevent contamination or loss of sample.

7.1.1 *Pretest Preparation.* Follow the general procedure given in Method 5, Section 4.1.1, except omit the directions on the filter.

7.1.2 *Preliminary Determinations.* Follow the general procedure given in Method 5, Section 4.1.2, except as follows: Select a nozzle size based on the range of velocity heads to assure that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates below 25 liters/min (1.5 cfm).

Obtain samples over a period or periods that accurately determine the maximum emissions that occur in a 24-hour period. In the case of cyclic operations, run sufficient tests for the accurate determination of the emissions that occur over the duration of the cycle. A minimum sample time of 2 hours is recommended. In some instances, high Hg or high SO₂ concentrations make it impossible to sample for the desired minimum time. This is indicated by reddening (liberation of free iodine) in the first impinger. In these cases, the tester may divide the sample run into two or more subruns to insure that the absorbing solution is not depleted.

7.1.3 *Preparation of Sampling Train.* Clean all glassware (probe, impingers, and connectors) by rinsing with 50 percent HNO_3 , tap water, 0.1 M ICI, tap water, and finally deionized distilled water. Place 100 ml of 0.1 M ICI in each of the first three impingers. Take care to prevent the absorbing solution from contacting any greased surfaces. Place approximately 200 g of preweighed silica gel in the fourth impinger. The tester may use more silica gel, but should be careful to ensure that it is not entrained and carried out from the impinger during sampling. Place the silica gel container in a clean place for later use in the sample recovery. Alternatively, determine and record the weight of the silica gel plus impinger to the nearest 0.5 g.

Install the selected nozzle using a Viton A O-ring when stack temperatures are less than 200° C (500° F). Use a fiberglass string gasket if temperatures are higher. See APTD-0576 (Citation 9 in Section 10) for details. Other connecting systems using either

316 stainless steel or Teflon ferrules may be used. Mark the probe with heat-resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point. Assemble the train as shown in Figure 101-1, using (if necessary) a very light coat of silicone grease on all ground glass joints. Grease only the outer portion (see APTD-0576) to avoid possibility of contamination by the silicone grease.

NOTE: An empty impinger may be inserted between the third impinger and the silica gel to remove excess moisture from the sample stream.

After the sampling train has been assembled, turn on and set the probe, if applicable, at the desired operating temperature. Allow time for the temperatures to stabilize. Place crushed ice around the impingers.

7.1.4 *Leak-Check Procedures.* Follow the leak-check procedures outlined in Method 5, Sections 4.1.4.1 (Pretest Leak Check), 4.1.4.2 (Leak Checks During Sample Run), and 4.1.4.3 (Post-Test Leak Check).

7.1.5 *Mercury Train Operation.* Follow the general procedure given in Method 5, Section 4.1.5. For each run, record the data required on a data sheet such as the one shown in Figure 101-4.

7.1.6 *Calculation of Percent Isokinetic.* Same as Method 5, Section 4.1.6.

7.2 *Sample Recovery.* Begin proper cleanup procedure as soon as the probe is removed from the stack at the end of the sampling period.

Allow the probe to cool. When it can be safely handled, wipe off any external particulate matter near the tip of the probe nozzle and place a cap over it. Do not cap off the probe tip tightly while the sampling train is cooling. Capping would create a vacuum and draw liquid out from the impingers.

Before moving the sampling train to the cleanup site, remove the probe from the train, wipe off the silicone grease, and cap the open outlet of the probe. Be careful not to lose any condensate that might be present. Wipe off the silicone grease from the impinger. Use either ground-glass stoppers, plastic caps, or serum caps to close these openings.

Transfer the probe and impinger assembly to a cleanup area that is clean, protected from the wind, and free of Hg contamination. The ambient air in laboratories located in the immediate vicinity of Hg-using facilities is not normally free of Hg contamination.

Inspect the train before and during assembly, and note any abnormal conditions. Treat the sample as follows:

7.2.1 *Container No. 1 (Impinger and Probe).* Using a graduated cylinder, measure the liquid in the first three impingers to

Chapter I—Environmental Protection Agency

Part 61, App. B

within ± 1 ml. Record the volume of liquid present (e.g., see Figure 5-3 of Method 5). This information is needed to calculate the moisture content of the effluent gas. (Use only glass storage bottles and graduated cylinders that have been precleaned as in Section 7.1.3.) Place the contents of the first three impingers into a 1000-ml glass sample bottle.

Taking care that dust on the outside of the probe or other exterior surfaces does not get into the sample, quantitatively recover the Hg (and any condensate) from the probe nozzle, probe fitting, and probe liner as follows: Rinse these components with two 50-ml portions of 0.1-M ICl. Next, rinse the probe nozzle, fitting and liner, and each piece of connecting glassware between the probe liner and the back half of the third impinger with a maximum of 400 ml of deionized distilled water. Add all washings to the 1000-ml glass sample bottle containing the liquid from the first three impingers.

After all washings have been collected in the sample container, tighten the lid on the container to prevent leakage during shipment to the laboratory. Mark the height of the liquid to determine later whether leakage occurred during transport. Label the container to clearly identify its contents.

7.2.2 Container No. 2 (Silica Gel). Note the color of the indicating silica gel to determine whether it has been completely spent and make a notation of its condition. Transfer the silica gel from its impinger to its original container and seal. The tester may use as aids a funnel to pour the silica gel and a rubber policeman to remove the silica gel from the impinger. The small amount of particles that may adhere to the impinger wall need not be removed. Since the gain in weight is to be used for moisture calculations, do not use any water or other liquids to transfer the silica gel. If a balance is available in the field, weigh the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g; record this weight.

7.2.3 Container No. 3 (Absorbing Solution Blank). For a blank, place 50 ml of the 0.1 M ICl absorbing solution in a 100-ml sample bottle. Seal the container. Use this blank to prepare the working mercury standard solution (8.2.5).

7.3 Sample Preparation. Check the liquid level in each container to see whether liquid was lost during transport. If a noticeable amount of leakage occurred, either void the sample or use methods subject to the approval of the Administrator to account for the losses. Then follow the procedures below:

7.3.1 Container No. 1 (Impinger and Probe). Carefully transfer the contents of Container No. 1 into a 1000-ml volumetric flask and adjust the volume to exactly 1000 ml with deionized distilled water.

7.3.2 Dilutions. Pipet a 2-ml aliquot from the diluted sample from 7.3.1 into a 250-ml volumetric flask. Add 10 ml of 5 percent H₂SO₄ and adjust the volume to exactly 250 ml with deionized distilled water. These solutions are stable for at least 72 hours.

NOTE: The dilution factor will be 250/2 for this solution.

7.4 Analysis. Calibrate the spectrophotometer and recorder and prepare the calibration curve as described in Sections 8.1 to 8.4.

7.4.1 Mercury Samples. Repeat the procedure used to establish the calibration curve with appropriately sized aliquots (1 to 5 ml) of each of the diluted samples (from Section 7.3.2) until two consecutive peak heights agree within ± 3 percent of their average value. The peak maximum of an aliquot (except the 5-ml aliquot) must be greater than 10 percent of the recorder full scale. If the peak maximum of a 1.0-ml aliquot is off scale on the recorder, further dilute the original source sample to bring the Hg concentration into the calibration range of the spectrophotometer.

Run a blank and standard at least after every five samples to check the spectrophotometer calibration; recalibrate as necessary.

It is also recommended that at least one sample from each stack test be checked by the method of standard additions to confirm that matrix effects have not interfered in the analysis.

7.4.2 Container No. 2 (Silica Gel). Weigh the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g using a balance. (This step may be conducted in the field.)

8. Calibration and Standards—Before use, clean all glassware, both new and used, as follows: brush with soap and water, liberally rinse with tap water, soak for 1 hour in 50 percent HNO₃, and then rinse with deionized distilled water.

8.1 Flow Calibration. Assemble the aeration system as shown in Figure 101-5. Set the outlet pressure on the aeration gas cylinder regulator to a minimum pressure of 500 mm Hg (10 psid), and use the flowmetering valve and a bubble flowmeter or wet test meter to obtain a flow rate of 1.5 ± 0.1 liters/min through the aeration cell. After the flow calibration is complete, remove the bubble flowmeter from the system.

8.2 Optical Cell Heating System Calibration. Using a 50-ml graduated cylinder, add 50 ml of deionized distilled water to the bottle section of the aeration cell and attach the bottle section to the bubbler section of the cell. Attach the aeration cell to the optical cell; and while aerating at 1.5 liters/min, determine the minimum variable transformer setting necessary to prevent condensation of moisture in the optical cell and in the

Part 61, App. 8

connecting tubing. (This setting should not exceed 30 volts.)

8.3 Spectrophotometer and Recorder Calibration. The mercury response may be measured by either peak height or peak area.

NOTE: The temperature of the solution affects the rate at which elemental Hg is released from a solution and, consequently, it affects the shape of the absorption curve (area) and the point of maximum absorbance (peak height). Therefore, to obtain reproducible results, bring all solutions to room temperature before use.

Set the spectrophotometer wavelength at 253.7 nm, and make certain the optical cell is at the minimum temperature that will prevent water condensation. Then set the recorder scale as follows: Using a 50-ml graduated cylinder, add 50 ml of deionized distilled water to the aeration cell bottle and pipet 5.0 ml of the working mercury standard solution into the aeration cell.

NOTE: Always add the Hg-containing solution to the aeration cell after the 50 ml of deionized distilled water.

Place a Teflon-coated stirring bar in the bottle. Before attaching the bottle section to the bubbler section of the aeration cell, make certain that (1) the aeration cell exit arm stopcock (Figure 161-3) is closed (so that Hg will not prematurely enter the optical cell when the reducing agent is being added) and (2) there is no flow through the bubbler. If conditions (1) and (2) are met, attach the bottle section to the bubbler section of the aeration cell through the side arm of the cell and immediately stopper the side arm. Stir the solution for 15 sec, turn on the recorder, open the aeration cell exit arm stopcock, and then immediately initiate aeration with continued stirring. Determine the maximum absorbance of the standard and set this value to read 99 percent of the recorder full scale.

8.4 Calibration Curve. After setting the recorder scale, repeat the procedure in Section 8.3 using 0.5-, 1.0-, 2.0-, 3.0-, 4.0-, and 5.0-ml aliquots of the working standard solution (final amount of Hg in the aeration cell is 0.250, 0.500, 0.750, 1.00, and 1.500 mg, respectively). Repeat this procedure on each aliquot size until two consecutive peaks agree within 3 percent of their average value. (Note: To prevent Hg carryover from one sample to another, do not close the aeration gas tank valve and do not disconnect the aeration cell from the optical cell until the recorder pen has returned to the baseline.) It should not be necessary to disconnect the aeration gas inlet line from the aeration cell when changing samples. After separating the bottle and bubbler sections of the aeration cell, place the bubbler section into a 600-ml beaker containing approximately 400 ml of deionized distilled water.

Title 40—Protection of Environment

Rinse the bottle section of the aeration cell with a stream of deionized distilled water to remove all traces of the tin (II) reducing agent. Also, to prevent the loss of Hg before aeration, remove all traces of the reducing agent between samples by washing with deionized distilled water. It will be necessary, however, to wash the aeration cell parts with concentrated HCl if any of the following conditions occur: (1) A white film appears on any inside surface of the aeration cell, (2) the calibration curve changes suddenly, or (3) the replicate samples do not yield reproducible results.

Subtract the average peak height (or peak area) of the blank (0.5-ml aliquot)—which should be less than 3 percent of recorder full scale—from the averaged peak heights of the 1.0-, 2.0-, 3.0-, 4.0-, and 5.0-ml aliquot standards. If the blank absorbance is greater than 3 percent of full-scale, the probable cause is Hg contamination of a reagent or carry-over of Hg from a previous sample. Plot the corrected peak height of each standard solution versus the corresponding final total Hg weight in the aeration cell (in mg) and draw the best-fit straight line. This line should either pass through the origin or pass through a point no further from the origin than ± 3 percent of the recorder full scale. If the line does not pass through or very near to the origin, check for nonlinearity of the curve and for incorrectly prepared standards.

8.5 Sampling Train Calibration. Calibrate the sampling train components according to the procedures outlined in the following sections of Method 8: Section 8.1 (Probe Nozzle), Section 8.2 (Pilot Tube), Section 8.3 (Metering System), Section 8.4 (Probe Heater), Section 8.5 (Temperature Gauge), Section 8.7 (Barometer). Note that the leak-check described in Section 8.6 of Method 8 applies to this method.

8. Calculations—8.1 Dry Gas Volume. Using the data from this test, calculate V_{stack} , the dry gas sample volume at standard conditions (corrected for leakage, if necessary) as outlined in Section 8.3 of Method 8.

8.2 Volume of Water Vapor and Moisture Content. Using the data obtained from this test, calculate the volume of water vapor $V_{\text{H}_2\text{O}}$ and the moisture content H_m of the stack gas. Use Equations 8-2 and 8-3 of Method 8.

8.3 Stack Gas Velocity. Using the data from this test and Equation 8-9 of Method 2, calculate the average stack gas velocity v_s .

8.4 Total Mercury. For each source sample, correct the average maximum absorbance of the two consecutive samples whose peak heights agree within ± 3 percent of their average for the contribution of the solution blank (see Section 8.4). Use the calibration curve and these corrected aver-

Chapter 1—Environmental Protection Agency

Part 61, App. B

ages, to determine the final total weight of mercury in nanograms in the aeration cell for each source sample. Correct for any dilutions made to bring the sample in the working range of the spectrophotometer. Then calculate the Hg in μg (m_{Hg}) in the original solution as follows:

$$m_{\text{Hg}} = \frac{C_{\text{total}} \text{ D.F. } V, 10^{-4}}{8}$$

Eq. 101-1

Where:

C_{total} —Total nanograms of mercury in aliquot analyzed (reagent blank subtracted).

D.F.—Dilution factor for the Hg-containing solution (before adding to the aeration cell; e.g., D.F.=250/2 if the source samples were diluted as described in Section 7.2.2.)

V —Solution volume of original sample, 1000 ml for samples diluted as described in Section 7.2.1.

10^{-4} —Conversion factor, $\mu\text{g}/\text{ng}$.

S —Aliquot volume added to aeration cell, ml.

9.5 Mercury Emission Rate. Calculate the Hg emission rate R in g/day for continuous operations using Equation 101-2. For cyclic operations, use only the time per day each stack is in operation. The total Hg emission rate from a source will be the summation of results from all stacks.

$$R = K \frac{m_{\text{Hg}} \times A (24,000 \times 10^{-3})}{(V_{\text{stack}} + V_{\text{atm}})(T/P)}$$

Eq. 101-2

Where:

A —Stack cross-sectional area, m^2 (ft^2).

24,000—Conversion factor, sec/day.

10^{-3} —Conversion factor, g/ μg .

T —Absolute average stack gas temperature, $^{\circ}\text{K}$ ($^{\circ}\text{R}$).

P —Absolute stack gas pressure, mm Hg (in. Hg).

K —0.3858 $^{\circ}\text{K}/\text{mm Hg}$ for metric units.
—17.88 $^{\circ}\text{R}/\text{in. Hg}$ for English units.

9.6 Isokinetic Variation and Acceptable Results. Same as Method 5, Sections 6.11 and 6.12, respectively.

9.7 Determination of Compliance. Each performance test consists of three repetitions of the applicable test method. For the purpose of determining compliance with an

applicable national emission standard, use the average of the results of all repetitions.

10. *Bibliography.* 1. Addendum to Specifications for Incinerator Testing at Federal Facilities. PHS, NCAFC, December 6, 1967.

2. Determining Dust Concentration in a Gas Stream. ASME Performance Test Code No. 27, New York, NY, 1967.

3. Devortin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, CA, November 1963.

4. Hatch, W.R., and W.I. Ott. Determination of Sub-Microgram Quantities of Mercury by Atomic Absorption Spectrophotometry. Anal. Chem. 40:2668-67, 1968.

5. Mark, L.S. Mechanical Engineers' Handbook. McGraw-Hill Book Co., Inc. New York, NY, 1951.

6. Martin, Robert M. Construction Details of Isokinetic Source Sampling Equipment. U.S. Environmental Protection Agency, Research Triangle Park, NC. Publication No. APTD-6841, April 1971.

7. Western Precipitation Division of Joy Manufacturing Co. Methods for Determination of Velocity, Volume, Dust and Mist Content of Gases. Bulletin WP-66, Los Angeles, CA, 1966.

8. Perry, J.H. Chemical Engineers' Handbook. McGraw-Hill Book Co., Inc. New York, NY, 1969.

9. Rom, Jerome J. Maintenance, Calibration, and Operation of Isokinetic Source Sampling Equipment. U.S. Environmental Protection Agency, Research Triangle Park, NC. Publication No. APTD-6876, April 1972.

10. Shigehara, R.T., W.F. Todd, and W.S. Smith. Significance of Errors in Stack Sampling Measurements. Stack Sampling News. 12:13-18, September 1973.

11. Smith, W.S., et al. Stack Gas Sampling Improved and Simplified with New Equipment. AFCA Paper No. 67-119, 1967.

12. Smith, W.S., R.T. Shigehara, and W.F. Todd. A Method of Interpreting Stack Sampling Data. Stack Sampling News. 12:13-17, August 1973.

13. Specifications for Incinerator Testing at Federal Facilities. PHS, NCAFC, 1967.

14. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Annual Book of ASTM Standards, Part 21. ASTM Designation D-2828-71. Philadelphia, PA, 1971.

15. Vennard, J.K. Elementary Fluid Mechanics. John Wiley and Sons, Inc. New York, 1947.

16. Mitchell, W.J., and M.R. Midgett. Improved Procedure for Determining Mercury Emissions from Mercury Cell Chlor-Alkali Plants. J. AFCA. 26: 674-677, July 1976.

17. Shigehara, R.T. Adjustments in the EPA Nomograph for Different Pitot Tube Coefficients and Dry Molecular Weights. Stack Sampling News. 24-11, October 1974.

Chapt

19. Klein, R., and C. Hach. *Standard Addition: Uses and Limitation in Spectrophotometric Measurements*. Amer. Lab. 9:21. 1977.

20. Water. *Atmospheric Analysis*. In: *Annual Book of ASTM Standards*, Part 31. ASTM Designation D-1163-74. Philadelphia, PA. 1974.

20. Water, Atmospheric Analysis. In Annual Book of ASTM Standards, Part 31. ASTM Designation D-1193-74. Philadelphia, PA. 1974.

[illegible]




Figure 101-1 Mercury sampling train.

Part 61, App. B

Title 40—Protection of Environment




Figure 101-2. Optical cell.




Figure 101-3. Aeration cell.

AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED HEIGHT, ft _____
 PPODE LENGTH, in (ft) _____
 NOZZLE IDENTIFICATION NO. _____
 AVERAGE CALCULATED NOZZLE DIAMETER, in (ft) _____
 PPODE HEATER SETTINGS _____
 LEAK RATE, m^3/hr (ft³/hr) _____
 PPODE LUNCH MATERIALS _____
 STATIC PRESSURE, in (ft) H₂O _____
 FILTER NO. _____

Part 61, Appendix B

C:20

Title 40—Protection of Environment

TRAVERSE POINT NUMBER	SAMPLING TIME (M, sec.)	VACUUM mm Hg (in. H ₂ O)	STACK TEMPERATURE (°F) (°C F°)	VELOCITY FEET MIN.	PRESSURE DIFFERENTIAL ACROSS ORifice METER mm H ₂ O (in. H ₂ O)	GAS SAMPLE VOLUME cu ft (m³)	GAS SAMPLE TEMPERATURE AT ORIF GAS METER		FILTER COLLECTOR* TEMPERATURE (°F) (°C)	TEMPERATURE OF GAS LEAVING COILS CONDENSER OR LAST PIPEWORK (°F) (°C)
							INLET (°F) (°C)	OUTLET (°F) (°C)		
TOTAL							Avg.	Avg.		
AVERAGE							Avg.	Avg.		

THE APPLICABLE

Fig. 101-4. Mercury field data:

80

SL 025713




Figure 101-5. Schematic of aeration system.

Chapter I—Environmental Protection Agency

Part 61, App. B

Method 101, Section 8, except for the following variations:

8.1 Optical Cell Heating System Calibration. Same as method 101, Section 8.1, except use a 25-ml graduated cylinder to add 25 ml of deionized distilled water to the bottle section of the aeration cell.

8.2 Spectrophotometer and Recorder Calibration. The mercury response may be measured by either peak height or peak area. (Note: the temperature of the solution affects the rate at which elemental Hg is released from a solution and, consequently, it affects the shape of the absorption curve (area) and the point of maximum absorbance (peak height). To obtain reproducible results, all solutions must be brought to room temperature before use.) Set the spectrophotometer wave length at 253.7 nm and make certain the optical cell is at the minimum temperature that will prevent water condensation.

Then set the recorder scale as follows: Using a 25-ml graduated cylinder, add 25 ml of deionized distilled water to the aeration cell bottle and pipet 5.0 ml of the working mercury standard solution into the aeration cell. (Note: Always add the Hg-containing solution to the aeration cell after the 25 ml of deionized distilled water.) Place a Teflon-coated stirring bar in the bottle. Add 5 ml of the 4 percent KIO₃ absorbing solution followed by 5 ml of 15 percent HNO₃ and 5 ml of 5 percent KIO₃ to the aeration bottle and mix well. Now, attach the bottle section to the bubbler section of the aeration cell and make certain that (1) the aeration cell exit arm stopcock (Figure 101-3 of Method 101) is closed (so that Hg will not prematurely enter the optical cell when the reducing agent is being added) and (2) there is no flow through the bubbler. Add 5 ml of sodium chloride hydroxylamine in 1-ml increments until the solution is colorless. Now add 5 ml of tin (II) solution to the aeration bottle through the side arm. Stir the solution for 15 seconds, turn on the recorder, open the aeration cell exit arm stopcock, and immediately initiate aeration with continued stirring. Determine the maximum absorbance of the standard and set this value to read 99 percent of the recorder full scale.

8. Calculations—8.1 Dry Gas Volume, Volume of Water Vapor and Moisture Content, Stack Gas Velocity, Isokinetic Variation and Acceptable Results, and Determination of Compliance. Same as Method 101, Sections 8.1, 8.2, 8.3, 8.4, and 8.7, respectively, except use data obtained from this test.

8.2 Total Mercury. For each source sample, correct the average maximum absorbance of the two consecutive samples whose peak heights agreed within ± 3 percent of their average for the contribution of the field blank. Then calculate the total Hg content in μg in each sample. Correct for

any dilutions made to bring the sample into the working range of the spectrophotometer.

8.3 Mercury Emission Rate. Calculate the Hg emission rate R in g/day for continuous operations using Equation 101A-1. For cyclic operations, use only the time per day each stack is in operation. The total Hg emission rate from a source will be the summation of results from all stacks.

$$R = K \frac{m_{\text{Hg}} V_A (24,000 \times 10^{-9})}{(V_{\text{dry}} + V_{\text{water}})(T/P)}$$

Eq. 101A-1

Where:

m_{Hg} = Total Hg content in each sample, μg .

V_A = Average stack gas velocity, m/sec (ft/min).

A = Stack cross-sectional area, m^2 (ft^2).

84,460 = Conversion factor, sec/day.

10^{-9} = Conversion factor, g/ μg .

V_{dry} = Dry gas sample volume at standard conditions, corrected for leakage (if any), m^3 (ft^3).

V_{water} = Volume of water vapor at standard conditions, m^3 (ft^3).

T = Absolute average stack gas temperature, $^{\circ}\text{K}$ ($^{\circ}\text{R}$).

P = Absolute stack gas pressure, mm Hg (in. Hg).

K = 0.3255 $^{\circ}\text{K}/\text{mm Hg}$ for metric units.

= 17.64 $^{\circ}\text{R}/\text{in. Hg}$ for English units.

10. Bibliography. 1. Same as Method 101, Section 10.

2. Mitchell, W. J., M. R. Midgett, J. C. Sager, and D. Albritton.

Test Methods to Determine the Mercury Emissions from Sludge Incineration Plants. U.S. Environmental Protection Agency. Research Triangle Park, North Carolina. Publication No. EPA-600/4-79-042. September 1979.

METHOD 102—DETERMINATION OF PARTICULATE AND GASEOUS MERCURY EMISSIONS FROM CHLOR-ALKALI PLANTS—HYDROGEN STREAMS

1. Introduction.—Although similar to Method 101, Method 102 requires changes to accommodate the sample being extracted from a hydrogen stream. Conduct the test according to Method 101, except as shown below:

2. Mercury Train Operation—2.1 Probe Heating System. Do not use, unless otherwise specified.

2.2 Glass Fiber Filter. Do not use, unless otherwise specified.

2.3 Safety Procedures. The sampler must conduct the source test under conditions of utmost safety, because hydrogen and air

Part 61, App. B

mixtures are explosive. Since the sampling train essentially is leakless, attention to safe operation can be concentrated at the inlet and outlet. If a leak does occur, however, remove the meter box cover to avoid a possible explosive mixture. The following specific precautions are recommended:

2.3.1 Operate only the vacuum pump during the test. The other electrical equipment, e.g., heaters, fans, and timers, normally are not essential to the success of a hydrogen stream test.

2.3.2 Seal the sample port to minimize leakage of hydrogen from the stack.

2.3.3 Vent sampled hydrogen at least 5 m (15 feet) away from the train. This can be accomplished by attaching a 13-mm-ID (0.50-in.) Tyson tube to the exhaust from the orifice meter. (Note: A smaller ID tubing may cause the orifice meter calibration to be erroneous.) Take care to ensure that the exhaust line is not bent or pinched.

2.4 Setting of Isokinetic Rates.

2.4.1 If a nomograph is used, take special care in the calculation of the molecular weight of the stack gas and in the setting of the nomograph to maintain isokinetic conditions during sampling (Sections 2.4.1.1 through 2.4.1.3 below).

2.4.1.1 Calibrate the meter box orifice. Use the techniques described in APTD-6576 (see Citation 9 in Section 10 of Method 101). Calibration of the orifice meter at flow conditions that simulate the conditions at the source is suggested. Calibration should either be done with hydrogen or with some other gas having a similar Reynolds Number so that there is similarity between the Reynolds Numbers during calibration and during sampling.

2.4.1.2 The nomograph described in APTD-6576 cannot be used to calculate the C factor because the nomograph is designed for use when the stack gas dry molecular weight is 30±4. Instead, the following calculation should be made to determine the proper C factor:

$$C = \frac{2.0 \times 10^4 \Delta H_0 \sqrt{C_p T_s / P_s}}{(1 - R_w) \sqrt{M_d}} \quad (2.4.1.2)$$

Where:

ΔH_0 —Meter box calibration factor obtained in Section 2.4.1.1, in H₂O.

C_p —Pitot tube calibration coefficient, dimensionless.

T_s —Absolute temperature of gas at the orifice, °R.

P_s —Absolute pressure of stack gas, in Hg.

P_m —Absolute pressure of gas at the meter, in Hg.

R_w —Fraction by volume of water vapor in the stack gas.

M_d —Dry molecular weight of stack gas, lb/lb-mole.

Title 40—Protection of Environment

Note: This calculation is left in English units, and is not converted to metric units because nomographs are based on English units.

2.4.1.3 Set the calculated C factor on the operating nomograph and select the proper nozzle diameter and K factor as specified in APTD-6576. If the C factor obtained in Section 2.4.1.2 exceeds the values specified on the existing operating nomograph, expand the C scale logarithmically so that the values can be properly located.

2.4.2 If a calculator is used to set isokinetic rates, it is suggested that the isokinetic equation presented in Citation 17 in the Bibliography of Method 101 be used.

2.5 Sampling in Small (<13-in.-Diameter) Stacks. When the stack diameter (or equivalent diameter) is less than 13 inches, conventional "pitot tube-probe" assemblies should not be used. For sampling guidelines, see Citation 18 in the Bibliography of Method 101.

METHOD 103—BERYLLIUM SAMPLING METHOD

1. Principle and applicability.—1.1 Principle.—Beryllium emissions are isokinetically sampled from three points in a duct or stack. The collected sample is analyzed for beryllium using an appropriate technique.

1.2 Applicability.—This procedure details guidelines and requirements for methods acceptable for use in determining beryllium emissions in ducts or stacks at stationary sources, as specified under the provisions of § 61.14 of the regulations.

2. Apparatus.—2.1 Sampling train.—A schematic of the required sampling train configuration is shown in figure 103-1. The essential components of the train are the following:

2.1.1 Nozzle.—Stainless steel, or equivalent, with sharp, tapered leading edge.

2.1.2 Probe.—Sheathed Pyrex® glass.

2.1.3 Filter.—Millipore AA, or equivalent, with appropriate filter holder that provides a positive seal against leakage from outside or around the filter. It is suggested that a Whatman 41, or equivalent, be placed immediately against the back side of the Millipore filter as a guard against breakage of the Millipore. Include the Whatman 41 in the analysis. Equivalent filters must be at least 99.5 percent efficient (DOP Test) and amenable to the analytical procedure.

2.1.4 Meter-pump system.—Any system that will maintain isokinetic sampling rate, determine sample volume, and is capable of a sampling rate of greater than 0.5 cfm.

2.2 Measurement of stack conditions.—(stack pressure, temperature, moisture and

*Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

APPENDIX D

Sampling Parameters, Field Data and Results

SL 025717

4EB-1

FIELD SAMPLING DATA

0:25

12/11/84 700-3001

29.8400730

Amb. T 64



PLANT & LOCATION

Lake Charles Plant A

ASSUMED: $X_{H_2O} \sim 2.0$; T_g , °F 63

End Box Stack (Circumferential)

Pa. in. WG 30.00

DATE: 12/12/84 TEST NO.: 84EB-1

LEAK CHECKS

EQUIP.: MFG. Anderson METER BOX NO. B-4

INITIAL 3 FINAL

YD 0.9698 ΔH_g : 2.00 SAMP. BOX NO. B-4

TRAIN: 201°C @ 0.002 @ 11"

OPERATOR M. Hagan / J. Kuyler

PITOT: IMP. 5.3" OK 7.8"

PITOTBE: NO. 16 TYPE S Cp 0.84

WAKE 6.8 OK 8.0"

NOZZLE: NO. 1 ID, in. 0.189 Ft² 1.948^{E-04}

FIELD METER CHECK

STACK: DIMENSIONS 12" AREA 0.7854 Ft²

Cylinder Flow ✓ =

K r A P REF.: 1.57 C FACTOR

Plant

Test No.

One lane only 4-5, 8 pt
Date 15 min / pt. $\theta = 120$ min.

Comments	Clock Time	Dry Gas Meter, CF	Pitot ΔP in. H ₂ O	$\sqrt{\Delta P}$	Orifice ΔH in H ₂ O	Dry Gas Temp., °F In Ave. Or	Pump Vacuum In. Hg Gauge	Orifice Meter Temp. °F	Impinger Temp. °F	Stack Press. in H ₂ O	Stack Temp. °F
403	0	408.900	1.3	1.1	2.00	73 23	8.0	288	45	-0.40	63
	5	413.400	1.3		2.00	100 74	8.2	282	44		63
	10	416.400	1.3		2.00	107 76	8.5	258	46		64
	15	420.175	1.25		1.90	112 78	8.5	250	48		65
	20	424.965	1.25		1.90	115 81	8.5	240	47		
2	25	427.850	1.25		1.90	117 84	8.5	237	47		
	30	431.690	1.20		1.83	119 87	8.5	233	48	-0.50	65
	35	435.540	1.20		1.83	120 89	8.5	232	48		
3	40	439.390	1.20		1.85	120 91	8.5	225	47		66
	45	443.248	1.15		1.75	121 92	8.5	256	47		
	50	447.000	1.15		1.75	120 92	8.0	253	47		
4	55	450.775	1.15		1.75	121 93	8.0	251	46	-0.45	67
	60	454.485	0.99		1.50	120 94	7.0	249	46		
	65	457.975	0.99		1.50	119 95	7.0	245	46		
5	70	461.475	0.99		1.50	119 95	7.0	246	47	-0.47	66
	75	465.002	0.92		1.42	118 95	7.0	247	48		
	80	468.350	0.93		1.44	118 96	7.0	250	48		
	85	471.785	0.93		1.44	118 95	7.0	250	48	-0.48	66
	90	475.170	0.83		1.28	119 95	6.0	250	48		
	95	478.410	0.83		1.28	118 96	6.0	248	49		
7	100	481.620	0.83		1.28	118 96	6.0	248	49	-0.48	66

SL 025718

D:27



ORSAT ANALYSIS

Test No. B4 EB-1 Date 12-12-84
Sampl Location END BOX Stack Analyzed by M. Hogan
Sample Type Integrated Bag
Volume (30 L minimum) _____
Time (4 hrs. max. after sampling) 1135

Orsat Leak Checks(Mandatory)

Before OK
After OK

Orsat Test No.	CO ₂	+	O ₂	O ₂	CO	N ₂
1	<u>0.0</u>		<u>20.8</u>	<u>20.8</u>	<u>0</u>	<u>79.2</u>
2	<u>0.0</u>		<u>20.8</u>	<u>20.8</u>	<u>0</u>	<u>79.2</u>
3	<u>0.0</u>		<u>20.8</u>	<u>20.8</u>	<u>0</u>	<u>79.2</u>
4	—		—	—	—	—
5	—		—	—	—	—
6	—		—	—	—	—
AVE.	—		—	—	—	—

Ambient Air 20.8%

M. Hogan

SL 025720

84EB-1

0:28

PARTICULATE DATA SHEET


 Date 12/1/84 Test No. 84EB-1 Plant Lake Charles Mercury Circuit - End Box Stack

Impinger #1	<u>757.2</u> g	Impinger #2	<u>980.7</u> g	Impinger #3	<u>555.5</u> g
	<u>636.2</u> g		<u>607.2</u> g		<u>631.2</u> g
	<u>121.0</u> g		<u>-26.5</u> g		<u>-75.7</u> g

 Silica gel 759.9 g Total H₂O 34.1 g
 No. 744.6 g
15.3 g

 100ml 0.1M ICI in Impinger 1, 2, 3
 Filter No. _____ Bottle No. _____ Blank No. _____ Bottle No. _____

			Date	Time	Rel. Hum.	Analyst
Gross filter wt.	_____ mg	Gross blk wt.	_____ mg	_____	_____	_____
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg	<u>12/1/84 1200</u>	_____	<u>J. G. Gole</u>
Tare wt.	_____ mg	Tare wt.	_____ mg	<u>12/1/84 1000</u>	_____	<u>J. G. Gole</u>
Particulate wt.	_____ mg	Blank wt.	_____ mg	_____	_____	_____

 Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate on filter _____ mg

Acetone Wash Beaker No. _____ Mls used _____ Blank Beaker No. _____ Mls used _____

			Date	Time	Rel. Hum.	Analyst
Gross wash wt.	_____ mg	Gross blk wt.	_____ mg	_____	_____	_____
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg	_____	_____	_____
Tare wt.	_____ mg	Tare wt.	_____ mg	_____	_____	_____
Particulate wt.	_____ mg	Blank wt.	_____ mg	_____	_____	_____

 Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate in wash _____ mg

 Total particulate on filter _____ mg
 Total particulate in acetone wash _____ mg
 Total particulate _____ mg
 Total H₂O _____ ml

REMARKS:

Sample plus washings → 12 for Hg analysis

SL 025721

84EB-2

D:29
FIELD SAMPLING DATA

R 27.79 @ 12:06



PLANT & LOCATION

Lake Charles Plant A

ASSUMED: % H₂O 2.0 ; T_g °F 63

Pn, in. WG 30.00

DATE:

12/12/84

TEST NO.:

84EB-2

LEAK CHECKS

EQUIP.: MFG.

Anderson

METER BOX NO.

B-4

INITIAL

3

FINAL

Y_D 0.9698 Δ H_g:

2.00

SAMP. BOX NO.

B-4

TRAIN: 15" .001"

10" OK L.C.

OPERATOR

MAH/LAK

PITOT: IMP.

8.6" OK

7.4 OK

PITOT: NO.

16

TYPE

S

Cp 0.84

WAKE 7.5" OK

6.3 OK

NOZZLE: NO.

1

ID, in.

0.189 Ft² 1.948 E-04

FIELD METER CHECK

STACK: DIMENSIONS

12"

AREA 0.7854 Ft²

K r Δ P REF.:

1.57

C FACTOR

Plant

Test No.

One Lane only N-S 8 ft
Date 15 min / ft @ 120.

Comments	Clock Time	Dry Gas Meter, CF	Pitot Δ P in. H ₂ O	Δ P	Orifice Δ H in H ₂ O	Dry Gas Temp., °F	Pump Vacuum in. Hg Gauge	Orifice Meter Temp., °F	Impinger Temp., °F	Stack Press. in H ₂ O	Stack Temp., °F
1330	0	502.118	1.20		1.85	99 82	6.0	238	48	-0.41	66
	5	505.995	1.25		1.90	100 83	6.2	240	47		
1	10	509.200	1.25		1.90	100 84	6.2	245	48		
	15	513.520	1.25		1.90	116 86	6.5	248	47	-0.45	66
	20	517.445	1.25		1.90	118 88	6.2	249	47		
2	25	521.400	1.25		1.90	118 90	6.2	250	47		
	30	525.160	1.20		1.85	121 92	6.2	251	45	-0.43	65
	35	528.985	1.08		1.70	120 94	6.0	254	46		
3	40	531.960	1.05		1.60	120 94	6.0	254	47		
	45	536.290	1.15		1.75	121 95	6.0	256	46	-0.40	65
	50	540.010	1.15		1.75	123 97	6.1	256	46		
4	55	543.800	1.15		1.75	123 98	6.1	258	47		
	60	547.603	1.05		1.61	123 98	5.8	258	47	-0.37	65
	65	551.283	1.05		1.61	122 99	5.8	255	48		
5	70	554.830	1.05		1.61	122 99	5.8	254	47		
	75	558.435	0.94		1.44	121 99	5.3	253	45	-0.38	65
	80	561.833	0.93		1.43	121 98	5.3	250	46		
6	85	565.220	0.93		1.43	121 98	5.3	250	45		
	90	568.608	0.79		1.21	117 98	5.0	251	45	-0.92	65
	95	571.764	0.79		1.21	118 98	5.0	251	46		
7	100	574.888	0.80		1.22	118 98	5.0	251	46		

SL 025722

Planck**Test No.****Note**

15:30⁸

dditi nel Comments:

SL 025723

$\bar{x} T_s = \underline{65} \text{ } ^\circ\text{F}$
 $\bar{x} T_s = \underline{525} \text{ } ^\circ\text{R}$

84EB-2

D:31

PARTICULATE DATA SHEET



INDUSTRIES

Date 12/12/84 Test No. 84EB-2 Plant Lake Charles Mercury
Crumb

Impinger #1 636.4 g 628.2 g 8.2 g
Impinger #2 651.4 g 642.0 g 9.4 g
Impinger #3 602.1 g 600.8 g 1.3 g

Silica gel 763.6 g
No. 750.4 g
13.2 g
Total H₂O 32.1

1, 2, 3 0.1 M TCI 100 ml

Filter No. _____ Bottle No. _____ Blank No. _____ Bottle No. _____

Date Time Rel. Hum. Analyst

Gross filter wt. _____ mg Gross blk wt. _____ mg
Avg. gr ss wt. _____ mg Avg. gross wt. _____ mg
Tare wt. _____ mg Tare wt. _____ mg
Particulate wt. _____ mg Blank wt. _____ mg
Date 12/12/84 Time 1600 Rel. Hum. _____ Analyst T. J. Gyle
Date 12/12/84 Time 1210 Rel. Hum. _____ Analyst T. J. Gyle

Particulate wt. _____ mg
Blank wt. _____ mg
Weight of particulate on filter _____ mg

Acetone Wash Beaker No. _____ Mls used _____ Blank Beaker No. _____ Mls used _____

Date Time Rel. Hum. Analyst

Gr ss wash wt. _____ mg Gross blk wt. _____ mg
Avg. gr ss wt. _____ mg Avg. gross wt. _____ mg
Tare wt. _____ mg Tare wt. _____ mg
Particulate wt. _____ mg Blank wt. _____ mg
Date _____ Time _____ Rel. Hum. _____ Analyst _____

Particulate wt. _____ mg
Blank wt. _____ mg
Weight of particulate in wash _____ mg

Total particulate on filter _____ mg
Total particulate in acetone wash _____ mg
Total particulate _____ mg
Total H₂O 32.1 ml

REMARKS:

Sample for washings → 1 l for analysis

SL 025724

0:32



ORSAT ANALYSIS

Test No. 84 EB-2 Date 12-12-84

Sample Location End Box Scrubber Stack Analyzed by W. Hebert

Sample Type Grab

Volume (30 L minimum) _____

Time (4 hrs. max. after sampling) _____

Orsat Leak Checks(Mandatory)

Before OK

After _____

<u>Orsat Test No.</u>	<u>CO₂</u>	+	<u>O₂</u>	<u>O₂</u>	<u>CO</u>	<u>N₂</u>
1	<u>0</u>		<u>20.9</u>	<u>20.9</u>	<u>0</u>	<u>79.1</u>
2	<u>0</u>		<u>20.9</u>	<u>20.9</u>	<u>0</u>	<u>79.1</u>
3	_____		_____	_____	_____	_____
4	_____		_____	_____	_____	_____
5	_____		_____	_____	_____	_____
6	_____		_____	_____	_____	_____
AVE.	_____		_____	_____	_____	_____

M. Hagan
Ambient air 20.9% O₂

SL 025725

84EB-3

0:33
FIELD SAMPLING DATA



PLANT & LOCATION: Lake Charles Plant A
End Box Stack (Murray Circuit)

ASSUMED: X_{H_2O} 2; T_g , °F 65

Pm, in. WG 29.75

DATE: 12/3/84 TEST NO.: 84EB-3

LEAK CHECKS

EQUIP.: MFG. Anderson METER BOX NO. B-4

INITIAL 3 FINAL

Y_D 0.9698 ΔH_g : 200 SAMP. BOX NO. B-4

TRAIN: 18" oc 13" OK

OPERATOR MH/MC

PITOT: IMP. 5.3 oc 7.3 OK

PITOB: NO. 16 TYPE S C_p 0.84

WAKE 8.6 oc 47 OK

NOZZLE: NO. 1 ID, in. 0.189 Ft^2 1.948 E-04

FIELD METER CHECK

STACK: DIMENSIONS 12", AREA 0.7854 Ft^2

K or A P REF.: 2.57 C FACTOR

Plant

Test No.

Date One June only U-5 8 PT
15 min / RT 2 = 120 min

08:10

Comments

Clock Time	Dry Gas Meter, CF	Pitot A P in. H ₂ O	$\sqrt{A/P}$	Orifice A B in H ₂ O	Dry Gas Temp., °F (1) App. Out	Pump Vacuum in. Hg Gauge	Open Jibber Temp. °F	Impinger Temp. °F	Stack Press. in H ₂ O	Stack Temp. °F
0	600.788	1.15	1.072	1.75	86 72	7.5	245	55	-0.5	62
5	604.335	1.15	1.072	1.75	101 70	8.0	216	49		
10	607.750	1.20	1.095	1.85	110 76	8	225	47		
15	611.620	1.20	1.095	1.85	111 79	8.0	229	46	-0.45	63
20	615.350	1.20	1.095	1.85	112 80	8.0	233	46		
25	619.075	1.20	1.095	1.85	114 82	8.0	234	45		
30	622.160	1.20	1.095	1.85	115 85	8.0	247	44	-0.42	64
35	626.440	1.20	1.095	1.85	115 85	7.5	250	43		
40	630.210	1.20	1.095	1.85	115 85	7.8	250	43		
45	634.200	1.05	1.024	1.62	112 87	6.0	250	43	-0.44	64
50	638.200	1.05	1.024	1.62	116 87	7.0	253	41		
55	640.650	0.87	0.933	1.45	118 80	7.0	255	41		
60	644.310	1.0	1.000	1.54	120 88	7.0	258	42	-0.40	64
65	647.981	1.03	1.015	1.60	122 89	7.0	258	42		
70	651.270	1.00	1.000	1.54	122 89	7.0	259	42		
75	654.750	0.91	0.954	1.40	122 90	6.2	259	41	-0.44	65
80	658.120	0.91	0.954	1.40	121 90	6.2	260	41		
85	661.500	0.92	0.959	1.42	121 91	6.2	261	41		
90	664.810	0.76	0.863	1.19	119 92	5.2	261	42	-0.43	64
95	668.200	0.77	0.863	1.19	115 93	5.2	262	43		
100	670.770	0.75	0.866	1.18	113 91	5.5	262	44		

SL 025726

Plant

Test No. 84 EB-3 Date 12/13/84

10:10

SL 025727

84 EB-3

D:35



PARTICULATE DATA SHEET

Date 12/1/84Test No. 84 EB-3Plant Lake Charles Marine
Cell Circuit, End BoxImpinger 637.4 g
#1 628.1 g
9.3 gImpinger 647.6 g
#2 641.3 g
6.3 gImpinger 602.2 g
#3 601.4 g
0.9 gSilica gel 754.9 g
N. 741.5 g
13.4 gTotal H₂O 29.9

Filter No. _____ Bottle No. _____ Blank No. _____ Bottle No. _____

			Date	Time	Rel. Hum.	Analyst
Gross filter wt.	_____ mg	Gross blk wt.	_____ mg			
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg	<u>12/13/84</u>		<u>J. H. H.</u>
Tare wt.	_____ mg	Tare wt.	_____ mg	<u>12/12/84</u>	<u>1600</u>	<u>J. H. H.</u>
Particulate wt.	_____ mg	Blank wt.	_____ mg			

Particulate wt. _____ mg
Blank wt. _____ mg
Weight of particulate on filter _____ mg

Acetone Wash Beaker No. _____ Mls used _____ Blank Beaker No. _____ Mls used _____

			Date	Time	Rel. Hum.	Analyst
Gross wash wt.	_____ mg	Gross blk wt.	_____ mg			
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg			
Tare wt.	_____ mg	Tare wt.	_____ mg			
Particulate wt.	_____ mg	Blank wt.	_____ mg			

Particulate wt. _____ mg
Blank wt. _____ mg
Weight of particulate in wash _____ mg

Total particulate on filter _____ mg
Total particulate in acetone wash _____ mg
Total particulate 29.9 mg
Total H₂O _____ ml

REMARKS:

O₂ 20.9 @ 0820

Ambient 20.9 @ 0820

mw 01.6 x 18 = 0.288O₂ = 20.9 (.984) x 32 = 6.58N₂ = 79.1 (.964) x 28 = 21.794

28.662

SL 025728

D:36



ORSAT ANALYSIS

Test No. 04-EB-3 Date 12-13-84

Sample Location END Box Scrubber Stack Analyzed by M. Hogan

Sample Type Integrated Bag

Volume (30 L minimum) _____

Time (4 hrs. max. after sampling) _____

Orsat Leak Checks (Mandatory)

Before OK

After OK

<u>Orsat</u> <u>Test No.</u>		<u>CO₂</u>	+	<u>O₂</u>	<u>O₂</u>	<u>CO</u>	<u>N₂</u>
0820	1	<u>—</u>		<u>20.9</u>	<u>20.9</u>	<u>—</u>	<u>79.1</u>
	2	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
	3	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
	4	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
	5	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
	6	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
	AVE.	<u>—</u>		<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>

Ambient Air 20.9 @ 0830

M. Hogan

SL 025729

D:37

PARTICULATE EMISSIONS SAMPLING REPORT

PLANT-NAME AND ADDRESS

TEST TEAM LEADER

LAKE CHARLES

KURTLA

TEST 1 84ER-1

TEST 2 84ER-2

TEST 3 84ER-3

RUN NUMBER

1

2

3

TEST DATE

12/12/84

12/12/84

12/13/84

TR	TIME-START	903	1330	810
TF	TIME-FINISH	1103	1530	1010
TT	NET TIME OF TEST, MIN.	120.0	120.0	120.0
FNP	NET SAMPLING POINTS	8.	8.	8.
DN	SAMPLING NOZZLE DIA., IN.	0.189	0.189	0.189
CP	PITOT TUBE COEFFICIENT	0.84	0.84	0.84
PM	AVERAGE ORIFICE PRESSURE	1.60	1.59	1.54
	DROP, IN. H2O			
VH	VOLUME OF DRY GAS SAMPLED	82.353	82.771	79.364
	CU. FT. AT METER CONDITIONS			
TM	AVERAGE GAS METER TEMP	102.5	106.0	100.0
	DEGREES F			
VHST	VOLUME OF DRY GAS SAMPLED	77.399	77.180	74.562
	AT STANDARD CONDITIONS, SCF			
VW	TOTAL H2O COLLECTED IN	34.10	32.10	29.90
	IMPINGERS & SILICA GEL, ML.			
VWV	VOLUME OF WATER VAPOR	1.605	1.511	1.407
	AT STANDARD CONDITIONS, SCF			
PHV	PERCENT MOISTURE BY VOL.	2.0	1.9	1.9
FND	MOLE FRACTION DRY GAS	0.980	0.981	0.981
PCO2	PERCENT CO2 BY VOL., DRY	0.0	0.0	0.0
PO2	PERCENT O2 BY VOL., DRY	20.80	20.90	20.90
PCO	PERCENT CO BY VOL., DRY	0.0	0.0	0.0
PN2	PERCENT N2 BY VOL., DRY	79.20	79.10	79.10
FMW	MOLECULAR WT-DRY STK GAS	28.83	28.84	28.84
FNV	MOLECULAR WT-STK GAS	28.61	28.63	28.64
PR	BAROMETRIC PRESSURE, IN. HG.	29.84	29.79	29.70
PSI	STATIC PRES OF STK GAS IN. HG	-0.46	-0.39	-0.44
	IN. H2O			
PS	STACK PRES, ABS. IN. HG.	29.806	29.761	29.668
TS	AVERAGE STACK TEMP, DEG. F	65.0	65.0	64.0
BPS	SD OF AVE OF SD RTS OF DELTA P S	1.0420	1.0360	0.9950
	STACK GAS, IN. H2O			
VS	AVE STK GAS VELOCITY, FPS	57.52	57.38	56.26
AS	STACK AREA, FT. SQRD	0.8	0.8	0.8
DS	STK FLOW RATE, DRY, DSCFH	2660.	2653.	2600.
DA	ACTUAL STK FLOW RATE, ACFH	2710.	2704.	2651.
PERI	PERCENT ISOKINETIC	97.8	97.8	96.4

SL 025730

SL 025731

84 PV-1

D:39
FIELD SAMPLING DATA

KB 2969

PLANT & LOCATION: Lake CharlesASSUMED: % H₂O _____; T_a °F _____

Pm, in. WG _____

DATE: 12/13/84 TEST NO.: 84 PV-1

LEAK CHECKS

EQUIP.: MFG. RAC METER BOX NO. B-3INITIAL h FINAL _____Y_D 0.9801 Δ H_g: N/A SAMP. BOX NO. B-2TRAIN: 001015" 00207"OPERATOR LAK/WHPITOT: IMP. XPITOB: NO. N/A TYPE _____ Cp _____

WAKE _____

NOZZLE: NO. _____ ID, in. _____ Ft² _____

FIELD METER CHECK

STACK: DIMENSIONS _____, AREA _____ Ft² _____

K or Δ P REF.: _____ C FACTOR _____

Plant _____

Test No. _____

Date _____

05:54 Comments	Clock Time	Dry Gas Meter, CF	Pitot Δ P in. H ₂ O	√Δ P	Orifice Δ H in H ₂ O	Dry Gas Temp., °F Avg	Pump Vacuum In. Hg Gauge	Filter Temp. °F	Impin- ger Temp. °F	Stack Press. in H ₂ O	Stack Temp. °F
East Bed sampling system urged to start of at	0	029.212			0.15	70 70	3				
	10	034.330			0.10	74 72	3				
	20	040.050			0.09	78 74	3				
	30	045.780			0.09	79 76	3				
	40	051.530			0.09	80 77	3				
	50	57.258			0.09	86 78	3				
	60	062.950			0.09	80 78	3				
	70	68.680			0.09	78 78	3				
	80	74.385			0.09	80 79	3				
	90	80.100			0.09	79 78	3				
	100	85.810			0.09	79 79	3				
	110	91.510			0.09	78 78	3				
of 07:54	120	97.198				77°F/537R					
	$V_m = 67.986 \times 0.9801 = 66.663$										
	$V_{ms} = (17.647)(66.663)\left(\frac{129.20}{537}\right) = 65.064 \text{ cu ft}$										
SL 025732	$H_2O = 0.04707 \times 17.7 = 0.833 \text{ cu ft}$										
	$\%H_2O = \frac{0.833}{65.064} \times 100 = 1.26 \text{ (MFC 0.982)}$										

SL 025732

65.897 total

FIELD DATA

D:40

Plant

Test No.

Notes

[illegible]

$V_m = \text{_____ Ft}^3$ $x Yd$ $= \text{_____ Ft}^3 (\text{Dry})$	$\bar{x} / \sqrt{\Delta P} = \text{_____}$ $(\bar{x} / \sqrt{\Delta P})^2 = \text{_____}$	$\bar{x} P_m = \text{_____ "WG}$ $\bar{x} P_m = \text{_____ "Hg}$ $P_m \text{ abs.} = \text{_____ "Hg}$	$\bar{x} P_s = \text{_____ "WG}$ $\bar{x} P_s = \text{_____ "Hg}$ $P_s \text{ abs.} = \text{_____ "Hg}$
Additional Comments:			$\bar{x} T_s = \text{_____ } ^\circ F$ $\bar{x} T_s = \text{_____ } ^\circ R$

D:41



PARTICULATE DATA SHEET

Date 12/13/84 Test No. 84 PV-1 Plant Lake Charles, H₂S gas

Impinger #1 563.9 g 560.5 g 3.4 g
 Impinger #2 629.7 g 629.5 g 0.2 g
 Impinger #3 560.5 g 560.5 g 0 g

Silica gel 681.1 g
 No. 667.0 g
14.1 g
 Total H₂O 17.7

100 ml 0.1 M ICI in impingers 1, 2, 3
 Filter N. Bottle No. Blank No. Bottle No.

			Date	Time	Rel. Hum.	Analyst
Gross filter wt.	mg	Gross blk wt.	mg	<u>12/13/84</u>	<u>0811</u>	<u>Wayne Niles</u>
	mg		mg			
Avg. gross wt.	mg	Avg. gross wt.	mg			
Tare wt.	mg	Tare wt.	mg	<u>12/11/84</u>	<u>1100</u>	<u>J. G. G.</u>
Particulate wt.	mg	Blank wt.	mg			

Particulate wt. mg
 Blank wt. mg
 Weight of particulate on filter mg

Acetone Wash Beaker No. Mls used Blank Beaker No. Mls used

			Date	Time	Rel. Hum.	Analyst
Gross wash wt.	mg	Gross blk wt.	mg			
	mg		mg			
Avg. gross wt.	mg	Avg. gross wt.	mg			
Tare wt.	mg	Tare wt.	mg			
Particulate wt.	mg	Blank wt.	mg			

Particulate wt. mg
 Blank wt. mg
 Weight of particulate in wash mg

Total particulate on filter mg
 Total particulate in acetone wash mg
 Total particulate mg
 Total H₂O ml

REMARKS:

Impingers plus washings → 1 l for analysis

SL 025734

D:42
FIELD SAMPLING DATA



PLANT & LOCATION

ASSUMED: $\% \text{ H}_2\text{O}$ 6; T_a , °F

Pm. In. WG

LEAK CHECKS

EQUIP.: MFG.

METER BOX NO.

INITIAL

FINAL

 $y_D = 0.9801 \Delta H_D$

SAMP. BOX NO.

TRAIN: .002 @ 19" : 001 @ 7"

OPERATOR

PITOT: IMP.

PITOB: NO.

TYPE

Cp

WAKE

NOZZLE: NO.

ID. in.

Ft 2

FIELD METER CHECK

STACK: DIMENSIONS

AREA

 Fe^{2+}

K T Δ P REF.:

C FACTOR

Plant**Test No.**

Date _____

12:53	Clock Time	Dry Gas Meter, CF	Pitot Δ P in. H ₂ O	√Δ P	Orifice Δ H in. H ₂ O	Dry Gas Temp., °F Ave.	Pump Vacuum in. Hg Gauge	Filter Temp. °F	Impinger Temp. °F	Stack Press. in. H ₂ O	Stack Temp. °F
Bad min. sample in purge	0	974.58			0.10	71 72	3				
	10	102.948			0.09	76 74	3				
	20	108.599			0.07	80 77	3				
	30	114.245			0.07	82 79	3				
	40	119.826			0.07	82 80	3				
	50	125.455			0.07	83 81	3				
	60	131.075			0.07	83 82	3				
	70	136.694			0.07	83 82	3				
	80	142.330			0.07	84 83	3				
	90	147.952			0.07	84 83	3				
	100	153.585			0.07	84 83	3				
	110	159.212			0.07	84 83	3				
14:53	120	164.868			X 80.6 °F / 540.6 PR						
$V_m = 67.410 \times 0.9701 = 66.069$											SL 025735
$V_{m,s} = (17.647)(66.069)\left(\frac{29.71}{540.6}\right) = 64.076$											
$H_2O = 0.04707 \times 20.0 = 0.970$											
$H_2O = \frac{0.970}{100} \times 100$											

FIELD DATA

D:43

Planck

Test No.

Notes

[illegible]

$V_m = \text{_____ Ft}^3$ $\times Y_d \text{_____}$ $= \text{_____ Ft}^3 \text{ (Dry)}$	$\bar{x} / \Delta P = \text{_____}$ $(\bar{x} / \Delta P)^2 = \text{_____}$	$\bar{x} P_m = \text{_____ "WG}$ $\bar{x} P_m = \text{_____ "Hg}$ $P_m \text{ abs.} = \text{_____ "Hg}$	$\bar{x} P_s = \text{_____ "WG}$ $\bar{x} P_s = \text{_____ "Hg}$ $P_s \text{ abs.} = \text{_____ "Hg}$
Additional Comments: SL 025736		$\bar{x} T_s = \text{_____ } ^\circ F$ $\bar{x} T_s = \text{_____ } ^\circ R$	

SL 025736

84 PV-2

D:44

PARTICULATE DATA SHEET



Date 12/13/84 Test No. 84PV-2 Plant Lake Charles H₂ System

Impinger #1 <u>567.3</u> g	Impinger #2 <u>631.0</u> g	Impinger #3 <u>561.5</u> g
<u>561.3</u> g	<u>630.4</u> g	<u>560.9</u> g
<u>6.0</u> g	<u>0.6</u> g	<u>0.6</u> g

Silica g 1 694.5 g Total H₂O 20.6
 No. 691.1 g
13.4 g

100 ml 0.1M ICI in impingers 1,2,3
 Filter No. _____ Bottle No. _____ Blank No. _____

Gross filter wt.	mg	Gross blk wt.	mg	Date	Time	Rel. Hum.	Analyst
_____	_____	_____	_____	<u>12/13/84</u>	<u>1510</u>	_____	_____
Avg. gross wt.	mg	Avg. gross wt.	mg	_____	_____	_____	_____
Tare wt.	mg	Tare wt.	mg	<u>12/1/84</u>	_____	_____	<u>Wayne Nelson</u>
Particulate wt.	mg	Blank wt.	mg	_____	_____	_____	_____

Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate on filter _____ mg

Acetone Wash Beaker No. _____ Mls used _____ Blank Beaker No. _____ Mls used _____

Gross wash wt.	mg	Gross blk wt.	mg	Date	Time	Rel. Hum.	Analyst
_____	_____	_____	_____	_____	_____	_____	_____
Avg. gross wt.	mg	Avg. gross wt.	mg	_____	_____	_____	_____
Tare wt.	mg	Tare wt.	mg	_____	_____	_____	_____
Particulate wt.	mg	Blank wt.	mg	_____	_____	_____	_____

Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate in wash _____ mg

Total particulate on filter _____ mg
 Total particulate in acetone wash _____ mg
 Total particulate _____ mg
 Total H₂O _____ ml

REMARKS:

Impingers plus washings → 1 l for analysis

84 PV-3

D:45
FIELD SAMPLING DATA

B 29.79
INDUSTRIES

PLANT & LOCATION: Lake Charles

ASSUMED: % H₂O _____; T_g, °F _____

Hydogen System

P_m, in. WG _____

DATE: 12/13/84 TEST NO.: 84 PV-3

LEAK CHECKS

EQUIP.: MFG. LAC METER BOX NO. B-3

INITIAL 4 FINAL _____

ID₀ 9801 Δ H_g: N/A SAMP. BOX NO. B-1

TRAIN: 002 @ 2.0"

OPERATOR LAK / W. Hebert / TC

PITOT: train H_g: 001 @ 6" Final

PITOB: NO. _____ TYPE _____ Cp _____

WAKE _____

NOZZLE: NO. _____ ID, in. _____ Ft² _____

FIELD METER CHECK

STACK: DIMENSIONS _____, AREA _____ Ft² _____

K or Δ P REF.: _____ C FACTOR _____

Plant _____ Test No. _____ Date _____

Comments	Clock Time	Dry Gas Meter, CF	Orifice P ₁ , in. H ₂ O	Δ P	Orifice P ₂ , in. H ₂ O	Dry Gas Temp., °F Ave.	Pump Vacuum In. Hg Gauge	Filter Temp. °F	Impinger Temp. °F	Stack Press. in H ₂ O	Stack Temp. °F
19:53 East End 15 min Sample Line Purge	0	165.063	0.1			70 71	2				
	10	171.378	0.09			71 73	2				
	20	177.720	0.09			78 76	2				
	30	184.015	0.09			80 77	2				
	40	190.320	0.08			81 79	2				
	50	196.615	0.09			82 80	2				
	60	202.910	0.09			83 80	2				
	70	209.245	0.09			83 81	2				
	80	215.500	0.09			83 81	2				
	90	221.814	0.09			83 81	2				
	100	228.108	0.09			83 82	2				
	110	234.420	0.09			84 82	2				
21:53	120	240.736				79.5°F	539.5°R				
$V_{na} = 75.673 \times 0.9201 = 74.167$											
$V_{ms} = (17.647)(74.167)(\frac{29.50}{329.5}) = 72.295$											
$H_2O = 0.04707 \times 22.6 = 1.064$											
$\%H_2O = \frac{1.064}{(72.295 + 1.064)} \times 100 = 1.45$ (MFCG 0.985)											

Plant

Test No.

Notes

$V_m = \text{_____ Ft}^3$	$\bar{x}/\sqrt{\Delta P} = \text{_____}$	$\bar{x} P_m = \text{_____ "WG}$	$\bar{x} P_s = \text{_____ "WG}$
$x Y_d \text{_____}$	$(\bar{x}/\sqrt{\Delta P})^2 = \text{_____}$	$\bar{x} P_m = \text{_____ "Hg}$	$\bar{x} P_s = \text{_____ "Hg}$
$= \text{_____ Ft}^2 \text{ (Dry)}$		$P_m \text{ abs.} = \text{_____ "Hg}$	$P_s \text{ abs.} = \text{_____ "Hg}$

SL 025739

$\sum T_n =$ _____

$$\bar{x} \text{ Ts} = \text{---} \cdot R$$

84 PV-3

D:47



PARTICULATE DATA SHEET

Date 12/13/84 Test No. 84 PV-3 Plant Lake Charles
H₂ System

Impinger #1	<u>568.4</u> g <u>560.8</u> g <u>7.6</u> g	Impinger #2	<u>629.5</u> g <u>629.6</u> g <u>-0.1</u> g	Impinger #3	<u>560.6</u> g <u>560.4</u> g <u>0.2</u> g
-------------	--	-------------	---	-------------	--

Silica gel 683.9 g
 No. 669.0 g
14.9 g

Total H₂O 22.6

Filter No. _____ Bottle No. _____ Blank No. _____ Bottle No. _____

			Date	Time	Rel. Hum.	Analyst
Gross filter wt.	_____ mg	Gross blk wt.	_____ mg	<u>12/13/84</u>	<u>10:20</u>	<u>T. Lyle</u>
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg			
Tare wt.	_____ mg	Tare wt.	_____ mg	<u>12/13/84</u>	<u>1530</u>	<u>T. Lyle</u>
Particulate wt.	_____ mg	Blank wt.	_____ mg			

Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate on filter _____ mg

Acetone Wash Beaker No. _____ Mls used _____ Blank Beaker No. _____ Mls used _____

			Date	Time	Rel. Hum.	Analyst
Gross wash wt.	_____ mg	Gross blk wt.	_____ mg			
Avg. gross wt.	_____ mg	Avg. gross wt.	_____ mg			
Tare wt.	_____ mg	Tare wt.	_____ mg			
Particulate wt.	_____ mg	Blank wt.	_____ mg			

Particulate wt. _____ mg
 Blank wt. _____ mg
 Weight of particulate in wash _____ mg

Total particulate on filter _____ mg
 Total particulate in acetone wash _____ mg
 Total particulate _____ mg
 Total H₂O _____ ml

REMARKS:

Sample plus washings → 1 l for analysis

SL 025740

APPENDIX E

**Analytical QA and Results,
Emission Calculations and Chain of Custody**

SL 025741

E:49

CHEMICALS



INTEROFFICE / LAKE CHARLES

TO L. A. Kuryla

DATE Dec. 20, 1984

FROM M. G. Carver

SUBJECT Hg Analyses

MC.

Attached are the results from the analyses of the samples obtained while stack sampling the Mercury Cell End Box (EB) Stack and the Purasieve (PURA) Unit.

Also included is the calibration curve data and spiked recovery analyses.

If you have any questions concerning these data, please call.

ce

Attachments

cc: M. W. Wood
W. H. Cooper
H. J. Hoanes
K. S. Komoroski

SL 025742

MERCURY ANALYSES DATA FROM
DECEMBER 12 & 13

E:50

=====

STANDARDIZATION

SPIKED RECOVERY
DATA

Hg (actual) (ug)	Hg (analyzed) (ug)	Sample	Hg spiked (ug)	Hg rec. (ug)	% rec
1.0	0.89	PURA-2	0.88	0.88	100
0.80	0.68				
0.60	0.55	EB-2	1.02	0.97	95.1
0.40	0.38				
0.20	0.18	BLANK	0.00	0.00	--
0.00	0.00				

=====


SAMPLE ANALYSES DATA

RUN ID	Hg (ug)
PURA-1	< 125
PURA-2	< 125
PURA-3	1450
EB-1	525
EB-2	1450
EB-3	525

SL 025743

E:51
ACTUAL -VS- INSTRUMENT RDING

Coleman model 60



SL 025744

E:52

BARBERTON TECHNICAL CENTER

End Box

Barberton, Ohio

2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

Mercury Emission Rate Calculations
(Eq. 101A-1, 40 CFR 61, App B)

84 EB-1

$$R = \frac{(17.647)(52.5\mu)(57.5)(0.7854)(86,400^{E-06})}{[77.379 + 1.605] \left(\frac{52.5}{29.81} \right)} = \underline{25.98g/day}$$

84 EB-2

$$R = \frac{(17.647)(1450\mu)(57.4)(0.7854)(86,400^{E-06})}{[77.180 + 1.511] \left(\frac{52.5}{29.76} \right)} = \underline{71.80g/day}$$

84 EB-3

$$R = \frac{(17.647)(52.5)(56.3)(0.7854)(86,400^{E-06})}{[74.562 + 1.407] \left(\frac{52.5}{29.67} \right)} = \underline{26.38g/day}$$

$\bar{X}R = 41.7g/day$

SL 025745

Hydrogen System (Purifier)

E:53

BARBERTON TECHNICAL CENTER

Barberton, Ohio

2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

Mercury Emissions Rate Calculations

84 PV-1, East, 05:54-07:54, 12/13/84

$$H_2 \text{ flow rate @ } 70^\circ F = 6.079^{E06} \times \frac{528}{530} = 6.056^{E06} \text{ SCF}_d/\text{day}$$

$$Hg \text{ conc. } \frac{< 1.25^{E-04} \text{ g}}{65.897 \text{ scf}} = \leq 1.897^{E-06} \text{ g/scf}$$

$$R = \leq 1.897^{E-06} \times 6.056^{E06} = \underline{\underline{11.49 \text{ g/Day}}}$$

84 PV-2, East, 12:53-14:53, 12/13/84

$$H_2 \text{ flow rate @ } 70^\circ F = 6.915^{E06} \times \frac{528}{530} = 6.889^{E06} \text{ SCF}_d/\text{day}$$

$$Hg \text{ conc. } \frac{< 1.25^{E-04} \text{ g}}{65.046 \text{ scf}} = \leq 1.922^{E-06} \text{ g/scf}$$

$$R = \leq 1.922^{E-06} \times 6.889^{E06} = \underline{\underline{13.24 \text{ g/Day}}}$$

84 PV-3, East, 19:53-21:53, 12/13/84

$$H_2 \text{ flow rate @ } 70^\circ F = 7.119^{E06} \times \frac{528}{530} = 7.092^{E06} \text{ SCF}_d/\text{day}$$

$$Hg \text{ conc. } \frac{1.45^{E-03} \text{ g}}{73.359 \text{ scf}} = 1.977^{E-05} \text{ g/scf}$$

$$R = 1.977^{E-05} \times 7.092^{E06} = \underline{\underline{140.18 \text{ g/Day}}}$$

CHAIN OF CUSTODY RECORD

OJ. NO.		PROJECT NAME		NO. OF CONTAINERS		REMARKS	
COLLECTORS: (Signature)							
NO.	DATE	TIME	COMP.	GRAB	STATION LOCATION		
	12/12/84	12:30	✓		End Box stack	1	Sample 84 EB-1
	12/12/84	16:44	✓		" " "	1	Sample 84 EB-2
	12/13/84	08:11	✓		H ₂ System	1	Sample 84 PV-1
	12/13/84	10:45	-		End Box Stack	1	Sample 84 EB-3
	12/13/84	15:10	✓		H ₂ System	1	Sample 84 PV-2
	12/13/84	22:20	✓		H ₂ System	1	Sample 84 PV-3
<i>All Samples for Hg analysis - Blank will be prepared by W. Helbert</i>							
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Date / Time	
W. C. Kuyke		12/13/84 22:20		Wayne P. Helbert			
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Date / Time	
Relinquished by: (Signature)		Date / Time		Received for Laboratory by: (Signature)		Date / Time	
						Remarks	

SL 025747

E:54

APPENDIX F
Sampling QA

SL 025748

CALIBRATIONS & QUALITY ASSURANCEGENERAL

All measuring equipment PPG uses is initially calibrated before use. Equipment which can change calibration is both checked upon return from each field use and is also periodically recalibrated in full. When an instrument is found out of calibration, it is so noted in the report and appropriate adjustments are made to the final results. The equipment is then repaired and recalibrated or retired as needed. Specific equipment is handled as follows:

PITOT TUBE

All pitot tubes used by PPG, whether separate or attached to a sampling probe, are calibrated using EPA geometry standards. In general, if a type "S" pitot tube is assembled correctly, and positioned properly in relation to the probe nozzle, it will have an average C_p of 0.84. As long as it is not damaged, it should not change its calibration. The recalibration schedule for pitot tubes is related to the physical condition and usage of the pitot tube, not a fixed time schedule. Pitot tubes are calibrated before each field use.

DRY GAS METER AND ORIFICE METER

All PPG meter boxes are calibrated upon purchase and at least once every six months against a secondary test meter (one calibrated against a wet test meter) according to their usage history. Basic procedures are outlined in the EPA Publication No. APTD-0576. The only differences are in the choice of flow rates used and the volumes metered at each flow rate. After each field use, check checks are performed to insure all changes of less than 2%. These checks compare the orifice against the dry gas meter. If greater than 2% changes occur, recalibration and repair are instituted. EPA and PPG Method 5 audit orifices are also used in the field or at the laboratory.

NOZZLES

Each nozzle is calibrated upon purchase, and thereafter whenever it becomes apparent that the nozzle has become damaged. Each nozzle is inspected upon return to laboratory from each field use. The diameter is measured on four different axes, with the high and low readings differing by no more than 0.004 inches as a tolerance.

TEMPERATURE MEASURING INSTRUMENTS

After each field use, the thermocouples or thermometers are calibrated against an ASTM precision mercury-in-glass thermometer across a wide range of temperatures. If the initial reading is not within $\pm 1.5\%$ of the absolute temperature reading of the standard thermometer, the instrument is adjusted until it is in the acceptable range.

SL 025749

MAGNEHELIC GAUGES

After each field use, each magnehelic gauge is calibrated against an inclined manometer at three different settings (low, medium, high) over the range of the individual gauges. If the readings differ more than $\pm 5\%$ from the monometer readings, the magnehelics are recalibrated.

BAROMETER

After each field use, each barometer is checked against a mercury barometer.

SOURCE ANALYSIS

PPG Industries, Barberton Technical Center, actively participates in the EPA quality assurance audit program, i.e., Methods 3, 5, 6, & 7.

SL 025750

F:58

INTER-LABORATORY STUDY RESULTS

DATE PRINTED: 12/06/04

(JUNE 1984)

POLLUTANT - SO₂

127009
MR. LYNN A. KOSYLA
PPG INDUSTRIES INC.
P. O. BOX 31
CANTON, OH 44705

UNITS - CUBIC METERS

SITE - OC4 6.4
BRIDGE NUMBER

	REPORTED VALUE	ECO VALUE	PERCENT DIFFERENCE
216	0.2619	0.2619	+2
216	0.2611	0.2616	-1
216	0.2616	0.2616	-1

Note: B-4 not used between audit
and CCH of testing

SL 025751

F:59

INTER-LABORATORY STUDY RESULTS

DATE PRINTED: 12/06/84

JUNE 1984

POLLUTANT - OGN

127009
MR. LYNN A. KURTLE
PPG INDUSTRIES INC.
P. O. BOX 37
BARRINGTON, OH 44203

UNITS - CUBIC METERS

SITE - 003
REFILE NUMBER

(RAC)

B-3

RECORDED VALUE

REC. VALUE

PERCENT DIFFERENCE

214

0.2596

0.2616

-0.7

214

0.2596

0.2616

-0.8

214

0.2596

0.2616

-0.8

Note: B-3 not used between audit
and LCH ify testing

METER BOX IDENTIFICATION: B-3 S/N 1536

Rockwell 10.5 S/N 29043
CALIBRATION METER IDENTIFICATION: Y2.9962
BAROMETRIC PRESSURE (P_b): 28.91 → 28.89

SL 025753

[illegible]

Logk ✓ OK

2/14/83 Jf. Chute

$$\Delta H_g = \frac{0.0217 \Delta H}{P_b (T_g + 460)} \left| \frac{(T_g + 460)^2}{V_{g1} (Y_{H_2})} \right|$$

$$Y_0 = Y_{d1} \cdot \frac{V_{d1}}{V_d} \cdot \frac{(T_d + 460)}{(T_{d1} + 460)} \cdot \frac{P_b}{(P_b + \frac{\Delta H}{13.8})}$$

WHERE: ΔH_0 = ORIFICE PRESSURE DIFFERENTIAL THAT GIVES 0.75 cfm OF AIR AT 70° F AND 29.92 inches OF MERCURY, in. H₂O.
TOLERANCE: ± 0.15

B-4

Ambient 73°F

0.9888

- .118

29.142 " Hg

DATE:

12 Jan 84

Anderson Rockwell 29043
Calibration Meter Identification

METER BOX IDENTIFICATION: Anderson (B-4) S/N 783-184

BAROMETRIC PRESSURE (P_b) 29.142 in. Hg

APPROXIMATE FLOW RATE (Q) cfm	ORIFICE READING (ΔH) in. H ₂ O	CALIBRATION METER GAS VOLUME (V _{d1}) ft ³	METER BOX METER GAS VOLUME (V _{d2}) ft ³	TEMPERATURE						TIME (t) min.	METER BOX METER COEFFICIENT (Y _d)	(ΔH ₀)
				CALIBRATION METER			METER BOX METER					
				INLET (t _{d1}) °F	OUTLET (t _{d2}) °F	AVERAGE (t _d) °R	INLET (t _{d1}) °F	OUTLET (t _{d2}) °F	AVERAGE (t _d) °R			
0.39	0.5	4.007	4.227			53.5			55.2	10.134	0.9680	1.85
0.54	1.0	5.435	5.766			53.5			56.9	10.072	0.9747	1.95
0.64	1.5	6.513	6.942			53.5.5			56.9	10.016	0.9680	2.03
0.74	2.0	7.450	7.967			53.5.5			56.8	10.009	0.9703	2.05
0.82	2.5	8.359	8.966			53.6			56.4	10.033	0.9680	2.05
0.90	3.0	9.165	9.818			53.6			56.3	10.057	0.9696	2.05

$$\Delta H_0 = \frac{0.0319}{P_b (t_d + 460)} \left[\frac{(t_{d1} + 460)(t_d)}{V_{d1}(Y_{d1})} \right]$$

$$Y_d = Y_{d1} \frac{V_{d1} (t_d + 460)}{V_d (t_{d1} + 460)} \frac{P_b}{(P_b + \frac{\Delta H}{13.6})}$$

$$\bar{Y} = 0.9698 \quad \bar{Y} = 2.00$$

$$\sigma = 0.0026 \quad \sigma = 0.012$$

WHERE: ΔH₀ = ORIFICE PRESSURE DIFFERENTIAL THAT GIVES 0.75 cfm OF AIR AT 70°F AND 29.92 inches OF MERCURY, in. H₂O.
TOLERANCE: ± 0.15

Figure 4. Example data sheet for calibration of meter box gas meter against a calibration dry gas meter (English units).

Comments: Anderson's Control unit calibration is attached - however the metering system was found to be leaking upon receipt. These numbers are for the system as received. J. G. Kuryla 1/17/84

SL 025754

Dedicated DGM 5 Point Spirometer

Calibrated by: ANDERSON

Date: 11-83

Meter Box Identification B-4 SN 703-184

Calibration Meter Identification 33-29043

Yds = 0.9000

Calibrated by: M. Hogan

Date: 1-2-85

Barometric Pressure (P_b): 29.31

In Hg

Approximate Flow Rate (Q) cfm	Orifice Reading (ΔH) in H ₂ O	Calibration Meter Gas Volume (V _{ds}) ft ³ (V _d = .9000)	Meter Box Meter Gas Volume (V _d) ft ³	Temperature						Time (t) min.	Meter Box Meter Coefficient V _d	(ΔH)
				Calibration Meter			Meter Box Meter					
				Inlet (t _{dsi}) °F	Outlet (t _{dso}) °F	Average (t _{ds}) °F	Inlet (t _{di}) °F	Outlet (t _{do}) °F	Average (t _d) °F			
	0.5	3.928	4.146	74	76	75	104	82	93	10	0.9734	1.83
	0.5	3.928	4.147	74	76	75	107	86	97	10	0.9740	1.82
	1.0	5.768	5.917	75	77	76	116	94	105	10	0.9703	1.92
	1.0	5.767	5.917	74	77	76	117	96	107	10	0.9703	1.91
	1.5	6.431	7.013	74	77	76	126	99	112	10	0.9748	1.98
	1.5	6.413	7.006	74	77	76	129	100	115	10	0.9703	1.98
	2.0	7.386	8.028	74	77	76	130	102	116	10	0.9748	1.99
	2.0	7.387	8.031	74	77	76	130	102	116	10	0.9775	1.98
	2.5	8.324	8.980	75	77	76	133	90	107	10	0.9810	1.99
	2.5	8.317	8.981	75	77	76	136	95	111	10	0.9793	1.98
	3.0	9.028	9.818	75	77	76	135	99	112	10	0.9730	2.01
	3.0	9.026	9.816	75	77	76	135	100	113	10	0.9727	2.01

SL 025755

SL 025755

F:60

$\bar{X} = 0.9750$ $\bar{X} = 1.95$

$$\Delta H = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left(\frac{t_{ds} + 460}{V_{ds} (Y_{ds})} \right)^2$$

$$Y_d = Y_{ds} \frac{V_{ds}}{V_d} \cdot \frac{(t_d + 460)}{(t_{ds} + 460)} \cdot \frac{P_b}{(P_b + \frac{\Delta H}{13.6})}$$

M. Hogan
1-2-85

WHERE: ΔH = Orifice Pressure Differential that gives 0.75 cfm of air at 70°F and 29.92" of mercury, in H₂O.
Tolerance ±0.15

Dedicated DGM 5 Point Spirometer

Calibrated by: Anderson

Date: 11-83

Meter Box Identification B-3

Calibration Meter Identification 29043

$Y_{ds} = 0.9888$

Calibrated by: M. Hogan

Date: 1-23-85

Barometric Pressure (P_b): 29.31 in Hg

29.39 (1-2-85)

Approximate Flow Rate (Q) cfm	Orifice Reading (ΔH) in H ₂ O	Calibration Meter Gas Volume (V _{ds}) ft ³ Y _d 0.9888	Meter Box Meter Gas Volume (V _d) ft ³	Temperature						Time (t) min.	Meter Box Meter Coefficient Y _d	(AHP)
				Calibration Meter			Meter Box Meter					
				Inlet (t _{dsl}) °F	Outlet (t _{dso}) °F	Average (t _{ds}) °F	Inlet (t _{dl}) °F	Outlet (t _{do}) °F	Average (t _d) °F			
SL 025756	0.5	3.951	4.134	74	76	75	97	99	98	10	0.9867	1.80
	0.5	4.030	4.232	74	77	76	101	91	96	10	0.9841	1.74
	1.0	5.581	5.703	74	77	76	105	94	100	10	0.9853	1.74
	1.0	5.578	5.676	74	77	76	108	96	102	10	0.9827	1.83
	1.5	6.767	7.204	74	77	76	110	98	104	10	0.9845	1.82
	1.5	6.784	7.205	74	77	76	114	100	107	10	0.9926	1.80
	2.0	7.753	8.131	74	77	76	115	101	108	10	0.9905	1.85
	2.0	7.757	8.160	70	73	72	109	94	101	10	0.9974	1.82
	2.5	8.558	8.663	71	74	73	112	98	105	10	1.0407	1.84
	2.5	8.574	9.408	71	74	73	112	98	105	10	0.9560	1.84
	3.0	9.423	9.889	71	74	73	113	98	106	10	1.0103	1.84
	3.0	9.187	9.830	71	74	73	113	98	106	10	0.9868	1.83

$\bar{Y} = 0.9915$ $\bar{Z} = 1.83$

$$\Delta H = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left(\frac{t_{ds} + 460}{Y_{ds}} \right)^2$$

$$Y_d = Y_{ds} \frac{V_{ds}}{V_d} \cdot \frac{(t_d + 460)}{(t_{ds} + 460)} \cdot \frac{P_b}{(P_b + 13.6)}$$

WHERE: ΔH = Orifice Pressure Differential that gives 0.75 cfm of air at 70°F and 29.92" of mercury, in H₂O.
Tolerance ± 0.15

M. Hogan
1-23-85

1-3-85
Power 29.34

PITOT TUBE INSPECTION DATA SHEET


Company Name: PPG Industries

Pre-sample

Post Sample

Date 11/25/84

Date 1-3-85



YES	level?	Yes
NO	obstructions?	No
NO *	damaged?	No
4'	$-10^\circ < \alpha_1 < +10^\circ$	3°
1'	$-10^\circ < \alpha_2 < +10^\circ$	0°
0'	$-5^\circ < \beta_1 < +5^\circ$	0°
2'	$-5^\circ < \beta_2 < +5^\circ$	1°
0'	γ	0°
1'	θ	0°
0.815	A	0.811
0.40	$1.05 D_t < P_a < 1.5 D_t$	0.40
0.42	$1.05 D_t < P_b < 1.5 D_t$	0.411
.375	$3/16" \leq D_t \leq 3/8"$	0.375
0	$A \tan \gamma < 0.125"$	0
0.014	$A \tan \theta < 0.03125"$	0
YES	$P_a = P_b \pm 0.063"$	Yes

Comments: * SLIGHT BURR ON STATIC SIDE OF TUBE OPENING,
FILED TO SMOOTHNESS

Pitot tube/probe number 16 meets or exceeds all specifications criteria and/or applicable design features* and is hereby assigned a pitot tube calibration factor of 0.84.

Signature

Date

*See 40 CFR 60, Vol. 42, No. 160, Method 2. Verify the minimum setback of the thermocouple and the minimum 1/4 inch distance between the pilot tube and the nozzle as shown at the top of this page.