1/28/72 Bill Engman

Paul Hensler

Samples taken at the Waste Treatment Plant by government for PCB on 1/25/72 were

	Influent		Effluent	
	ppb	#/day	ppb	#/day
1/25/72	471	60 #/day	122	16 #/day

for comparison

Jan average to date	92 ppb	11 #/day	107 ppb	13 #/day
Dec. average	107 ppb	12 #/day	47 ppb	5 #/day

Influent sample about 6 times greater than last two months average daily figure.

Effluent sample about 3 times greater than best we have done in past (Dec.)

DSW 296310

WGK Hg on 25th
In 4 ppb
Out 3 ppb

Ed Stewart

STLCOPCB4066254