Anniston, Alabama

April 10, 1968

CEA 1430 AROCLOR EXPANSION
ANNISTON DESIGN QUESTIONS

This Copy For
W. F. Taffee
V. R. Haupt
R. A. Haydel
E. E. Smith

R. W. Peterson
CED
General Offices

In answer to your following questions, we can put 4465 through the 5460 line and Flaker Feed Tank and then to a drumming station, and all other solids also. Steel pipe is ok for the above.

I talked with E. E. Smith and R. A. Haydel and they agreed that separate Hi-Level Alarms are necessary for the eight tanks or a remote pump cut off be supplied for each tank.

J. C. Bradley

JCB:kd

0285252

TOWOLDMON0044199