(d) *Location of Doors.* All doors of combined wash and locker rooms and separate wash and locker rooms for means of ingress and egress shall be provided with automatic closing devices. The doors of wash and locker rooms for males and females shall not be located closer than six (6) feet apart. The doors shall be so located that the interior of the rooms is not visible from the outside through the doors except that partitions may be located and built within at least one (1) foot of the floor and not less than six (6) feet high to screen the interior of the room from beyond the door view.

Doors may be provided with glass that is not transparent.

Wash and locker rooms shall be plainly marked "MEN" or "WOMEN."

If wash and locker rooms are built as separate units or in combination, and adjoin toilet rooms, there shall be a connecting door between the facilities.

Rule 4. Washroom Facilities: Every washroom shall be provided with lavatories and/or shower baths as per the following:

(a) *Lavatories.* Lavatories shall be provided for employees per shift on the following basis:

Number of Employees	*Lavatories*
1 to 15 inclusive	1
16 to 30 inclusive	2
31 to 50 inclusive	3

For each additional 25 employees or fractional part thereof, there shall be provided 1 additional lavatory.

The lavatories may consist of individual units or wash sinks or circular fountains. Where wash sinks or circular fountains are used, twenty-four (24) inches of outside rim of a wash sink and seventeen (17) inches of outside rim of a circular fountain shall be the equivalent of one (1) lavatory.

(b) *Construction of Lavatories.* All lavatories installed in new wash rooms, or any additional lavatories installed in existing wash rooms after the approval of this code by the Industrial Commission shall be constructed as follows:

Lavatories, wash sinks or circular fountains shall be constructed of vitreous china or other impervious material. The surfaces left exposed after installation shall have a glazed, smooth finish.

Individual lavatories may be equipped with a drain plug or stopper. Wash sinks and circular fountains shall not be equipped with a drain plug or stopper.