

of excess air. This will result in less heat, reduced economy; and possibly a complete interruption of service.

The following factors may influence the air supply: (1) changes in combustion draft due to a variety of causes (i.e., changes in chimney draft because of weather changes, seasonal changes, back drafts, failure or inadequacy of automatic draft regulator, use of chimney for other purposes, possible stoppage of the chimney, and changes in draft resistance of boiler due to partial stoppage of the flues); and (2) changes in air inlet adjustments at the fan.

Air leakage into the boiler or furnace setting should be reduced to a minimum. The amount of air leakage will be determined by the draft in the combustion chamber. It is important that this draft should be reduced as low as is consistent with the proper disposal of the gases of combustion. When using mechanical draft burners with average condi-




FIG. 18. TYPICAL OIL-FIRED FURNACE UNIT

tions, the combustion chamber draft should not be allowed to exceed 0.02-0.05 in. water. An automatic draft regulator is necessary in order to maintain constant draft conditions which, in turn, improve efficiency of operation. The draft regulator should be adjusted in accordance with the manufacturer's instructions.

Even though a fan is generally used to supply the air for combustion, in most oil burners, the importance of a proper chimney should not be overlooked. The chimney should have sufficient height and size to insure that the draft will be uniform within the limits given, if maximum efficiency throughout the heating season is to be maintained.

Measurement of the Efficiency of Combustion

Since efficient combustion is based upon a clean flame and definite proportions of oil and air employed, it is possible to determine the results by analyzing the combustion gases. It is usually sufficient to analyze only for carbon dioxide (CO_2) and to obtain the temperature of the stack gas. A showing of 10 to 12 percent indicates the best adjustment, if the flame is clean. Most of the good installations show from 8 to 10 percent

CO_2 . Taking into account the potential hazard of low excess air (high CO_2), a setting to give 10 percent CO_2 constitutes a reasonable standard for most oil burners. *Commercial Standard CS-75* requires that oil burners labeled as complying with the standard shall obtain smoke-free combustion at 10 percent CO_2 . In all cases smokeless combustion is a requirement for oil burners.

Combustion Chamber Design

With burners requiring a refractory combustion chamber, the size and shape should be in accordance with the manufacturer's instructions. It is important that the chamber be as nearly air tight as is possible, except when the particular burner requires a secondary supply of air for combustion.

The atomizing burner is dependent upon the surrounding heated combustion chamber surfaces to vaporize the oil and support combustion. Unsatisfactory combustion may be due to inadequate atomization and mixing. A combustion chamber can only compensate for these things to a limited extent. If liquid fuel continually reaches some part of the fire-brick surface, a carbon deposit will result. The combustion chamber should enclose a space having a shape similar to the flame, but large enough to avoid flame contact. The nearest approach in practice is to have the bottom of the combustion chamber flat, but far enough below the nozzle to avoid flame contact, the sides tapering from the air tube at the same angle as the nozzle spray, and the back wall rounded. A plan view of the combustion chamber resembles in shape the outline of the flame. This insures quick vaporization, rapid combustion and better mixing by eliminating dead spaces in the combustion chamber. An overhanging arch at the back of the fire pot is sometimes used to increase the flame travel and give more time for mixing and burning, and sometimes to prevent the gases from going too directly into the boiler flues. When good atomization and vigorous mixing are achieved by the burner, combustion chamber design becomes a less critical matter. Where secondary air is used, combustion chamber design is quite important. When installing some of the vertical rotary burners, the manufacturer's instructions must be followed carefully when installing the hearth, as in this class successful performance depends upon this factor.

Boiler Settings

As the volume of space available for combustion is a determining factor in oil consumption, it is general practice to remove grates and extend the combustion chamber downward to include or even exceed the ash pit volume; in new installations the boiler may be raised to make added volume available. Approximately 1 cu ft of combustion volume should be provided for every developed boiler horsepower, and in this volume from 1.5 to 2.5 lb of oil per hour can properly be burned. This corresponds to an average liberation of about 38,000 Btu per cubic foot per hour. At times much higher fuel rates may be satisfactory. For best results, care should be taken to keep the gas velocity below 40 fps. Where checkerwork of brick is used to provide secondary air, good practice calls for about 1 sq in. of opening for each pound of oil fired per hour. Such checkerwork is best adapted to flat flames, or to conical flames that can be spread over the floor of the combustion chamber. The proper bricking of a large or even medium sized boiler for oil firing is important, and frequently it is advisable to consult an authority on this subject. The essential in combustion