

POWER SYSTEMS SERVICES DIVISION

COMBUSTION ENGINEERING, INC.

IV. POWER SYSTEMS SERVICES SCOPE OF WORK (Continued)

B. Materials and Equipment (Continued)

4. Replacement Airheater Baskets

Unit #2

- 1 - Complete set, basketed hot end heating elements, type "DJ" double undulated 32" depth fabricated from #24 USG open hearth steel.
- 1 - Complete set, basketed cold end heating elements, type NF-6.00-0.00 notched flat, 12" depth, fabricated from 18 USG low alloy steel.

5. Steam Coil Air Preheaters

a. Unit #2

- 1 - Aero-fin, 33-1/4" x 14'-0" heating coil 10" deep designed for a 400 psig sat. steam supply.

b. Unit #3

- 2 - Aero-fin, 33-1/4" x 10'-0" heating coil 10" deep, designed for a 400 psig sat. steam supply.
- 1 - Lot metalwork as necessary to adapt the above heating coils to the existing cold air ducts on units #2 and 3.
- 1 - Lot insulation as required to restore the ductwork and insulation after steam coils are installed.

6. Platforms and Stairs

- 1 - Lot of platforms and stairs to service sootblowers, all in accordance with OSHA requirements. For units #2 and 3.