

corresponding height and diameter can then be determined from Equations 6 and 7, respectively, and the economical size will then be attained. Equations 6, 7 and 9 may be simplified considerably for average operating conditions in an average size steam plant by assuming the following conditions:

Average chimney gas temperature, 500 F.....	$T_c = 960$
Mean atmospheric temperature, 62 F.....	$T_o = 522$
Average coefficient of friction, 0.016.....	$f = 0.016$
Average chimney gas density, 0.09.....	$W_c = 0.09$
Sea level elevation with barometer of 29.92.....	$B_o = 29.92$

Substituting these values in Equations 9, 7 and 6, respectively, and reducing:

$$V_c = 13.7W^{1/5} \quad (10)$$

$$D = 1.5W^{2/5} \quad (11)$$

$$H = 190D_r \quad (12)$$

Fig. 7 gives the economical chimney sizes for various amounts of gases flowing and for required draft intensities as computed from Equations 10, 11 and 12. They are based on the operating factors used in reducing Equations 6, 7 and 9 to their simpler form. The sizes shown by the curves in the chart should be used for general operating conditions only, or for installations where the required data necessary for an exact determination are difficult or impossible to secure. Whenever it is possible to secure accurate data, or the anticipated operating conditions are fairly well known, the required size should be determined from Equations 6, 7 and 9. The recommended minimum inside dimensions and heights of chimneys for small and medium size installations are given in Table 1.

GENERAL EQUATION

The general draft equation for a steam producing plant may be stated as follows:

$$D_t - h_f = h_F + h_B + h_{Bd} + h_C + h_{Br} + h_V + h_O + h_E + h_R \quad (13)$$

where

- D_t = theoretical draft intensity created by pressure transformer, inches of water.
- h_f = draft loss due to friction in pressure transformer, inches of water.
- h_F = draft loss through the fuel bed, inches of water.
- h_B = draft loss through the boiler and setting, inches of water.
- h_{Br} = draft loss through the breeching, inches of water.
- h_V = draft loss due to velocity, inches of water.
- h_{Bd} = draft loss due to bends, inches of water.
- h_C = draft loss due to contraction of opening, inches of water.
- h_O = draft loss due to enlargement of opening, inches of water.
- h_E = draft loss through the economizer, inches of water.
- h_R = draft loss through recuperators, regenerators or air heaters, inches of water.

The left hand member of Equation 13 represents the total amount of available draft created by the pressure transformer, that is, the natural

TABLE 1. RECOMMENDED MINIMUM CHIMNEY SIZES FOR HEATING BOILERS AND FURNACES†

WARM AIR FURNACE CAPACITY IN SQ. IN. OF LEADER PIPE	STEAM BOILER CAPACITY SQ. FT. OF RADI- ATION	HOT WATER HEATER CAPACITY SQ. FT. OF RADI- ATION	NOMINAL DIMEN- SIONS OF FIRE CLAY LINING IN INCHES	RECTANGULAR FLUE		ROUND FLUE		HEIGHT IN FT. ABOVE GRATE
				Actual Inside Dimensions of Fire Clay Lining in Inches	Actual Area Sq. In.	Inside Diam- eter of Lining in Inches	Actual Area Sq. In.	
790	590	973	8½ x 13	7 x 11½	81	10	79	35
1000	690	1,140	13 x 13	11¼ x 11¼	127			
	900	1,490	8½ x 18	6¾ x 16¼	110	12	113	40
	900	1,490						
	1,100	1,820	13 x 18	11¼ x 16¼	183	15	177	
	1,700	2,800						
	1,940	3,200	18 x 18	15¾ x 15¾	248			45
	2,130	3,520	20 x 20	17¼ x 17¼	298	18	254	50
	2,480	4,090				20	314	
	3,150	5,200						
	4,300	7,100	20 x 24	17 x 21	357			
	4,600	7,590	24 x 24	21 x 21	441			55
	5,000	8,250		24 x 24*	576			60
	5,570	9,190				22	380	
	5,580	9,200				24	452	65
	6,980	11,500						
	7,270	12,000		24 x 28*	672			
	8,700	14,400		28 x 28*	784			
	9,380	15,500				27	573	
	10,150	16,750		30 x 30*	900			
	10,470	17,250		28 x 32*	896			

*Dimensions are for unlined rectangular flues.

†This table is taken from the A.S.H.V.E. Code of Minimum Requirements for the Heating and Ventilation of Buildings (Edition of 1929).

draft chimney, Venturi chimney, or fan, and is equal to the theoretical intensity less the internal losses incidental to operation. The right hand member represents the sum of all of the various losses of draft throughout the entire boiler plant installation outside of the pressure transformer itself. The left hand member expresses the available intensity and is analogous to the head developed by a centrifugal pump in a water works system, while the right hand member expresses the required draft intensity and is analogous to the total dynamic head in a water works system. For a general circulation of gases then

$$D_a = D_r \quad (14)$$

where

D_a = available draft intensity, inches of water.

D_r = required draft, inches of water

The draft loss through the fuel bed (h_F), or the amount of draft required to effect a given or required rate of combustion, varies between wide limits and represents the greater portion of the required draft. In coal-fired installations, the draft loss through the fuel bed is dependent upon the following factors: (1) character and condition of the fuel, clean or dirty; (2) percentage of ash in the fuel; (3) volume of interstices in the fuel bed,