

INTER-OFFICE MEMO **TENNECO OIL P&M**

TO J. T. Sweeney

FROM W. R. Smickle

SUBJECT VCM Control Report
Period: 11/29/82 - 12/5/82

AT Flemington

DATE December 8, 1982

AT Flemington

COPY TO R. A. Donovan
J. E. Durant
W. R. Fogelsanger
F. W. Kanzler
H. R. Horton
R. A. Lojewski
W. Miringoff
S. P. Robbins
M. K. Rosen
D. I. Scofield

Area	VCM Average Level	% > 1 PPM	Number > 100 PPM
Reactor Building	< 0.1	0.06	0
Recovery Comp. Room	0	0	0
General Area	0	0	0
Pilot Plant	0.2	1.7	1
Parshall Flume	< 0.1	0.1	0

W. R. Smickle

WRS : ms

012078

INTER-OFFICE MEMO

TENNECO OIL P&M

TO W. R. Smickle

AT **Flemington**

Date December 8, 1982

FROM J. E. Durant

At Flemington

CCP/77 P. R. Bisson

SUBJECT VCM Control Report

Period: 11/29/82 - 12/5/82

Attached is a summary of the Flemington Plant VCM levels as determined by the Computerized Area Monitoring System for the week of November 29, 1982 to December 5, 1982.

J. E. Durant

J. E. Durant

JED:ms

012079

TABLE I
AREA MONITORING SYSTEM - FLEMINGTON
Weekly Summary

Period: 11/29 - 12/5/82

<u>Area</u>	<u>AVERAGE PPM, VCM</u>	<u>Total Samples</u>	<u>N</u>	<u>≥1 %</u>	<u>Number of Readings & Percentages</u>					
					<u>≥5 %</u>	<u>≥25 %</u>	<u>≥100 %</u>			
Reactor Building	<0.1	12,096	7	0.06	1	0.01	0	0	0	0
Recovery Comp. Room	0	1,344	0	0	0	0	0	0	0	0
General Area	0	6,720	0	0	0	0	0	0	0	0
Pilot Plant	0.2	5,376	94	1.7	27	0.5	5	0.1	1	0.02
Parshall Flume	<0.1	672	1	0.1	1	0.1	0	0	0	0

J E Durant
J. E. Durant


JED:ms

012080

GRAPH

FLEMINGTON BENDIX MONITORING SYSTEM
PERCENT GREATER THAN 1 AND 5 ppm VCM

REACTOR BUILDING




WEEKLY REPORT BEGINNING - JULY 5th 1982

O = % > 1 ppm

GRAPH

FLEMINGTON PLANT EXPOSURE AVERAGES

REACTOR BUILDING




WEEKLY AVERAGES BEGINNING - JULY 5th 1982

GRAPH ILL

FLEMINGTON PLANT EXPOSURE AVERAGES

PILOT PLANT



WEEKLY AVERAGES BEGINNING-JULY 5th 1982