

COPY

EBASCO SERVICES
INCORPORATED

PLAINTIFF'S EXHIBIT

BAW-403

VIA AIR MAIL

October 29, 1958

Mr A A Woodward, Acting Chief Mechanical Engineer
Public Service Company of Colorado
P O Box 840
Denver, Colorado

CHEROKEE STATION - UNIT NO. 1
STEAM GENERATING UNIT

Dear Mr Woodward:

We attach for your information one copy of Babcock & Wilcox's
Letter of October 27, 1958.

B & W states that they have no objection to the installation of two retractable blowers from Unit 2 on Boiler No. 1 in order to prevent the possibility of plugging of the superheater bank which would necessitate an outage for cleaning. However, they state that they will not at this time order replacement units for Cherokee 2. They wish first to obtain test data based on changes which have been made during the present outage to Unit 1 and if this test data and observation of the fouling of the superheater bank indicates that the blowers are not required, then they would request that these blowers be removed and installed on Unit 2 as originally intended. They further state that if it is required that the blowers are needed for Unit 1 they will order out two additional blowers for Unit 2 but after Unit 2 has gone into operation they will consider the necessity of furnishing two additional blowers for the superheater on Unit 2. They also mention that the arrangement of the furnace surface and screen at the entrance to the superheater is different on Unit 2. They do not believe that the need for additional blowers for the superheater on Unit 1 will necessarily justify ordering additional blowers for the same location on Unit 2 at this time.

We trust you are in agreement with this suggested means of procedure.

Very truly yours,

RRE/ia

Encl

cc: M M Koch
A A Woodward
L M Robertson
B A Snow
E C Yaw/R R Bennett/J C McCoy
H L Lowe/J P Kennell/R B Harvey
J R Smith/R G Ganahl
W O Harris Jr
W G Lauffer

E C Yaw
Chief Mechanical Engineer

By

R R Bennett

COPY

WAD00045