Case: 48106-3

PLAINTIFF'S EXHIBIT

SWB-126

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582 [illegible]00

August 21, 1980

Mr. Roy Deitchman
New York Telephone Company
1095 Avenue of the Americas
Room 2561
New York, New York 10036

Dear Roy:

The bulk sample you sent from 277 Park Avenue, BSMT Frame room has been analyzed for asbestos by McCrone Associates, Chicago, Illinois. The sample was found to contain 40-45% chrysotile mixed with mineral wool. The analytical techques used were polarized light microscopy and dispersion staining.

Vicki

MH-8691-VRC-sma Vicki R. Cohen

Ref: 1193

G. H. Collings, Jr., M.D. - NYT

R. L. Beach - AT&T
N. J. DeCapua
J. M. Degen THIS COPY FOR
R. W. Stone, M.D.

W. J. Schreibeis
G. M. Wilkening

CONFIDENTIAL

003623