

CHEMICAL EXPOSURE INDEX AUDIT

CHLOR-ALKALI II

LOUISIANA DIVISION

JULY 1992

REFERENCE #11

QUESTION #27

DO A 046971
CONFIDENTIAL

FULL FACE MASK INSPECTION

MONTHLY C-9 AUDIT

NAME OF AUDITER: W. Dyer DATE OF AUDIT: 1-22-92

THINGS TO CHECK

FACEPIECE:

1. CLEAN
2. NOT CRACKED
3. LENS NOT LOOSE
OR SCRATCHED.

HEADSTRAPS:

1. ELASTICITY
2. NO BROKEN BUCKLES
3. NO BREAKS
4. NO WORN SERRATIONS

EXHALATION VALVE:

1. RUBBER NOT TORN
2. COVER IN PLACE
3. COVER NOT BROKEN

NUMBER OF SANITIZED, BAGGED MASKS IN THE RESPIRATORY
CABINET

SCOTT-O-VISTA 2

SCOTT 30 MINUTE 5

OTHER FACE MASKS 5

WITH SEAL AND IN DATE

13

DO A 046972
CONFIDENTIAL

DO A 046973
CONFIDENTIAL

C-9 MONTHLY CHECK of SCOTT AIR PACKS

UNIT #	GOOD REGULATOR	HYD. TEST DATE	STRAPS MASK	EXTENDED HARNESS	BOTTLE PRESS. > 1500#
# 1	✓	10/88	✓	✓	✓
# 2	✓	4/88	✓	✓	✓
# 3	✓	6/90	✓	✓	✓
# 4	✓	9/90	✓	✓	✓
# 5	✓	6/90	✓	✓	✓
# 6	✓	9/91	✓	✓	✓
# 7	✓	5/88	✓	✓	✓
# 8	✓	11/91	✓	✓	✓
# 9	✓	12/87	✓	✓	✓
# 10	✓	2/90	✓	✓	✓
# 11	✓	12/86	✓	✓	✓
# 12	✓	1/89	✓	✓	✓
# 1 5 MINUTE UNIT IN THE C/R	N/A	1/88	✓	✓	✓
# 2 5 MINUTE UNIT IN THE C/R	N/A	1/89	✓	✓	✓
# 3 5 MINUTE UNIT IN THE C/R	N/A	1/88	✓	✓	✓

EXTRA BOTTLES IN WAREHOUSE

COMMENTS: Have to send bottle
for # 11 out for HYD TEST

	BOTTLE PRESSURE GT 1500 PSIG
BOTTLE # 1	✓
BOTTLE # 2	✓
BOTTLE # 3	✓
BOTTLE # 4	✓
BOTTLE # 5	✓
BOTTLE # 6	✓
BOTTLE # 7	✓
BOTTLE # 8	✓
BOTTLE # 9	✓
BOTTLE # 10	✓

DATE 1-22-92

NAME W. DYER

DO A 046974
CONFIDENTIAL

CHECKSHEET EAST

DO A 046975
CONFIDENTIAL

ME	2006/1/10	DATE	1/10
----	-----------	------	------