

TO: #333, Danville, R. Reeder

October 6, 1986

FROM: #151, C. D. Byers

SUBJECT: INSULATION ANALYSIS

AR 1565

PLAINTIFF'S EXHIBIT

USG-1480

A sample was received on October 1 in a plastic bag sealed in an envelope. The sample was not labeled but appeared to be a piece of insulation tile. The sample was analyzed by polarized light microscopy using dispersion staining. The sample contains asbestos.

CB/ts

#143, M. F. O'Toole
#151, B. W. Ost

176-S J. Rabe