

MON-191

CONFIDENTIALRENTAL JOB 3375CHOCOLATE BAYOU REFINERY

CONFIRMATION OF CONFERENCE

<u>Monsanto</u>	<u>Bechtel</u>	Date:	November 9, 1961
S. A. Bjorkman	J. W. Nelson	Place:	San Francisco
		Recorded by:	J. W. Nelson
		Subject:	Specification 1 # 3
			<u>1-CN-131</u>

Mr. Robert Muir, of Union Asbestos and Rubber Company, called and reviewed Specification 1 # 3, which calls for use of U-200 polyurethane as supplied by Union Asbestos. Since the specification was written, Union has gained additional experience with this relatively new material. As a result, Mr. Muir suggested (1) that the type and amount of banding used to hold the U-200 onto the equipment be changed; (2) that double layer polyurethane be used on all vessels and lines below minus 50F; (3) that the anti-abrasive material between layers of polyurethane was not required. (4) that expansion joints were not required on the inner layer of polyurethane.

These suggestion were discussed with Mr. Bjorkman on 11-9-61. He agreed with the revised banding requirements, the application of double layer polyurethane on surfaces less than minus 50F, and the elimination of expansion joints on the inner layer of polyurethane. Mr. Bjorkman will discuss the possibility of eliminating the anti-abrasion material with people in St. Louis next week.

As a result of these changes, some of typical drawings in Specification 1 # 3 will have to be revised. Mr. Bjorkman suggested that the entire specification be revised in the light of these changes

[Signature]
G. L. Johnson

JM/zmt

Distribution

C 002886

<u>Monsanto</u>	<u>Bechtel</u>		
R. E. Lanz	G. L. Bruno/J. H. Poulson	W. R. Ayers	J. Leisel
W. K. Volz	G. L. Johnson	M. M. Perkins	
W. L. Bolles (3)	A. C. Page (2)	W. Kest	
S. Bjorkman	S. E. Meuse	T. W. Moran (2)	
	D. F. Mordoff	K. G. Wolfe	
	M. H. Hyde	M. V. Marlowe	
	W. B. Hodge	L. T. Tuttle	

LAM022700