

Permit Number: EPR/BU5453IY
Operator: AGC Chemicals Europe Limited
Facility: AGC Chemicals Europe, Hillhouse

Form Number: n/a

A14 - Thermal Treatment Plant Summary for the period from ...April 2023... to ...June 2023...

Month	Number of Reportable Days (Waste onto the Thermal Treatment Plant for more than 21.5 hours)	Number of Exceedances of the Permit Limits, during reportable days	Number of Non-Reportable Days (Waste onto the Thermal Treatment Plant for less than 21.5 hours)	Number of Exceedances of the Permit Limits, during non-reportable days when waste into the Thermal Treatment Plant
April 2023	0	0	30	0
May 2023	0	0	31	0
June 2023	0	0	30	0

Thermal Oxidiser was offline for the majority of Q2 while undergoing repair as discussed with EA. There were approximately 5.5 days of re-commissioning where the Thermal Oxidiser was destroying liquid waste (high boilers from AGC plant) in April 04/04/23 - 10/04/23 before further failure halted re-commissioning, however no gaseous waste streams (from Low Boiler Stack or Waste Acid Stack) were incinerated.

Recommissioning of liquid waste commenced 06/07/2023 and gaseous waste streams (from Low Boiler Stack and Waste Acid Stack) will be commissioned in August 2023 with operation expected from September 2023.

No data is therefore being reported for Q2 2023 as operation has not commenced.

Signed*: [REDACTED]

Date: 31/07/2023

(*authorised to sign as representative of AGC Chemicals Europe Limited)