



*** Reference number- 8292
:NO 650716.150
:TL Copy letter ABA Perth to Public Health Department *
Recurring trouble with sewer lines to septic tanks to
installation at Wittenoom
:SO AUTHOR Unknown
OCCUPATION for General Superintendent
ORGANISATION ABA
PLACE Perth WA
REFERENCE File marked "Govt - State Sundry"
(ABA Library Index No. GS.04)
:TY LETTER
:LO Perth CC CDR 33
:CI NAME -
OCCUPATION Under Secretary
ORGANISATION Public Health Department
PLACE Perth WA
:AD KEYWORDS TOWNSHIP GOVERNMENT
:TT

16th July 1965

The Under Secretary
Public Health Department
57 Murray Street
PERTH

Dear Sir,

SEWER LINES - WITTENOOM

We have constantly recurring trouble with sewer lines to
septic tanks in our installation at Wittenoom due to roots of
shrubs penetrating the cement joints and choking the
pipeline. Similar troubles occur with drain lines.

If we were able to use PVC piping and fittings the number of
joints would be considerably reduced and minimise this
hazard.

It would be appreciated if you would give this consideration
and let us have your comments.

Yours faithfully,
AUSTRALIAN BLUE ASBESTOS PTY LTD

***Handwriting (Initialled by) @@@
For General Superintendent

:##