

HEATING VENTILATING AIR CONDITIONING GUIDE 1939

TABLE 1. DESIGN DRY- AND WET-BULB TEMPERATURES, WIND VELOCITIES, AND WIND DIRECTIONS FOR JUNE, JULY, AUGUST, AND SEPTEMBER

STATE	CITY	DESIGN DRY-BULB	DESIGN WET-BULB	SUMMER WIND VELOCITY MPH	PREVAILING SUMMER WIND DIRECTION
Ala.	Birmingham	95	78	5.2	S
	Mobile	95	80	8.6	SW
Ariz.	Phoenix	105	76	6.0	W
Ark.	Little Rock	95	78	7.0	NE
Calif.	Los Angeles	90	70	6.0	SW
	San Francisco	90	65	11.0	SW
Colo.	Denver	95	64	6.8	S
Conn.	New Haven	95	75	7.3	S
Dela.	Wilmington	95	78	9.7	SW
D. C.	Washington	95	78	6.2	S
Fla.	Jacksonville	95	78	8.7	SW
	Tampa	94	79	7.0	E
Ga.	Atlanta	95	76	7.3	NW
	Savannah	95	78	7.8	SW
Idaho	Boise	95	65	5.8	NW
Ill.	Chicago	95	75	10.2	NE
	Peoria	95	76	8.2	S
Ind.	Indianapolis	95	76	9.0	SW
Iowa	Des Moines	95	77	6.6	SW
Kansas	Wichita	100	75	11.0	S
Ky.	Louisville	95	76	8.0	SW
La.	New Orleans	95	79	7.0	SW
	Shreveport	100	78	6.2	S
Maine	Portland	90	73	7.3	S
Md.	Baltimore	95	78	6.9	SW
Mass.	Boston	92	75	9.2	SW
Mich.	Detroit	95	75	10.3	SW
Minn.	Minneapolis	95	75	8.4	SE
Miss.	Vicksburg	95	78	6.2	SW
Mo.	Kansas City	100	76	9.5	S
	St. Louis	95	78	9.4	SW
Mont.	Helena	95	67	7.3	SW
Nebr.	Lincoln	95	75	9.3	S
Nev.	Reno	95	65	7.4	W
N. H.	Manchester	90	73	5.6	NW
N. J.	Trenton	95	78	10.0	SW
N. Y.	Albany	92	75	7.1	S
	Buffalo	93	75	12.2	SW
	New York	95	75	12.9	SW
N. M.	Santa Fe	90	65	6.5	SE
N. C.	Asheville	90	75	5.6	SE
	Wilmington	95	79	7.8	SW
N. Dak.	Bismarck	95	73	8.8	NW
Ohio	Cincinnati	95	78	6.6	SW
	Cleveland	95	75	9.9	S
Okla.	Oklahoma City	101	76	10.1	S
Oreg.	Portland	90	65	6.6	NW
Pa.	Philadelphia	95	78	9.7	SW
	Pittsburgh	95	75	9.0	NW
R. I.	Providence	93	75	10.0	NW
S. C.	Charleston	95	80	9.9	SW
	Greenville	95	76	6.8	NE
S. Dak.	Sioux Falls	95	75	7.6	S
Tenn.	Chattanooga	95	77	6.5	SW
	Memphis	95	78	7.5	SW

CHAPTER 8. COOLING LOAD

TABLE 1. DESIGN DRY AND WET-BULB TEMPERATURES, WIND VELOCITIES, AND WIND DIRECTIONS FOR JUNE, JULY, AUGUST, AND SEPTEMBER (Concluded)

STATE	CITY	DESIGN DRY-BULB	DESIGN WET-BULB	SUMMER WIND VELOCITY MPH	PREVAILING SUMMER WIND DIRECTION
Texas	Dallas	100	78	9.4	S
	El Paso	100	69	6.9	E
	Galveston	95	80	9.7	S
	Houston	95	78	7.7	S
	San Antonio	100	78	7.4	SE
Utah	Salt Lake City	92	63	8.2	SE
Vt.	Burlington	90	73	8.9	S
Va.	Norfolk	95	78	10.9	S
	Richmond	95	78	6.2	SW
Wash.	Seattle	85	65	7.9	S
	Spokane	90	65	6.5	SW
W. Va.	Parkersburg	95	75	5.3	SE
Wisc.	Madison	95	75	8.1	SW
	Milwaukee	95	75	10.4	S
Wyo.	Cheyenne	95	65	9.2	S

temperatures given are not exceeded more than 5 to 8 per cent of the time during a cooling season of 1200 hours in June, July, August and September for an average year.

COMPONENTS OF HEAT GAIN

A cooling load determination is composed of five components which may be classified in the following manner:

1. Normal heat transfer through windows, walls, partitions, doors, floors, ceilings, etc.
2. Transfer of solar radiation through windows, walls, doors, skylights, or roof.
3. Heat emission of occupants within enclosures.
4. Heat introduced by infiltration of outside air or controlled ventilation.
5. Heat emission of mechanical, chemical, gas, steam, hot water and electrical appliances located within enclosures.

The components of heat gain, classified by source are further classified as sensible and latent heat gain.

The first two components fall into the classification of sensible heat gain, that is, they tend to raise the temperature of the air within the structure. The last three components not only produce sensible heat gain but they may also tend to increase the moisture content of the air within the structure.

Normal Heat Transmission

By normal heat transmission, as distinguished from solar heat transmission is meant the transmission of heat through windows, walls, partitions, etc. from without to interior of enclosure by virtue of difference between outside and inside air temperatures. This load is calculated in a