

INTER-COMPANY CORRESPONDENCE

RECEIVED

CARBIDE AND CARBON CHEMICALS COMPANY APR 23 1953

A DIVISION OF
UNION CARBIDE AND CARBON CORPORATION
ENGINEERING AND CONSTRUCTION DEPARTMENT—DIVISION CC
P. O. BOX 8361, SOUTH CHARLESTON 3, W. VA.

C
P. G. F.
R. W. P.
R. H. B.

TO Mr. L. J. Dempsey
LOCATION SOUTH CHARLESTON PLANT

DATE April 20, 1953

ANSWERING LETTER DATE

ATTENTION
COPIES TO

SUBJECT BOILER NO. 9 PLANT CI
WP-3058

Dear Mr. Dempsey:

A recent review of the contract with the Riley Stoker Company reveals that some discrepancies exist pertaining to the insulation responsibility. According to the design report we would proceed in our customary manner to provide insulation for this boiler; however, Riley's contract includes practically all of the insulation and to my knowledge we have had no information to the contrary that we would not proceed in the customary manner.

The
no.
1494
1450
a. b.

In order that the job be more complete it should be drawn to the attention of Mr. F. G. Feeley, Jr., that the section of the flue gas duct from the I.D. fan to the stack indicated as Item 3058E-2405 in the design report should be included in the Riley contract for insulation. Also, the portion of the stack inside the building and where it passes through the roof should be insulated to reduce the temperature within the building. Again, removable insulation covers for the drum manholes should be indicated.

I feel quite certain that Mr. T. L. Owens is desirous of having the work as outlined included.

Very truly yours,

/s/ Ray Thomas

Ray Thomas/es/bw

PLAINTIFF'S
EXHIBIT

76036-00

UCASB01123959

WV-17840