



E. I. DU PONT DE NEMOURS & COMPANY
INCORPORATED

WILMINGTON, DELAWARE 19898

EMPLOYEE RELATIONS DEPARTMENT

CC: D. ~~G. Windsor~~

Survey Exped
Soci. file

[illegible]

February 4, 1985

L. T. FREELAND
POLYMER PRODUCTS DEPARTMENT
BEALMONT

ASBESTOS CEMENT (AC) PIPE FOR WATER LINES

This confirms our recent telephone conversation in which I indicated that the Safety and Occupational Health Division recommends that no new AC pipe be installed for potable water.

Some pertinent information which we recognize in making this recommendation is:

- Municipal water systems already contain a lot of AC pipe. A 1981 American City and County water main pipe survey reported that the proportion of AC pipe in place was 13.9 percent in 1980. It was estimated that 40 percent of pipe installed in 1980 was AC.
- The American Water Works Association standard permits the use of AC pipe except for water which is highly corrosive toward AC. Corrosivity is measured by a "aggressivity index" which is a function of pH, total alkalinity and calcium hardness. However, some studies have indicated that the AI is not appropriate for predicting fiber release from AC pipe because other factors, e.g., iron, silica, manganese and zinc may contribute some protection against corrosion.
- Deteriorated AC pipe has been found in some municipal water mains. In at least one case, a scraping procedure used to clean the pipe interior

DUP 0908885

DU 028746

Even though AC pipe for potable water lines has not been proven to be detrimental to health, we recommend that it not be used in new installations because of the employee relations, public relations and eventual handling problems involved.

SAFETY AND OCCUPATIONAL HEALTH DIVISION

Bob

J. R. Martin, Survey Supervisor

JRM:mmv