

Monsanto

FROM (NAME & LOCATION) R. V. Sharp - Purchasing, Texas City PER (Ext. 3211)

DATE April 26, 1985 cc. A. H. Conrad
J. D. McPhail
SUBJECT Second Quarterly Safety and Housekeeping Jake Linkey
Inspection - Dept. 33 R. E. Mears
REFERENCE SHAC
TO : L. Vornkahl

The Second Quarter Safety and Housekeeping inspection for Lactic Acid was conducted by George Pappas, Jake Linkey, Roger Mears, and Rick Sharp on 4/23/85.

Dept. 33 received an outstanding rating.


Safety

1. Procedure in place for "bypassing protective devices."
2. AVIP is up-to-date.
3. Plectron working O.K.
4. Employee knowledge of hazardous material handling satisfactory.
5. Ladder did not have inspection tag - stepladder on top floor.
6. Possible asbestos exposure on elbow on first floor east of control room.

Housekeeping

1. Clutter around T-42 and T-28.
2. Small sign broken next to D2.

Please respond to Jim McPhail and Doug Barfoot by May 17, 1985.


R. V. Sharp

RVS:wy

SC

000328

LAM001525